



MOTEN LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
1	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004384	Classroom	3	In room 328	WT-042916-4401-A	2.39	WT-042916-4401-B	1.21				
2	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004383	Cooler	3	In hallway adjacent to room 327	WT-042916-4400-A	< 1	WT-042916-4400-B	< 1				
3	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004382	Classroom	3	In room 326	WT-042916-4399-A	< 1	WT-042916-4399-B	< 1				
4	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004381	Classroom	3	In room 327	WT-042916-4398-A	5.95	WT-042916-4398-B	< 1				
5	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004380	Classroom	3	In room 324	WT-042916-4397-A	4.93	WT-042916-4397-B	< 1				
6	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004379	Classroom	3	In room 322	WT-042916-4396-A	6.66	WT-042916-4396-B	1.05				
7	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004378	Cooler	3	In hallway adjacent to room 317	WT-042916-4395-A	< 1	WT-042916-4395-B	< 1				
8	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004377	Classroom	3	In room 315	WT-042916-4394-A	2.42	WT-042916-4394-B	< 1				
9	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004376	Classroom	3	In room 313	WT-042916-4393-A	1.64	WT-042916-4393-B	< 1				
10	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004375	Cooler	3	In hallway adjacent to room 312	WT-042916-4392-A	< 1	WT-042916-4392-B	< 1				
11	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004374	Cooler	3	In hallway adjacent to room 312	Left High	WT-042916-4391-A	< 1	WT-042916-4391-B	< 1			
12	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004373	Classroom	3	In room 311	WT-042916-4390-A	1.63	WT-042916-4390-B	< 1				
13	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004372	Classroom	3	In room 310	WT-042916-4389-A	< 1	WT-042916-4389-B	< 1				
14	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004371	Classroom	3	In room 309	WT-042916-4388-A	< 1	WT-042916-4388-B	3.02				
15	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004370	Classroom	3	In room 308	WT-042916-4387-A	4.5	WT-042916-4387-B	< 1				
16	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004369	Classroom	3	In room 307	WT-042916-4386-A	2.34	WT-042916-4386-B	< 1				
17	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004368	Classroom	3	In room 305	WT-042916-4385-A	1.17	WT-042916-4385-B	< 1				
18	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004367	Cooler	3	In hallway adjacent to room 301	Right High	WT-042916-4384-A	< 1	WT-042916-4384-B	< 1			
19	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004366	Cooler	3	In hallway adjacent to room 301	Left High	WT-042916-4383-A	< 1	WT-042916-4383-B	< 1			
20	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004365	Classroom	3	In room 302	WT-042916-4382-A	6.13	WT-042916-4382-B	< 1				
21	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004364	Cooler	2	In hallway adjacent to room 216	WT-042916-4381-A	< 1	WT-042916-4381-B	< 1				
22	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004363	Classroom	2	In room 212	Right	WT-042916-4380-A	9.35	WT-042916-4380-B	3.12			
23	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004362	Classroom	2	In room 212	Mid	WT-042916-4379-A	28	WT-042916-4379-B	2.57	Filter will be installed and then retested		
24	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004361	Classroom	2	In room 212	Left	WT-042916-4378-A	7.1	WT-042916-4378-B	< 1			
25	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004360	Classroom	2	In room 210	WT-042916-4377-A	< 1	WT-042916-4377-B	< 1				
26	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004359	Classroom	2	In room 210	Left	WT-042916-4376-A	3.97	WT-042916-4376-B	< 1			
27	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004358	Cooler	2	In hallway across room 210	Right Low	WT-042916-4375-A	< 1	WT-042916-4375-B	< 1			
28	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004357	Cooler	2	In hallway across room 210	Left High	WT-042916-4374-A	< 1	WT-042916-4374-B	< 1			
29	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004356	Break Room	2	In room 208	WT-042916-4373-A	< 1	WT-042916-4373-B	< 1				
30	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004355	Classroom	2	In room 209	WT-042916-4372-A	13.1	WT-042916-4372-B	1.48				
31	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004354	Classroom	2	In room 204	WT-042916-4371-A	3.47	WT-042916-4371-B	1.68				
32	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004353	Cooler	2	In hallway adjacent to room 203A	Right High	WT-042916-4370-A	< 1	WT-042916-4370-B	< 1			
33	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004352	Cooler	2	In hallway adjacent to room 203A	Left High	WT-042916-4369-A	< 1	WT-042916-4369-B	< 1			
34	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004351	Cooler	2	In hallway adjacent to room 224B	WT-042916-4368-A	< 1	WT-042916-4368-B	< 1				
35	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004350	Cooler	1	In hallway adjacent to room 134	WT-042916-4367-A	< 1	WT-042916-4367-B	< 1				
36	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004349	Classroom	1	In room 134	WT-042916-4366-A	1.92	WT-042916-4366-B	1.28				
37	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004348	Classroom	1	In room 133	WT-042916-4365-A	19.5	WT-042916-4365-B	1.94	Filter will be installed and then retested			
38	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004347	Classroom	1	In room 130	WT-042916-4364-A	< 1	WT-042916-4364-B	< 1				
39	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004346	Cooler	1	In hallway adjacent to room 124	WT-042916-4363-A	< 1	WT-042916-4363-B	< 1				
40	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004345	Classroom	1	In room 120	WT-042916-4362-A	1.43	WT-042916-4362-B	< 1				
41	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004344	Cooler	1	In hallway adjacent to room 119	Right Low	WT-042916-4361-A	< 1	WT-042916-4361-B	< 1			
42	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004343	Cooler	1	In hallway adjacent to room 119	WT-042916-4360-A	< 1	WT-042916-4360-B	< 1				
43	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004342	Health Suite	1	In healthsuite	WT-042916-4359-A	1.11	WT-042916-4359-B	< 1				
44	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004341	Classroom	1	In room 106	WT-042916-4358-A	2.76	WT-042916-4358-B	1.13				
45	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004340	Other	1	In occupational physical therapy room 102	WT-042916-4357-A	2.27	WT-042916-4357-B	< 1				
46	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004339	Cooler	1	In hallway adjacent to room 103	Low	WT-042916-4356-A	< 1	WT-042916-4356-B	< 1			
47	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004338	Cooler	1	In hallway adjacent to girls restroom 103	Left High	WT-042916-4355-A	< 1	WT-042916-4355-B	< 1			
48	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004337	Cooler	Ground Floor	In hallway adjacent to room G31	WT-042916-4354-A	< 1	WT-042916-4354-B	< 1				
49	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004336	Classroom	Ground Floor	In room G31	WT-042916-4353-A	< 1	WT-042916-4353-B	< 1				
50	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004335	Classroom	Ground Floor	In room G30	WT-042916-4352-A	< 1	WT-042916-4352-B	< 1				
51	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004334	Classroom	Ground Floor	In room G29	WT-042916-4351-A	< 1	WT-042916-4351-B	< 1				
52	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004333	Cooler	Ground Floor	In hallway adjacent to room B25	WT-042916-4350-A	< 1	WT-042916-4350-B	< 1				
53	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004332	Classroom	Ground Floor	In room G17	WT-042916-4349-A	< 1	WT-042916-4349-B	< 1				
54	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004331	Classroom	Ground Floor	In room B14	WT-042916-4348-A	< 1	WT-042916-4348-B	< 1				
55	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004330	Cooler	Ground Floor	In hallway adjacent to room G10	Right Low	WT-042916-4347-A	< 1	WT-042916-4347-B	< 1			
56	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004329	Cooler	Ground Floor	In hallway adjacent to room G10	Left High	WT-042916-4346-A	< 1	WT-042916-4346-B	< 1			
57	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004328	Kitchen	Ground Floor	In kitchen	Right	WT-042916-4345-A	< 1	WT-042916-4345-B	< 1			
58	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004327	Kitchen	Ground Floor	In kitchen	Mid	WT-042916-4344-A	< 1	WT-042916-4344-B	< 1			
59	MOTEN ELEMENTARY SCHOOL	5/6/2016	WS-004326	Kitchen	Ground Floor	In kitchen	Left	WT-042916-4343-A	< 1	WT-042916-4343-B	< 1			



MOTEN LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
60 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004325	Kitchen	Ground Floor	In kitchen (spray nozzle)	High WT-042916-4342- A	< 1	WT-042916-4342- B	< 1				
61 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004324	Kitchen	Ground Floor	In kitchen	Low WT-042916-4341- A	< 1	WT-042916-4341- B	< 1				
62 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004323	Cooler	Ground Floor	In hallway adjacent to room G06	Right Low WT-042916-4340- A	< 1	WT-042916-4340- B	< 1				
63 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004322	Cooler	Ground Floor	In hallway adjacent to B06	High WT-042916-4339- A	< 1	WT-042916-4339- B	< 1				
64 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004321	Classroom	Ground Floor	In room G05	WT-042916-4338- A	1.01	WT-042916-4338- B	< 1				
65 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004320	Classroom	Ground Floor	In room G01	WT-042916-4337- A	< 1	WT-042916-4337- B	< 1				
66 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004319	Classroom	Basement	In room B07	WT-042916-4336- A	< 1	WT-042916-4336- B	< 1				
67 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004318	Cooler	Basement	In hallway across from B08	WT-042916-4335- A	< 1	WT-042916-4335- B	< 1				
68 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004317	Classroom	Basement	In room B08	WT-042916-4334- A	27.1	WT-042916-4334- B	3.37	Filter will be installed and then retested			
69 MOTEN ELEMENTARY SCHOOL	5/6/2016	WS- 004316	Utility	Basement	In room B09	WT-042916-4333- A	7.87	WT-042916-4333- B	1.29				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.