



# MOTEN ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	MOTEN ELEMENTARY SCHOOL	WS- 004356	12/20/2016	2	Break Room	In break room 208	FT-102016-004356-A	< 1	FT-102016-004356-B	< 1
2	MOTEN ELEMENTARY SCHOOL	WS- 002322	12/20/2016	1	Break Room	In administrative work room 113	FT-102016-002322-A	< 1	FT-102016-002322-B	< 1
3	MOTEN ELEMENTARY SCHOOL	WS- 004332	12/20/2016	Ground Floor	Classroom Faucet	In classroom G17	FT-122016-004332-A	< 1	FT-122016-004332-B	< 1
4	MOTEN ELEMENTARY SCHOOL	WS- 004335	12/20/2016	Ground Floor	Classroom Faucet	In classroom G30	FT-122016-004335-A	< 1	FT-122016-004335-B	< 1
5	MOTEN ELEMENTARY SCHOOL	WS- 004336	12/20/2016	Ground Floor	Classroom Faucet	In classroom G31	FT-122016-004336-A	< 1	FT-122016-004336-B	< 1
6	MOTEN ELEMENTARY SCHOOL	WS- 004347	12/20/2016	1	Classroom Faucet	In classroom 130	FT-122016-004347-A	< 1	FT-122016-004347-B	< 1
7	MOTEN ELEMENTARY SCHOOL	WS- 004319	12/20/2016	Basement	Classroom Faucet	In classroom B07	FT-122016-004319-A	< 1	FT-122016-004319-B	< 1
8	MOTEN ELEMENTARY SCHOOL	WS- 004320	12/20/2016	Ground Floor	Classroom Faucet	In classroom G01	FT-122016-004320-A	< 1	FT-122016-004320-B	< 1
9	MOTEN ELEMENTARY SCHOOL	WS- 004331	12/20/2016	Ground Floor	Classroom Faucet	In classroom G14	FT-122016-004331-A	< 1	FT-122016-004331-B	< 1
10	MOTEN ELEMENTARY SCHOOL	WS- 004321	12/20/2016	Ground Floor	Classroom Faucet	In classroom G05	FT-122016-004321-A	< 1	FT-122016-004321-B	< 1
11	MOTEN ELEMENTARY SCHOOL	WS- 004334	12/20/2016	Ground Floor	Classroom Faucet	In classroom G29	FT-122016-004334-A	< 1	FT-122016-004334-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb