



# Moten ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002322	6/16/2017	6/16/2018	1	Break Room	In administrative work room 113	WF-62017-002322	11/21/2017	FT-FY18--62017-002322-A	<1	FT-FY18--62017-002322-B	<1
WS- 004319	10/31/2017	10/31/2018	Basement	Classroom Faucet	In classroom B07	WF-102017-004319	11/21/2017	FT-FY18-102017-004319-A	<1	FT-FY18-102017-004319-B	<1
WS- 004323	6/16/2017	6/16/2018	Ground Floor	Cooler	In hallway adjacent to room G06	WF-62017-004323	11/21/2017	FT-FY18--62017-004323-A	<1	FT-FY18--62017-004323-B	<1
WS- 004329	6/16/2017	6/16/2018	Ground Floor	Cooler	In hallway adjacent to room G10	WF-62017-004329	11/21/2017	FT-FY18--62017-004329-A	<1	FT-FY18--62017-004329-B	<1
WS- 004330	6/16/2017	6/16/2018	Ground Floor	Cooler	In hallway adjacent to room G10	WF-62017-004330	11/21/2017	FT-FY18--62017-004330-A	<1	FT-FY18--62017-004330-B	<1
WS- 004332	10/31/2017	10/31/2018	Ground Floor	Classroom Faucet	In classroom G17	WF-102017-004332	11/21/2017	FT-FY18-102017-004332-A	<1	FT-FY18-102017-004332-B	<1
WS- 004334	10/31/2017	10/31/2018	Ground Floor	Classroom Faucet	In classroom G29	WF-102017-004334	11/21/2017	FT-FY18-102017-004334-A	<1	FT-FY18-102017-004334-B	<1
WS- 004342	6/16/2017	6/16/2018	1	Health Suite	In health suite	WF-62017-004342	11/21/2017	FT-FY18--62017-004342-A	<1	FT-FY18--62017-004342-B	<1
WS- 004347	10/31/2017	10/31/2018	1	Classroom Faucet	In classroom 130	WF-102017-004347	11/21/2017	FT-FY18-102017-004347-A	<1	FT-FY18-102017-004347-B	<1
WS- 004351	6/16/2017	6/16/2018	2	Cooler	In hallway adjacent to room 224B	WF-62017-004351	11/21/2017	FT-FY18--62017-004351-A	<1	FT-FY18--62017-004351-B	<1
WS- 004357	6/16/2017	6/16/2018	2	Cooler	In hallway across from room 210	WF-62017-004357	11/21/2017	FT-FY18--62017-004357-A	<1	FT-FY18--62017-004357-B	<1
WS- 004358	6/16/2017	6/16/2018	2	Cooler	In hallway across from room 210	WF-62017-004358	11/21/2017	FT-FY18--62017-004358-A	<1	FT-FY18--62017-004358-B	<1
WS- 004378	6/16/2017	6/16/2018	3	Cooler	In hallway adjacent to room 317	WF-62017-004378	11/21/2017	FT-FY18--62017-004378-A	<1	FT-FY18--62017-004378-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004324	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	11/21/2017	FT-FY18-102017-004324-A	<1	FT-FY18-102017-004324-B	<1	