



Moten ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002322	5/18/2018	5/18/2019	1	Break Room	In administrative work room 113	WF-05182018-002322	10/24/2018	FT-FY19-102018-002322-A	< 1	FT-FY19-102018-002322-B	< 1
WS-004318	5/18/2018	5/18/2019	Basement	Cooler	In hallway across from room B08	WF-05182018-004318	10/24/2018	FT-FY19-102018-004318-A	< 1	FT-FY19-102018-004318-B	< 1
WS-004319	10/9/2018	10/9/2019	Basement	Classroom Faucet	In classroom B07	WF-10092018-004319	10/24/2018	FT-FY19-102018-004319-A	< 1	FT-FY19-102018-004319-B	< 1
WS-004320	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G01	WF-10092018-004320	10/24/2018	FT-FY19-102018-004320-A	< 1	FT-FY19-102018-004320-B	< 1
WS-004321	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G05	WF-10092018-004321	10/24/2018	FT-FY19-102018-004321-A	< 1	FT-FY19-102018-004321-B	< 1
WS-004322	5/18/2018	5/18/2019	Ground Floor	Cooler	In hallway adjacent to room G06 High Left	WF-05182018-004322	10/24/2018	FT-FY19-102018-004322-A	< 1	FT-FY19-102018-004322-B	< 1
WS-004323	5/18/2018	5/18/2019	Ground Floor	Cooler	In hallway adjacent to room G06 Low Right	WF-05182018-004323	10/24/2018	FT-FY19-102018-004323-A	< 1	FT-FY19-102018-004323-B	< 1
WS-004329	5/18/2018	5/18/2019	Ground Floor	Cooler	In hallway adjacent to room G10 High Left	WF-05182018-004329	10/24/2018	FT-FY19-102018-004329-A	< 1	FT-FY19-102018-004329-B	< 1
WS-004330	5/18/2018	5/18/2019	Ground Floor	Cooler	In hallway adjacent to room G10 Low Right	WF-05182018-004330	10/24/2018	FT-FY19-102018-004330-A	< 1	FT-FY19-102018-004330-B	< 1
WS-004331	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G14	WF-10092018-004331	10/24/2018	FT-FY19-102018-004331-A	< 1	FT-FY19-102018-004331-B	< 1
WS-004332	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G17	WF-10092018-004332	10/24/2018	FT-FY19-102018-004332-A	< 1	FT-FY19-102018-004332-B	< 1
WS-004333	5/18/2018	5/18/2019	Ground Floor	Cooler	In hallway adjacent to room G25	WF-05182018-004333	10/24/2018	FT-FY19-102018-004333-A	< 1	FT-FY19-102018-004333-B	< 1
WS-004334	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G29	WF-10092018-004334	10/24/2018	FT-FY19-102018-004334-A	< 1	FT-FY19-102018-004334-B	< 1
WS-004335	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G30	WF-10092018-004335	10/24/2018	FT-FY19-102018-004335-A	< 1	FT-FY19-102018-004335-B	< 1
WS-004336	10/9/2018	10/9/2019	Ground Floor	Classroom Faucet	In classroom G31	WF-10092018-004336	10/24/2018	FT-FY19-102018-004336-A	< 1	FT-FY19-102018-004336-B	< 1
WS-004337	5/18/2018	5/18/2019	Ground Floor	Cooler	In hallway adjacent to room G31	WF-05182018-004337	10/24/2018	FT-FY19-102018-004337-A	< 1	FT-FY19-102018-004337-B	< 1
WS-004338	5/18/2018	5/18/2019	1	Cooler	In hallway adjacent to girls' restroom 103 High Left	WF-05182018-004338	10/24/2018	FT-FY19-102018-004338-A	< 1	FT-FY19-102018-004338-B	< 1
WS-004339	5/18/2018	5/18/2019	1	Cooler	In hallway adjacent to girls' restroom 103 Low Right	WF-05182018-004339	10/24/2018	FT-FY19-102018-004339-A	< 1	FT-FY19-102018-004339-B	< 1
WS-004342	5/18/2018	5/18/2019	1	Health Suite	In health suite	WF-05182018-004342	10/24/2018	FT-FY19-102018-004342-A	< 1	FT-FY19-102018-004342-B	< 1
WS-004343	5/18/2018	5/18/2019	1	Cooler	In hallway adjacent to room 119 High Left	WF-05182018-004343	10/24/2018	FT-FY19-102018-004343-A	< 1	FT-FY19-102018-004343-B	< 1
WS-004344	5/18/2018	5/18/2019	1	Cooler	In hallway adjacent to room 119 Low Right	WF-05182018-004344	10/24/2018	FT-FY19-102018-004344-A	< 1	FT-FY19-102018-004344-B	< 1
WS-004346	5/18/2018	5/18/2019	1	Cooler	In hallway adjacent to room 124	WF-05182018-004346	10/24/2018	FT-FY19-102018-004346-A	< 1	FT-FY19-102018-004346-B	< 1
WS-004347	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 130	WF-10092018-004347	10/24/2018	FT-FY19-102018-004347-A	< 1	FT-FY19-102018-004347-B	< 1
WS-004350	5/18/2018	5/18/2019	1	Cooler	In hallway adjacent to room 134	WF-05182018-004350	10/24/2018	FT-FY19-102018-004350-A	< 1	FT-FY19-102018-004350-B	< 1
WS-004351	5/18/2018	5/18/2019	2	Cooler	In hallway adjacent to room 224B	WF-05182018-004351	10/24/2018	FT-FY19-102018-004351-A	< 1	FT-FY19-102018-004351-B	< 1
WS-004352	5/18/2018	5/18/2019	2	Cooler	In hallway adjacent to room 203A High Left	WF-05182018-004352	10/24/2018	FT-FY19-102018-004352-A	< 1	FT-FY19-102018-004352-B	< 1
WS-004353	5/18/2018	5/18/2019	2	Cooler	In hallway adjacent to room 203A Low Right	WF-05182018-004353	10/24/2018	FT-FY19-102018-004353-A	< 1	FT-FY19-102018-004353-B	< 1
WS-004356	5/18/2018	5/18/2019	2	Break Room	In break room 208	WF-05182018-004356	10/24/2018	FT-FY19-102018-004356-A	< 1	FT-FY19-102018-004356-B	< 1
WS-004357	5/18/2018	5/18/2019	2	Cooler	In hallway across from room 210 High Left	WF-05182018-004357	10/24/2018	FT-FY19-102018-004357-A	< 1	FT-FY19-102018-004357-B	< 1
WS-004358	5/18/2018	5/18/2019	2	Cooler	In hallway across from room 210 Low Right	WF-05182018-004358	10/24/2018	FT-FY19-102018-004358-A	< 1	FT-FY19-102018-004358-B	< 1
WS-004364	5/18/2018	5/18/2019	2	Cooler	In hallway adjacent to room 216	WF-05182018-004364	10/24/2018	FT-FY19-102018-004364-A	< 1	FT-FY19-102018-004364-B	< 1
WS-004366	5/18/2018	5/18/2019	3	Cooler	In hallway adjacent to room 301 High Left	WF-05182018-004366	10/24/2018	FT-FY19-102018-004366-A	< 1	FT-FY19-102018-004366-B	< 1
WS-004367	5/18/2018	5/18/2019	3	Cooler	In hallway adjacent to room 301 Low Right	WF-05182018-004367	10/24/2018	FT-FY19-102018-004367-A	< 1	FT-FY19-102018-004367-B	< 1
WS-004374	5/18/2018	5/18/2019	3	Cooler	In hallway adjacent to room 312 High Left	WF-05182018-004374	10/24/2018	FT-FY19-102018-004374-A	< 1	FT-FY19-102018-004374-B	< 1

WS- 004375	5/18/2018	5/18/2019	3	Cooler	In hallway adjacent to room 312	Low	Right	WF-05182018-004375	10/24/2018	FT-FY19-102018-004375-A	< 1	FT-FY19-102018-004375-B	< 1
WS- 004378	5/18/2018	5/18/2019	3	Cooler	In hallway adjacent to room 317			WF-05182018-004378	10/24/2018	FT-FY19-102018-004378-A	< 1	FT-FY19-102018-004378-B	< 1
WS- 004383	5/18/2018	5/18/2019	3	Cooler	In hallway adjacent to room 327			WF-05182018-004383	10/24/2018	FT-FY19-102018-004383-A	< 1	FT-FY19-102018-004383-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004324	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	Low			10/24/2018	FT-FY19-102018-004324-A	< 1	FT-FY19-102018-004324-B	< 1	