



Murch Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013750	5/19/2021	5/19/2022	Basement	Bottle Filler	In cafeteria	WF-05192021-013750	12/7/2021	FT-FY22-11222021-013750-A	<1	FT-FY22-11222021-013750-B	<1
WS-013752	5/19/2021	5/19/2022	Basement	Cooler	In cafeteria High Right	WF-05192021-013752	12/7/2021	FT-FY22-11222021-013752-A	<1	FT-FY22-11222021-013752-B	<1
WS-013760	5/19/2021	5/19/2022	1	Health Suite	In health suite B110	WF-05192021-013760	12/7/2021	FT-FY22-11222021-013760-A	<1	FT-FY22-11222021-013760-B	<1
WS-013761	5/19/2021	5/19/2022	1	Combo Fountain	In health suite B110	WF-05192021-013761	12/7/2021	FT-FY22-11222021-013761-A	<1	FT-FY22-11222021-013761-B	<1
WS-013762	5/19/2021	5/19/2022	1	Break Room	In staff room B111	WF-05192021-013762	12/7/2021	FT-FY22-11222021-013762-A	<1	FT-FY22-11222021-013762-B	<1
WS-013763	5/19/2021	5/19/2022	1	Combo Fountain	In staff room B111	WF-05192021-013763	12/7/2021	FT-FY22-11222021-013763-A	<1	FT-FY22-11222021-013763-B	<1
WS-013764	5/19/2021	5/19/2022	1	Break Room	In staff room B112	WF-05192021-013764	12/7/2021	FT-FY22-11222021-013764-A	<1	FT-FY22-11222021-013764-B	<1
WS-013765	5/19/2021	5/19/2022	1	Combo Fountain	In staff room B112	WF-05192021-013765	12/7/2021	FT-FY22-11222021-013765-A	<1	FT-FY22-11222021-013765-B	<1
WS-013767	5/19/2021	5/19/2022	1	Combo Fountain	In office B109	WF-05192021-013767	12/7/2021	FT-FY22-11222021-013767-A	<1	FT-FY22-11222021-013767-B	<1
WS-013769	5/19/2021	5/19/2022	1	Combo Fountain	In office B108	WF-05192021-013769	12/7/2021	FT-FY22-11222021-013769-A	<1	FT-FY22-11222021-013769-B	<1
WS-013771	5/19/2021	5/19/2022	1	Combo Fountain	In office B107	WF-05192021-013771	12/7/2021	FT-FY22-11222021-013771-A	<1	FT-FY22-11222021-013771-B	<1
WS-013772	5/19/2021	5/19/2022	1	Bottle Filler	In hallway across from offices B100E	WF-05192021-013772	12/7/2021	FT-FY22-11222021-013772-A	<1	FT-FY22-11222021-013772-B	<1
WS-013774	5/19/2021	5/19/2022	1	Cooler	In hallway across from offices B100E High Right	WF-05192021-013774	12/7/2021	FT-FY22-11222021-013774-A	<1	FT-FY22-11222021-013774-B	<1
WS-013776	5/19/2021	5/19/2022	1	Combo Fountain	In classroom C105	WF-05192021-013776	12/7/2021	FT-FY22-11222021-013776-A	<1	FT-FY22-11222021-013776-B	<1
WS-013778	5/19/2021	5/19/2022	1	Combo Fountain	In classroom C106	WF-05192021-013778	12/7/2021	FT-FY22-11222021-013778-A	<1	FT-FY22-11222021-013778-B	<1
WS-013779	5/19/2021	5/19/2022	1	Bottle Filler	In hallway adjacent to classroom C105	WF-05192021-013779	12/7/2021	FT-FY22-11222021-013779-A	<1	FT-FY22-11222021-013779-B	<1
WS-013781	5/19/2021	5/19/2022	1	Cooler	In hallway adjacent to classroom C105 High Right	WF-05192021-013781	12/7/2021	FT-FY22-11222021-013781-A	<1	FT-FY22-11222021-013781-B	<1
WS-013783	5/19/2021	5/19/2022	1	Combo Fountain	In classroom C104	WF-05192021-013783	12/7/2021	FT-FY22-11222021-013783-A	<1	FT-FY22-11222021-013783-B	<1
WS-013785	5/19/2021	5/19/2022	1	Combo Fountain	In classroom C107	WF-05192021-013785	12/7/2021	FT-FY22-11222021-013785-A	1.1	FT-FY22-11222021-013785-B	<1
WS-013787	5/19/2021	5/19/2022	1	Combo Fountain	In classroom C101	WF-05192021-013787	12/7/2021	FT-FY22-11222021-013787-A	<1	FT-FY22-11222021-013787-B	<1
WS-013788	5/19/2021	5/19/2022	1	Bottle Filler	In library/media center B119	WF-05192021-013788	12/7/2021	FT-FY22-11222021-013788-A	<1	FT-FY22-11222021-013788-B	<1
WS-013790	5/19/2021	5/19/2022	1	Cooler	In library/media center B119 High Right	WF-05192021-013790	12/7/2021	FT-FY22-11222021-013790-A	<1	FT-FY22-11222021-013790-B	<1
WS-013792	5/19/2021	5/19/2022	1	Combo Fountain	In small group instruction room B120	WF-05192021-013792	12/7/2021	FT-FY22-11222021-013792-A	<1	FT-FY22-11222021-013792-B	<1
WS-013794	5/19/2021	5/19/2022	1	Combo Fountain	In office B126	WF-05192021-013794	12/7/2021	FT-FY22-11222021-013794-A	<1	FT-FY22-11222021-013794-B	<1
WS-013795	5/19/2021	5/19/2022	1	Bottle Filler	In hallway adjacent to gym/janitor room A112	WF-05192021-013795	12/7/2021	FT-FY22-11222021-013795-A	<1	FT-FY22-11222021-013795-B	<1
WS-013797	5/19/2021	5/19/2022	1	Cooler	In hallway adjacent to gym/janitor room A112 High Right	WF-05192021-013797	12/7/2021	FT-FY22-11222021-013797-A	<1	FT-FY22-11222021-013797-B	<1
WS-013798	7/21/2021	7/21/2022	1	Bottle Filler	In hallway across from classroom A104	WF-07212021-013798	12/7/2021	FT-FY22-11222021-013798-A	<1	FT-FY22-11222021-013798-B	<1
WS-013801	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A104	WF-10042021-013801	12/7/2021	FT-FY22-11222021-013801-A	<1	FT-FY22-11222021-013801-B	<1
WS-013802	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A104	WF-05192021-013802	12/7/2021	FT-FY22-11222021-013802-A	<1	FT-FY22-11222021-013802-B	<1
WS-013803	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A108	WF-10042021-013803	12/7/2021	FT-FY22-11222021-013803-A	<1	FT-FY22-11222021-013803-B	<1
WS-013804	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A108	WF-05192021-013804	12/7/2021	FT-FY22-11222021-013804-A	<1	FT-FY22-11222021-013804-B	<1
WS-013805	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A103	WF-10042021-013805	12/7/2021	FT-FY22-11222021-013805-A	<1	FT-FY22-11222021-013805-B	<1
WS-013806	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A103	WF-05192021-013806	12/7/2021	FT-FY22-11222021-013806-A	<1	FT-FY22-11222021-013806-B	<1
WS-013807	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A102	WF-10042021-013807	12/7/2021	FT-FY22-11222021-013807-A	<1	FT-FY22-11222021-013807-B	<1
WS-013808	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A102	WF-05192021-013808	12/7/2021	FT-FY22-11222021-013808-A	<1	FT-FY22-11222021-013808-B	<1
WS-013809	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A107	WF-10042021-013809	12/7/2021	FT-FY22-11222021-013809-A	<1	FT-FY22-11222021-013809-B	<1
WS-013810	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A107	WF-05192021-013810	12/7/2021	FT-FY22-11222021-013810-A	<1	FT-FY22-11222021-013810-B	<1
WS-013811	10/4/2021	10/4/2022	1	Combo Faucet	In early childhood commons A113 adjacent to room A109	WF-10042021-013811	12/7/2021	FT-FY22-11222021-013811-A	<1	FT-FY22-11222021-013811-B	<1

WS-013812	5/19/2021	5/19/2022	1	Combo Fountain	In early childhood commons A113 adjacent to room A109	WF-05192021-013812	12/7/2021	FT-FY22-11222021-013812-A	<1	FT-FY22-11222021-013812-B	<1
WS-013813	10/4/2021	10/4/2022	1	Combo Faucet	In early childhood commons A113 adjacent to room A116	WF-10042021-013813	12/7/2021	FT-FY22-11222021-013813-A	<1	FT-FY22-11222021-013813-B	<1
WS-013814	5/19/2021	5/19/2022	1	Combo Fountain	In early childhood commons A113 adjacent to room A116	WF-05192021-013814	12/7/2021	FT-FY22-11222021-013814-A	<1	FT-FY22-11222021-013814-B	<1
WS-013815	5/19/2021	5/19/2022	1	Bottle Filler	In hallway across from classroom A121	WF-05192021-013815	12/7/2021	FT-FY22-11222021-013815-A	<1	FT-FY22-11222021-013815-B	<1
WS-013818	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A121	WF-10042021-013818	12/7/2021	FT-FY22-11222021-013818-A	1.6	FT-FY22-11222021-013818-B	<1
WS-013819	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A121	WF-05192021-013819	12/7/2021	FT-FY22-11222021-013819-A	<1	FT-FY22-11222021-013819-B	<1
WS-013820	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A120	WF-10042021-013820	12/7/2021	FT-FY22-11222021-013820-A	<1	FT-FY22-11222021-013820-B	<1
WS-013821	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A120	WF-05192021-013821	12/7/2021	FT-FY22-11222021-013821-A	<1	FT-FY22-11222021-013821-B	<1
WS-013822	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A115	WF-10042021-013822	12/7/2021	FT-FY22-11222021-013822-A	<1	FT-FY22-11222021-013822-B	<1
WS-013823	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A115	WF-05192021-013823	12/7/2021	FT-FY22-11222021-013823-A	<1	FT-FY22-11222021-013823-B	<1
WS-013824	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A114	WF-10042021-013824	12/7/2021	FT-FY22-11222021-013824-A	<1	FT-FY22-11222021-013824-B	<1
WS-013825	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A114	WF-05192021-013825	12/7/2021	FT-FY22-11222021-013825-A	<1	FT-FY22-11222021-013825-B	<1
WS-013826	10/4/2021	10/4/2022	1	Combo Faucet	In classroom A119	WF-10042021-013826	12/7/2021	FT-FY22-11222021-013826-A	<1	FT-FY22-11222021-013826-B	<1
WS-013827	5/19/2021	5/19/2022	1	Combo Fountain	In classroom A119	WF-05192021-013827	12/7/2021	FT-FY22-11222021-013827-A	1.1	FT-FY22-11222021-013827-B	<1
WS-013829	5/19/2021	5/19/2022	2	Combo Fountain	In classroom B205	WF-05192021-013829	12/7/2021	FT-FY22-11222021-013829-A	<1	FT-FY22-11222021-013829-B	<1
WS-013831	5/19/2021	5/19/2022	2	Combo Fountain	In classroom B204	WF-05192021-013831	12/7/2021	FT-FY22-11222021-013831-A	1.6	FT-FY22-11222021-013831-B	<1
WS-013836	5/19/2021	5/19/2022	2	Combo Fountain	In classroom B206	WF-05192021-013836	12/7/2021	FT-FY22-11222021-013836-A	2.4	FT-FY22-11222021-013836-B	<1
WS-013838	5/19/2021	5/19/2022	2	Combo Fountain	In classroom B203	WF-05192021-013838	12/7/2021	FT-FY22-11222021-013838-A	<1	FT-FY22-11222021-013838-B	<1
WS-013840	5/19/2021	5/19/2022	2	Combo Fountain	In classroom C205	WF-05192021-013840	12/7/2021	FT-FY22-11222021-013840-A	1.2	FT-FY22-11222021-013840-B	<1
WS-013842	5/19/2021	5/19/2022	2	Combo Fountain	In classroom C206	WF-05192021-013842	12/7/2021	FT-FY22-11222021-013842-A	3.8	FT-FY22-11222021-013842-B	<1
WS-013844	5/19/2021	5/19/2022	2	Combo Fountain	In classroom C204	WF-05192021-013844	12/7/2021	FT-FY22-11222021-013844-A	<1	FT-FY22-11222021-013844-B	<1
WS-013846	5/19/2021	5/19/2022	2	Combo Fountain	In classroom C207	WF-05192021-013846	12/7/2021	FT-FY22-11222021-013846-A	1.6	FT-FY22-11222021-013846-B	<1
WS-013847	5/19/2021	5/19/2022	2	Bottle Filler	In hallway adjacent to classroom C205	WF-05192021-013847	12/7/2021	FT-FY22-11222021-013847-A	<1	FT-FY22-11222021-013847-B	<1
WS-013849	5/19/2021	5/19/2022	2	Cooler	In hallway adjacent to classroom C205 High Right	WF-05192021-013849	12/7/2021	FT-FY22-11222021-013849-A	<1	FT-FY22-11222021-013849-B	<1
WS-013851	5/19/2021	5/19/2022	2	Combo Fountain	In classroom C201	WF-05192021-013851	12/7/2021	FT-FY22-11222021-013851-A	1.4	FT-FY22-11222021-013851-B	<1
WS-013853	5/19/2021	5/19/2022	2	Combo Fountain	In classroom B201	WF-05192021-013853	12/7/2021	FT-FY22-11222021-013853-A	2.9	FT-FY22-11222021-013853-B	<1
WS-013855	5/19/2021	5/19/2022	2	Combo Fountain	In music classroom A207	WF-05192021-013855	12/7/2021	FT-FY22-11222021-013855-A	<1	FT-FY22-11222021-013855-B	<1
WS-013860	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A209	WF-05192021-013860	12/7/2021	FT-FY22-11222021-013860-A	<1	FT-FY22-11222021-013860-B	<1
WS-013862	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A203	WF-05192021-013862	12/7/2021	FT-FY22-11222021-013862-A	<1	FT-FY22-11222021-013862-B	<1
WS-013864	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A202	WF-05192021-013864	12/7/2021	FT-FY22-11222021-013864-A	1.0	FT-FY22-11222021-013864-B	<1
WS-013866	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A208	WF-05192021-013866	12/7/2021	FT-FY22-11222021-013866-A	<1	FT-FY22-11222021-013866-B	<1
WS-013868	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A210	WF-05192021-013868	12/7/2021	FT-FY22-11222021-013868-A	<1	FT-FY22-11222021-013868-B	<1
WS-013869	5/19/2021	5/19/2022	2	Bottle Filler	In hallway adjacent to small group instruction room A213	WF-05192021-013869	12/7/2021	FT-FY22-11222021-013869-A	<1	FT-FY22-11222021-013869-B	<1
WS-013871	5/19/2021	5/19/2022	2	Cooler	In hallway adjacent to small group instruction room A213 High Right	WF-05192021-013871	12/7/2021	FT-FY22-11222021-013871-A	<1	FT-FY22-11222021-013871-B	<1
WS-013873	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A217	WF-05192021-013873	12/7/2021	FT-FY22-11222021-013873-A	<1	FT-FY22-11222021-013873-B	<1
WS-013875	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A212	WF-05192021-013875	12/7/2021	FT-FY22-11222021-013875-A	<1	FT-FY22-11222021-013875-B	<1
WS-013877	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A211	WF-05192021-013877	12/7/2021	FT-FY22-11222021-013877-A	<1	FT-FY22-11222021-013877-B	<1
WS-013879	5/19/2021	5/19/2022	2	Combo Fountain	In classroom A216	WF-05192021-013879	12/7/2021	FT-FY22-11222021-013879-A	<1	FT-FY22-11222021-013879-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013754	1/25/2021	1/25/2022	Basement	Food Prep Sink	In kitchen	WF-01252021-013754	12/7/2021	FT-FY22-11222021-013754-A	<1	FT-FY22-11222021-013754-B	<1