



Murch Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013750	4/30/2024	4/30/2025	Basement	Bottle Filler	In cafeteria	WF-04302024-013750	11/14/2024	FT-FY25-10082024-013750-A	<2	FT-FY25-10082024-013750-B	<2
WS-013751	4/30/2024	4/30/2025	Basement	Cooler	In cafeteria Low Left	WF-04302024-013751	11/14/2024	FT-FY25-10082024-013751-A	<2	FT-FY25-10082024-013751-B	<2
WS-013752	4/30/2024	4/30/2025	Basement	Cooler	In cafeteria High Right	WF-04302024-013752	11/14/2024	FT-FY25-10082024-013752-A	<2	FT-FY25-10082024-013752-B	<2
WS-013760	4/30/2024	4/30/2025	1	Health Suite	In health suite B110	WF-04302024-013760	11/14/2024	FT-FY25-10082024-013760-A	<2	FT-FY25-10082024-013760-B	<2
WS-013761	4/30/2024	4/30/2025	1	Combo Fountain	In health suite B110	WF-04302024-013761	11/14/2024	FT-FY25-10082024-013761-A	<2	FT-FY25-10082024-013761-B	<2
WS-013762	4/30/2024	4/30/2025	1	Break Room	In staff room B111	WF-04302024-013762	11/14/2024	FT-FY25-10082024-013762-A	<2	FT-FY25-10082024-013762-B	<2
WS-013763	4/30/2024	4/30/2025	1	Combo Fountain	In staff room B111	WF-04302024-013763	11/14/2024	FT-FY25-10082024-013763-A	<2	FT-FY25-10082024-013763-B	<2
WS-013764	4/30/2024	4/30/2025	1	Break Room	In staff room B112	WF-04302024-013764	11/14/2024	FT-FY25-10082024-013764-A	<2	FT-FY25-10082024-013764-B	<2
WS-013767	4/30/2024	4/30/2025	1	Combo Fountain	In office B109	WF-04302024-013767	11/14/2024	FT-FY25-10082024-013767-A	<2	FT-FY25-10082024-013767-B	<2
WS-013769	4/30/2024	4/30/2025	1	Combo Fountain	In office B108	WF-04302024-013769	11/14/2024	FT-FY25-10082024-013769-A	<2	FT-FY25-10082024-013769-B	<2
WS-013771	4/30/2024	4/30/2025	1	Combo Fountain	In office B107	WF-04302024-013771	11/14/2024	FT-FY25-10082024-013771-A	<2	FT-FY25-10082024-013771-B	<2
WS-013772	4/30/2024	4/30/2025	1	Bottle Filler	In hallway across from offices B100E	WF-04302024-013772	11/14/2024	FT-FY25-10082024-013772-A	<2	FT-FY25-10082024-013772-B	<2
WS-013773	4/30/2024	4/30/2025	1	Cooler	In hallway across from offices B100E Low Left	WF-04302024-013773	11/14/2024	FT-FY25-10082024-013773-A	<2	FT-FY25-10082024-013773-B	<2
WS-013774	4/30/2024	4/30/2025	1	Cooler	In hallway across from offices B100E High Right	WF-04302024-013774	11/14/2024	FT-FY25-10082024-013774-A	<2	FT-FY25-10082024-013774-B	<2
WS-013776	4/30/2024	4/30/2025	1	Combo Fountain	In classroom C105	WF-04302024-013776	11/14/2024	FT-FY25-10082024-013776-A	<2	FT-FY25-10082024-013776-B	<2
WS-013778	4/30/2024	4/30/2025	1	Combo Fountain	In classroom C106	WF-04302024-013778	11/14/2024	FT-FY25-10082024-013778-A	<2	FT-FY25-10082024-013778-B	<2
WS-013779	4/30/2024	4/30/2025	1	Bottle Filler	In hallway adjacent to classroom C105	WF-04302024-013779	11/14/2024	FT-FY25-10082024-013779-A	<2	FT-FY25-10082024-013779-B	<2
WS-013780	4/30/2024	4/30/2025	1	Cooler	In hallway adjacent to classroom C105 Low Left	WF-04302024-013780	11/14/2024	FT-FY25-10082024-013780-A	<2	FT-FY25-10082024-013780-B	<2
WS-013781	4/30/2024	4/30/2025	1	Cooler	In hallway adjacent to classroom C105 High Right	WF-04302024-013781	11/14/2024	FT-FY25-10082024-013781-A	<2	FT-FY25-10082024-013781-B	<2
WS-013783	4/30/2024	4/30/2025	1	Combo Fountain	In classroom C104	WF-04302024-013783	11/14/2024	FT-FY25-10082024-013783-A	<2	FT-FY25-10082024-013783-B	<2
WS-013785	4/30/2024	4/30/2025	1	Combo Fountain	In classroom C107	WF-04302024-013785	11/14/2024	FT-FY25-10082024-013785-A	<2	FT-FY25-10082024-013785-B	<2
WS-013787	4/30/2024	4/30/2025	1	Combo Fountain	In classroom C101	WF-04302024-013787	11/14/2024	FT-FY25-10082024-013787-A	<2	FT-FY25-10082024-013787-B	<2
WS-013788	4/30/2024	4/30/2025	1	Bottle Filler	In library/media center B119	WF-04302024-013788	11/14/2024	FT-FY25-10082024-013788-A	<2	FT-FY25-10082024-013788-B	<2
WS-013789	4/30/2024	4/30/2025	1	Cooler	In library/media center B119 Low Left	WF-04302024-013789	11/14/2024	FT-FY25-10082024-013789-A	<2	FT-FY25-10082024-013789-B	<2
WS-013790	4/30/2024	4/30/2025	1	Cooler	In library/media center B119 High Right	WF-04302024-013790	11/14/2024	FT-FY25-10082024-013790-A	<2	FT-FY25-10082024-013790-B	<2
WS-013792	4/30/2024	4/30/2025	1	Combo Fountain	In small group instruction room B120	WF-04302024-013792	11/14/2024	FT-FY25-10082024-013792-A	<2	FT-FY25-10082024-013792-B	<2
WS-013794	4/30/2024	4/30/2025	1	Combo Fountain	In office B126	WF-04302024-013794	11/14/2024	FT-FY25-10082024-013794-A	<2	FT-FY25-10082024-013794-B	<2
WS-013795	4/30/2024	4/30/2025	1	Bottle Filler	In hallway adjacent to gym/janitor room A112	WF-04302024-013795	11/14/2024	FT-FY25-10082024-013795-A	<2	FT-FY25-10082024-013795-B	<2
WS-013796	4/30/2024	4/30/2025	1	Cooler	In hallway adjacent to gym/janitor room A112 Low Left	WF-04302024-013796	11/14/2024	FT-FY25-10082024-013796-A	<2	FT-FY25-10082024-013796-B	<2
WS-013797	4/30/2024	4/30/2025	1	Cooler	In hallway adjacent to gym/janitor room A112 High Right	WF-04302024-013797	11/14/2024	FT-FY25-10082024-013797-A	<2	FT-FY25-10082024-013797-B	<2
WS-013798	4/30/2024	4/30/2025	1	Bottle Filler	In hallway across from classroom A104	WF-04302024-013798	11/14/2024	FT-FY25-10082024-013798-A	<2	FT-FY25-10082024-013798-B	<2
WS-013799	4/30/2024	4/30/2025	1	Cooler	In hallway across from classroom A104 Low Left	WF-04302024-013799	11/14/2024	FT-FY25-10082024-013799-A	<2	FT-FY25-10082024-013799-B	<2
WS-013800	4/30/2024	4/30/2025	1	Cooler	In hallway across from classroom A104 High Right	WF-04302024-013800	11/14/2024	FT-FY25-10082024-013800-A	<2	FT-FY25-10082024-013800-B	<2

WS-013801	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A104		WF-09172024-013801	11/14/2024	FT-FY25-10082024-013801-A	<2	FT-FY25-10082024-013801-B	<2
WS-013802	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A104		WF-04302024-013802	11/14/2024	FT-FY25-10082024-013802-A	<2	FT-FY25-10082024-013802-B	<2
WS-013803	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A108		WF-09172024-013803	11/14/2024	FT-FY25-10082024-013803-A	<2	FT-FY25-10082024-013803-B	<2
WS-013804	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A108		WF-04302024-013804	11/14/2024	FT-FY25-10082024-013804-A	<2	FT-FY25-10082024-013804-B	<2
WS-013805	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A103		WF-09172024-013805	11/14/2024	FT-FY25-10082024-013805-A	<2	FT-FY25-10082024-013805-B	<2
WS-013806	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A103		WF-04302024-013806	11/14/2024	FT-FY25-10082024-013806-A	<2	FT-FY25-10082024-013806-B	<2
WS-013807	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A102		WF-09172024-013807	11/14/2024	FT-FY25-10082024-013807-A	<2	FT-FY25-10082024-013807-B	<2
WS-013808	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A102		WF-04302024-013808	11/14/2024	FT-FY25-10082024-013808-A	<2	FT-FY25-10082024-013808-B	<2
WS-013809	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A107		WF-09172024-013809	11/14/2024	FT-FY25-10082024-013809-A	<2	FT-FY25-10082024-013809-B	<2
WS-013810	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A107		WF-04302024-013810	11/14/2024	FT-FY25-10082024-013810-A	<2	FT-FY25-10082024-013810-B	<2
WS-013811	9/17/2024	9/17/2025	1	Combo Faucet	In early childhood commons A113 adjacent to room A109		WF-09172024-013811	11/14/2024	FT-FY25-10082024-013811-A	<2	FT-FY25-10082024-013811-B	<2
WS-013812	4/30/2024	4/30/2025	1	Combo Fountain	In early childhood commons A113 adjacent to room A109		WF-04302024-013812	11/14/2024	FT-FY25-10082024-013812-A	<2	FT-FY25-10082024-013812-B	<2
WS-013813	9/17/2024	9/17/2025	1	Combo Faucet	In early childhood commons A113 adjacent to room A116		WF-09172024-013813	11/14/2024	FT-FY25-10082024-013813-A	<2	FT-FY25-10082024-013813-B	<2
WS-013814	4/30/2024	4/30/2025	1	Combo Fountain	In early childhood commons A113 adjacent to room A116		WF-04302024-013814	11/14/2024	FT-FY25-10082024-013814-A	<2	FT-FY25-10082024-013814-B	<2
WS-013815	4/30/2024	4/30/2025	1	Bottle Filler	In hallway across from classroom A121		WF-04302024-013815	11/14/2024	FT-FY25-10082024-013815-A	<2	FT-FY25-10082024-013815-B	<2
WS-013816	4/30/2024	4/30/2025	1	Cooler	In hallway across from classroom A121	Low Left	WF-04302024-013816	11/14/2024	FT-FY25-10082024-013816-A	<2	FT-FY25-10082024-013816-B	<2
WS-013817	4/30/2024	4/30/2025	1	Cooler	In hallway across from classroom A121	High Right	WF-04302024-013817	11/14/2024	FT-FY25-10082024-013817-A	<2	FT-FY25-10082024-013817-B	<2
WS-013818	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A121		WF-09172024-013818	11/14/2024	FT-FY25-10082024-013818-A	<2	FT-FY25-10082024-013818-B	<2
WS-013819	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A121		WF-04302024-013819	11/14/2024	FT-FY25-10082024-013819-A	<2	FT-FY25-10082024-013819-B	<2
WS-013820	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A120		WF-09172024-013820	11/14/2024	FT-FY25-10082024-013820-A	<2	FT-FY25-10082024-013820-B	<2
WS-013821	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A120		WF-04302024-013821	11/14/2024	FT-FY25-10082024-013821-A	<2	FT-FY25-10082024-013821-B	<2
WS-013822	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A115		WF-09172024-013822	11/14/2024	FT-FY25-10082024-013822-A	<2	FT-FY25-10082024-013822-B	<2
WS-013823	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A115		WF-04302024-013823	11/14/2024	FT-FY25-10082024-013823-A	<2	FT-FY25-10082024-013823-B	<2
WS-013824	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A114		WF-09172024-013824	11/14/2024	FT-FY25-10082024-013824-A	<2	FT-FY25-10082024-013824-B	<2
WS-013825	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A114		WF-04302024-013825	11/14/2024	FT-FY25-10082024-013825-A	<2	FT-FY25-10082024-013825-B	<2
WS-013826	9/17/2024	9/17/2025	1	Combo Faucet	In classroom A119		WF-09172024-013826	11/14/2024	FT-FY25-10082024-013826-A	<2	FT-FY25-10082024-013826-B	<2
WS-013827	4/30/2024	4/30/2025	1	Combo Fountain	In classroom A119		WF-04302024-013827	11/14/2024	FT-FY25-10082024-013827-A	<2	FT-FY25-10082024-013827-B	<2
WS-013829	4/30/2024	4/30/2025	2	Combo Fountain	In classroom B205		WF-04302024-013829	11/14/2024	FT-FY25-10082024-013829-A	<2	FT-FY25-10082024-013829-B	<2
WS-013831	4/30/2024	4/30/2025	2	Combo Fountain	In classroom B204		WF-04302024-013831	11/14/2024	FT-FY25-10082024-013831-A	<2	FT-FY25-10082024-013831-B	<2
WS-013832	4/30/2024	4/30/2025	2	Bottle Filler	In hallway adjacent to classroom B204		WF-04302024-013832	11/14/2024	FT-FY25-10082024-013832-A	<2	FT-FY25-10082024-013832-B	<2
WS-013833	4/30/2024	4/30/2025	2	Cooler	In hallway adjacent to classroom B204	Low Left	WF-04302024-013833	11/14/2024	FT-FY25-10082024-013833-A	<2	FT-FY25-10082024-013833-B	<2
WS-013834	4/30/2024	4/30/2025	2	Cooler	In hallway adjacent to classroom B204	High Right	WF-04302024-013834	11/14/2024	FT-FY25-10082024-013834-A	<2	FT-FY25-10082024-013834-B	<2
WS-013836	4/30/2024	4/30/2025	2	Combo Fountain	In classroom B206		WF-04302024-013836	11/14/2024	FT-FY25-10082024-013836-A	<2	FT-FY25-10082024-013836-B	<2
WS-013838	4/30/2024	4/30/2025	2	Combo Fountain	In classroom B203		WF-04302024-013838	11/14/2024	FT-FY25-10082024-013838-A	<2	FT-FY25-10082024-013838-B	<2
WS-013840	4/30/2024	4/30/2025	2	Combo Fountain	In classroom C205		WF-04302024-013840	11/14/2024	FT-FY25-10082024-013840-A	<2	FT-FY25-10082024-013840-B	<2
WS-013842	4/30/2024	4/30/2025	2	Combo Fountain	In classroom C206		WF-04302024-013842	11/14/2024	FT-FY25-10082024-013842-A	<2	FT-FY25-10082024-013842-B	<2
WS-013844	4/30/2024	4/30/2025	2	Combo Fountain	In classroom C204		WF-04302024-013844	11/14/2024	FT-FY25-10082024-013844-A	<2	FT-FY25-10082024-013844-B	<2
WS-013846	4/30/2024	4/30/2025	2	Combo Fountain	In classroom C207		WF-04302024-013846	11/14/2024	FT-FY25-10082024-013846-A	<2	FT-FY25-10082024-013846-B	<2
WS-013847	4/30/2024	4/30/2025	2	Bottle Filler	In hallway adjacent to classroom C205		WF-04302024-013847	11/14/2024	FT-FY25-10082024-013847-A	<2	FT-FY25-10082024-013847-B	<2

WS-013851	4/30/2024	4/30/2025	2	Combo Fountain	In classroom C201	WF-04302024-013851	11/14/2024	FT-FY25-10082024-013851-A	<2	FT-FY25-10082024-013851-B	<2
WS-013853	4/30/2024	4/30/2025	2	Combo Fountain	In classroom B201	WF-04302024-013853	11/14/2024	FT-FY25-10082024-013853-A	<2	FT-FY25-10082024-013853-B	<2
WS-013856	4/30/2024	4/30/2025	2	Bottle Filler	In hallway across from small group instruction room A205	WF-04302024-013856	11/14/2024	FT-FY25-10082024-013856-A	<2	FT-FY25-10082024-013856-B	<2
WS-013857	4/30/2024	4/30/2025	2	Cooler	In hallway across from small group instruction room Low Left	WF-04302024-013857	11/14/2024	FT-FY25-10082024-013857-A	<2	FT-FY25-10082024-013857-B	<2
WS-013858	4/30/2024	4/30/2025	2	Cooler	In hallway across from small group instruction room High Right	WF-04302024-013858	11/14/2024	FT-FY25-10082024-013858-A	<2	FT-FY25-10082024-013858-B	<2
WS-013860	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A209	WF-04302024-013860	11/14/2024	FT-FY25-10082024-013860-A	<2	FT-FY25-10082024-013860-B	<2
WS-013862	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A203	WF-04302024-013862	11/14/2024	FT-FY25-10082024-013862-A	<2	FT-FY25-10082024-013862-B	<2
WS-013864	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A202	WF-04302024-013864	11/14/2024	FT-FY25-10082024-013864-A	<2	FT-FY25-10082024-013864-B	<2
WS-013866	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A208	WF-04302024-013866	11/14/2024	FT-FY25-10082024-013866-A	<2	FT-FY25-10082024-013866-B	<2
WS-013868	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A210	WF-04302024-013868	11/14/2024	FT-FY25-10082024-013868-A	<2	FT-FY25-10082024-013868-B	<2
WS-013869	4/30/2024	4/30/2025	2	Bottle Filler	In hallway adjacent to small group instruction room A213	WF-04302024-013869	11/14/2024	FT-FY25-10082024-013869-A	<2	FT-FY25-10082024-013869-B	<2
WS-013870	4/30/2024	4/30/2025	2	Cooler	In hallway adjacent to small group instruction room Low Left	WF-04302024-013870	11/14/2024	FT-FY25-10082024-013870-A	<2	FT-FY25-10082024-013870-B	<2
WS-013871	4/30/2024	4/30/2025	2	Cooler	In hallway adjacent to small group instruction room High Right	WF-04302024-013871	11/14/2024	FT-FY25-10082024-013871-A	<2	FT-FY25-10082024-013871-B	<2
WS-013873	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A217	WF-04302024-013873	11/14/2024	FT-FY25-10082024-013873-A	<2	FT-FY25-10082024-013873-B	<2
WS-013875	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A212	WF-04302024-013875	11/14/2024	FT-FY25-10082024-013875-A	<2	FT-FY25-10082024-013875-B	<2
WS-013877	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A211	WF-04302024-013877	11/14/2024	FT-FY25-10082024-013877-A	<2	FT-FY25-10082024-013877-B	<2
WS-013879	4/30/2024	4/30/2025	2	Combo Fountain	In classroom A216	WF-04302024-013879	11/14/2024	FT-FY25-10082024-013879-A	<2	FT-FY25-10082024-013879-B	<2
WS-013881	4/30/2024	4/30/2025	2	Combo Fountain	In art classroom A220 first clockwise from entry	WF-04302024-013881	11/14/2024	FT-FY25-10082024-013881-A	<2	FT-FY25-10082024-013881-B	<2
WS-013883	4/30/2024	4/30/2025	2	Combo Fountain	In art classroom A220 second clockwise from entry	WF-04302024-013883	11/14/2024	FT-FY25-10082024-013883-A	<2	FT-FY25-10082024-013883-B	<2
WS-013885	4/30/2024	4/30/2025	2	Combo Fountain	In art classroom A220 third clockwise from entry	WF-04302024-013885	11/14/2024	FT-FY25-10082024-013885-A	<2	FT-FY25-10082024-013885-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013754	11/28/2023	11/28/2024	Basement	Food Prep Sink	In kitchen	WF-11282023-013754	11/14/2024	FT-FY25-10082024-013754-A	<2	FT-FY25-10082024-013754-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013855	4/30/2024	4/30/2025	2	Combo Fountain	In music classroom A207	WF-04302024-013855	11/14/2024	FT-FY25-10082024-013855-A	7.9	FT-FY25-10082024-013855-B	3.1

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.