



Murch ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013750	5/1/2019	5/1/2020	Basement	Bottle Filler	In cafeteria	WF-05012019-013750	11/7/2019	FT-FY20-102019-013750-A	<1	FT-FY20-102019-013750-B	<1
WS-013751	5/1/2019	5/1/2020	Basement	Cooler	In cafeteria Low Left	WF-05012019-013751	11/7/2019	FT-FY20-102019-013751-A	<1	FT-FY20-102019-013751-B	<1
WS-013752	5/1/2019	5/1/2020	Basement	Cooler	In cafeteria High Right	WF-05012019-013752	11/7/2019	FT-FY20-102019-013752-A	<1	FT-FY20-102019-013752-B	<1
WS-013754	7/18/2019	7/18/2020	Basement	Food Prep Sink	In kitchen	WF-07182019-013754	11/7/2019	FT-FY20-102019-013754-A	<1	FT-FY20-102019-013754-B	<1
WS-013760	5/1/2019	5/1/2020	1	Health Suite	In health suite B110	WF-05012019-013760	11/7/2019	FT-FY20-102019-013760-A	<1	FT-FY20-102019-013760-B	<1
WS-013761	5/1/2019	5/1/2020	1	Combo Fountain	In health suite B110	WF-05012019-013761	11/7/2019	FT-FY20-102019-013761-A	<1	FT-FY20-102019-013761-B	<1
WS-013762	5/1/2019	5/1/2020	1	Break Room	In staff room B111	WF-05012019-013762	11/7/2019	FT-FY20-102019-013762-A	<1	FT-FY20-102019-013762-B	<1
WS-013763	5/1/2019	5/1/2020	1	Combo Fountain	In staff room B111	WF-05012019-013763	11/7/2019	FT-FY20-102019-013763-A	<1	FT-FY20-102019-013763-B	<1
WS-013764	5/1/2019	5/1/2020	1	Break Room	In staff room B112	WF-05012019-013764	11/7/2019	FT-FY20-102019-013764-A	<1	FT-FY20-102019-013764-B	<1
WS-013765	5/1/2019	5/1/2020	1	Combo Fountain	In staff room B112	WF-05012019-013765	11/7/2019	FT-FY20-102019-013765-A	1.1	FT-FY20-102019-013765-B	<1
WS-013767	5/1/2019	5/1/2020	1	Combo Fountain	In office B109	WF-05012019-013767	11/7/2019	FT-FY20-102019-013767-A	1.2	FT-FY20-102019-013767-B	<1
WS-013769	5/1/2019	5/1/2020	1	Combo Fountain	In office B108	WF-05012019-013769	11/7/2019	FT-FY20-102019-013769-A	<1	FT-FY20-102019-013769-B	<1
WS-013771	5/1/2019	5/1/2020	1	Combo Fountain	In office B107	WF-05012019-013771	11/7/2019	FT-FY20-102019-013771-A	<1	FT-FY20-102019-013771-B	<1
WS-013772	5/1/2019	5/1/2020	1	Bottle Filler	In hallway across from offices B100E	WF-05012019-013772	11/7/2019	FT-FY20-102019-013772-A	<1	FT-FY20-102019-013772-B	<1
WS-013773	5/1/2019	5/1/2020	1	Cooler	In hallway across from offices B100E Low Left	WF-05012019-013773	11/7/2019	FT-FY20-102019-013773-A	<1	FT-FY20-102019-013773-B	<1
WS-013774	5/1/2019	5/1/2020	1	Cooler	In hallway across from offices B100E High Right	WF-05012019-013774	11/7/2019	FT-FY20-102019-013774-A	<1	FT-FY20-102019-013774-B	<1
WS-013776	5/1/2019	5/1/2020	1	Combo Fountain	In classroom C105	WF-05012019-013776	11/7/2019	FT-FY20-102019-013776-A	<1	FT-FY20-102019-013776-B	<1
WS-013778	5/1/2019	5/1/2020	1	Combo Fountain	In classroom C106	WF-05012019-013778	11/7/2019	FT-FY20-102019-013778-A	<1	FT-FY20-102019-013778-B	<1
WS-013779	5/1/2019	5/1/2020	1	Bottle Filler	In hallway adjacent to classroom C105	WF-05012019-013779	11/7/2019	FT-FY20-102019-013779-A	<1	FT-FY20-102019-013779-B	<1
WS-013780	5/1/2019	5/1/2020	1	Cooler	In hallway adjacent to classroom C105 Low Left	WF-05012019-013780	11/7/2019	FT-FY20-102019-013780-A	<1	FT-FY20-102019-013780-B	<1
WS-013781	5/1/2019	5/1/2020	1	Cooler	In hallway adjacent to classroom C105 High Right	WF-05012019-013781	11/7/2019	FT-FY20-102019-013781-A	<1	FT-FY20-102019-013781-B	<1
WS-013783	5/1/2019	5/1/2020	1	Combo Fountain	In classroom C104	WF-05012019-013783	11/7/2019	FT-FY20-102019-013783-A	<1	FT-FY20-102019-013783-B	<1
WS-013785	5/1/2019	5/1/2020	1	Combo Fountain	In classroom C107	WF-05012019-013785	11/7/2019	FT-FY20-102019-013785-A	<1	FT-FY20-102019-013785-B	<1
WS-013787	5/1/2019	5/1/2020	1	Combo Fountain	In classroom C101	WF-05012019-013787	11/7/2019	FT-FY20-102019-013787-A	<1	FT-FY20-102019-013787-B	<1
WS-013788	5/1/2019	5/1/2020	1	Bottle Filler	In library/media center B119	WF-05012019-013788	11/7/2019	FT-FY20-102019-013788-A	<1	FT-FY20-102019-013788-B	<1
WS-013789	5/1/2019	5/1/2020	1	Cooler	In library/media center B119 Low Left	WF-05012019-013789	11/7/2019	FT-FY20-102019-013789-A	<1	FT-FY20-102019-013789-B	<1
WS-013790	5/1/2019	5/1/2020	1	Cooler	In library/media center B119 High Right	WF-05012019-013790	11/7/2019	FT-FY20-102019-013790-A	<1	FT-FY20-102019-013790-B	<1
WS-013792	5/1/2019	5/1/2020	1	Combo Fountain	In small group instruction room B120	WF-05012019-013792	11/7/2019	FT-FY20-102019-013792-A	1.4	FT-FY20-102019-013792-B	<1
WS-013794	5/1/2019	5/1/2020	1	Combo Fountain	In office B126	WF-05012019-013794	11/7/2019	FT-FY20-102019-013794-A	<1	FT-FY20-102019-013794-B	<1
WS-013795	5/1/2019	5/1/2020	1	Bottle Filler	In hallway adjacent to gym/janitor room A112	WF-05012019-013795	11/7/2019	FT-FY20-102019-013795-A	<1	FT-FY20-102019-013795-B	<1
WS-013796	5/1/2019	5/1/2020	1	Cooler	In hallway adjacent to gym/janitor room A112 Low Left	WF-05012019-013796	11/7/2019	FT-FY20-102019-013796-A	<1	FT-FY20-102019-013796-B	<1
WS-013798	5/1/2019	5/1/2020	1	Bottle Filler	In hallway across from classroom A104	WF-05012019-013798	11/7/2019	FT-FY20-102019-013798-A	<1	FT-FY20-102019-013798-B	<1
WS-013799	5/1/2019	5/1/2020	1	Cooler	In hallway across from classroom A104 Low Left	WF-05012019-013799	11/7/2019	FT-FY20-102019-013799-A	<1	FT-FY20-102019-013799-B	<1
WS-013800	5/1/2019	5/1/2020	1	Cooler	In hallway across from classroom A104 High Right	WF-05012019-013800	11/7/2019	FT-FY20-102019-013800-A	<1	FT-FY20-102019-013800-B	<1
WS-013801	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A104	WF-10212019-013801	11/7/2019	FT-FY20-102019-013801-A	1.1	FT-FY20-102019-013801-B	<1
WS-013802	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A104	WF-05012019-013802	11/7/2019	FT-FY20-102019-013802-A	3	FT-FY20-102019-013802-B	<1

WS-013803	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A108		WF-10212019-013803	11/7/2019	FT-FY20-102019-013803-A	<1	FT-FY20-102019-013803-B	<1
WS-013804	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A108		WF-05012019-013804	11/7/2019	FT-FY20-102019-013804-A	1.7	FT-FY20-102019-013804-B	<1
WS-013805	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A103		WF-10212019-013805	11/7/2019	FT-FY20-102019-013805-A	<1	FT-FY20-102019-013805-B	<1
WS-013806	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A103		WF-05012019-013806	11/7/2019	FT-FY20-102019-013806-A	<1	FT-FY20-102019-013806-B	<1
WS-013807	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A102		WF-10212019-013807	11/7/2019	FT-FY20-102019-013807-A	<1	FT-FY20-102019-013807-B	<1
WS-013808	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A102		WF-05012019-013808	11/7/2019	FT-FY20-102019-013808-A	<1	FT-FY20-102019-013808-B	<1
WS-013809	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A107		WF-10212019-013809	11/7/2019	FT-FY20-102019-013809-A	<1	FT-FY20-102019-013809-B	<1
WS-013810	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A107		WF-05012019-013810	11/7/2019	FT-FY20-102019-013810-A	<1	FT-FY20-102019-013810-B	<1
WS-013811	10/21/2019	10/21/2020	1	Combo Faucet	In early childhood commons A113 adjacent to room A109		WF-10212019-013811	11/7/2019	FT-FY20-102019-013811-A	<1	FT-FY20-102019-013811-B	<1
WS-013812	5/1/2019	5/1/2020	1	Combo Fountain	In early childhood commons A113 adjacent to room A109		WF-05012019-013812	11/7/2019	FT-FY20-102019-013812-A	<1	FT-FY20-102019-013812-B	<1
WS-013813	10/21/2019	10/21/2020	1	Combo Faucet	In early childhood commons A113 adjacent to room A116		WF-10212019-013813	11/7/2019	FT-FY20-102019-013813-A	<1	FT-FY20-102019-013813-B	<1
WS-013814	5/1/2019	5/1/2020	1	Combo Fountain	In early childhood commons A113 adjacent to room A116		WF-05012019-013814	11/7/2019	FT-FY20-102019-013814-A	<1	FT-FY20-102019-013814-B	<1
WS-013815	5/1/2019	5/1/2020	1	Bottle Filler	In hallway across from classroom A121		WF-05012019-013815	11/7/2019	FT-FY20-102019-013815-A	<1	FT-FY20-102019-013815-B	<1
WS-013816	5/1/2019	5/1/2020	1	Cooler	In hallway across from classroom A121	Low Left	WF-05012019-013816	11/7/2019	FT-FY20-102019-013816-A	<1	FT-FY20-102019-013816-B	<1
WS-013817	5/1/2019	5/1/2020	1	Cooler	In hallway across from classroom A121	High Right	WF-05012019-013817	11/7/2019	FT-FY20-102019-013817-A	<1	FT-FY20-102019-013817-B	<1
WS-013818	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A121		WF-10212019-013818	11/7/2019	FT-FY20-102019-013818-A	1.4	FT-FY20-102019-013818-B	<1
WS-013819	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A121		WF-05012019-013819	11/7/2019	FT-FY20-102019-013819-A	<1	FT-FY20-102019-013819-B	<1
WS-013820	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A120		WF-10212019-013820	11/7/2019	FT-FY20-102019-013820-A	1	FT-FY20-102019-013820-B	<1
WS-013821	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A120		WF-05012019-013821	11/7/2019	FT-FY20-102019-013821-A	<1	FT-FY20-102019-013821-B	<1
WS-013822	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A115		WF-10212019-013822	11/7/2019	FT-FY20-102019-013822-A	<1	FT-FY20-102019-013822-B	<1
WS-013823	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A115		WF-05012019-013823	11/7/2019	FT-FY20-102019-013823-A	<1	FT-FY20-102019-013823-B	<1
WS-013824	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A114		WF-10212019-013824	11/7/2019	FT-FY20-102019-013824-A	<1	FT-FY20-102019-013824-B	<1
WS-013825	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A114		WF-05012019-013825	11/7/2019	FT-FY20-102019-013825-A	<1	FT-FY20-102019-013825-B	<1
WS-013826	10/21/2019	10/21/2020	1	Combo Faucet	In classroom A119		WF-10212019-013826	11/7/2019	FT-FY20-102019-013826-A	<1	FT-FY20-102019-013826-B	<1
WS-013827	5/1/2019	5/1/2020	1	Combo Fountain	In classroom A119		WF-05012019-013827	11/7/2019	FT-FY20-102019-013827-A	<1	FT-FY20-102019-013827-B	<1
WS-013829	5/1/2019	5/1/2020	2	Combo Fountain	In classroom B205		WF-05012019-013829	11/7/2019	FT-FY20-102019-013829-A	<1	FT-FY20-102019-013829-B	<1
WS-013831	5/1/2019	5/1/2020	2	Combo Fountain	In classroom B204		WF-05012019-013831	11/7/2019	FT-FY20-102019-013831-A	<1	FT-FY20-102019-013831-B	<1
WS-013832	5/1/2019	5/1/2020	2	Bottle Filler	In hallway adjacent to classroom B204		WF-05012019-013832	11/7/2019	FT-FY20-102019-013832-A	<1	FT-FY20-102019-013832-B	<1
WS-013833	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to classroom B204	Low Left	WF-05012019-013833	11/7/2019	FT-FY20-102019-013833-A	<1	FT-FY20-102019-013833-B	<1
WS-013834	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to classroom B204	High Right	WF-05012019-013834	11/7/2019	FT-FY20-102019-013834-A	<1	FT-FY20-102019-013834-B	<1
WS-013836	5/1/2019	5/1/2020	2	Combo Fountain	In classroom B206		WF-05012019-013836	11/7/2019	FT-FY20-102019-013836-A	<1	FT-FY20-102019-013836-B	<1
WS-013838	5/1/2019	5/1/2020	2	Combo Fountain	In classroom B203		WF-05012019-013838	11/7/2019	FT-FY20-102019-013838-A	<1	FT-FY20-102019-013838-B	<1
WS-013840	5/1/2019	5/1/2020	2	Combo Fountain	In classroom C205		WF-05012019-013840	11/7/2019	FT-FY20-102019-013840-A	<1	FT-FY20-102019-013840-B	<1
WS-013842	5/1/2019	5/1/2020	2	Combo Fountain	In classroom C206		WF-05012019-013842	11/7/2019	FT-FY20-102019-013842-A	<1	FT-FY20-102019-013842-B	<1
WS-013844	5/1/2019	5/1/2020	2	Combo Fountain	In classroom C204		WF-05012019-013844	11/7/2019	FT-FY20-102019-013844-A	<1	FT-FY20-102019-013844-B	<1
WS-013846	5/1/2019	5/1/2020	2	Combo Fountain	In classroom C207		WF-05012019-013846	11/7/2019	FT-FY20-102019-013846-A	<1	FT-FY20-102019-013846-B	<1
WS-013847	5/1/2019	5/1/2020	2	Bottle Filler	In hallway adjacent to classroom C205		WF-05012019-013847	11/7/2019	FT-FY20-102019-013847-A	<1	FT-FY20-102019-013847-B	<1
WS-013848	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to classroom C205	Low Left	WF-05012019-013848	11/7/2019	FT-FY20-102019-013848-A	<1	FT-FY20-102019-013848-B	<1
WS-013849	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to classroom C205	High Right	WF-05012019-013849	11/7/2019	FT-FY20-102019-013849-A	<1	FT-FY20-102019-013849-B	<1
WS-013851	5/1/2019	5/1/2020	2	Combo Fountain	In classroom C201		WF-05012019-013851	11/7/2019	FT-FY20-102019-013851-A	<1	FT-FY20-102019-013851-B	<1
WS-013853	5/1/2019	5/1/2020	2	Combo Fountain	In classroom B201		WF-05012019-013853	11/7/2019	FT-FY20-102019-013853-A	<1	FT-FY20-102019-013853-B	<1
WS-013855	5/1/2019	5/1/2020	2	Combo Fountain	In music classroom A207		WF-05012019-013855	11/7/2019	FT-FY20-102019-013855-A	<1	FT-FY20-102019-013855-B	<1

WS-013856	5/1/2019	5/1/2020	2	Bottle Filler	In hallway across from small group instruction room A205	WF-05012019-013856	11/7/2019	FT-FY20-102019-013856-A	<1	FT-FY20-102019-013856-B	<1
WS-013857	5/1/2019	5/1/2020	2	Cooler	In hallway across from small group instruction room A205 Low Left	WF-05012019-013857	11/7/2019	FT-FY20-102019-013857-A	<1	FT-FY20-102019-013857-B	<1
WS-013858	5/1/2019	5/1/2020	2	Cooler	In hallway across from small group instruction room A205 High Right	WF-05012019-013858	11/7/2019	FT-FY20-102019-013858-A	<1	FT-FY20-102019-013858-B	<1
WS-013860	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A209	WF-05012019-013860	11/7/2019	FT-FY20-102019-013860-A	<1	FT-FY20-102019-013860-B	<1
WS-013862	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A203	WF-05012019-013862	11/7/2019	FT-FY20-102019-013862-A	<1	FT-FY20-102019-013862-B	<1
WS-013864	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A202	WF-05012019-013864	11/7/2019	FT-FY20-102019-013864-A	<1	FT-FY20-102019-013864-B	<1
WS-013866	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A208	WF-05012019-013866	11/7/2019	FT-FY20-102019-013866-A	<1	FT-FY20-102019-013866-B	<1
WS-013868	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A210	WF-05012019-013868	11/7/2019	FT-FY20-102019-013868-A	<1	FT-FY20-102019-013868-B	<1
WS-013869	5/1/2019	5/1/2020	2	Bottle Filler	In hallway adjacent to small group instruction room A213	WF-05012019-013869	11/7/2019	FT-FY20-102019-013869-A	<1	FT-FY20-102019-013869-B	<1
WS-013870	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to small group instruction room A213 Low Left	WF-05012019-013870	11/7/2019	FT-FY20-102019-013870-A	<1	FT-FY20-102019-013870-B	<1
WS-013871	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to small group instruction room A213 High Right	WF-05012019-013871	11/7/2019	FT-FY20-102019-013871-A	<1	FT-FY20-102019-013871-B	<1
WS-013873	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A217	WF-05012019-013873	11/7/2019	FT-FY20-102019-013873-A	<1	FT-FY20-102019-013873-B	<1
WS-013875	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A212	WF-05012019-013875	11/7/2019	FT-FY20-102019-013875-A	<1	FT-FY20-102019-013875-B	<1
WS-013877	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A211	WF-05012019-013877	11/7/2019	FT-FY20-102019-013877-A	<1	FT-FY20-102019-013877-B	<1
WS-013879	5/1/2019	5/1/2020	2	Combo Fountain	In classroom A216	WF-05012019-013879	11/7/2019	FT-FY20-102019-013879-A	<1	FT-FY20-102019-013879-B	<1
WS-013881	5/1/2019	5/1/2020	2	Combo Fountain	In art classroom A220 first clockwise from entry	WF-05012019-013881	11/7/2019	FT-FY20-102019-013881-A	<1	FT-FY20-102019-013881-B	<1
WS-013883	5/1/2019	5/1/2020	2	Combo Fountain	In art classroom A220 second clockwise from entry	WF-05012019-013883	11/7/2019	FT-FY20-102019-013883-A	<1	FT-FY20-102019-013883-B	<1
WS-013885	5/1/2019	5/1/2020	2	Combo Fountain	In art classroom A220 third clockwise from entry	WF-05012019-013885	11/7/2019	FT-FY20-102019-013885-A	<1	FT-FY20-102019-013885-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013754	7/18/2019	7/18/2020	Basement	Food Prep Sink	In kitchen	WF-07182019-013754	11/7/2019	FT-FY20-102019-013754-A	<1	FT-FY20-102019-013754-B	<1