



# Murch ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013750	8/13/2018	8/13/2019	Basement	Bottle Filler	in cafeteria	WF-08132018-013750	8/23/2018	FT-FY19-082018-013750-A	< 1	FT-FY19-082018-013750-B	< 1
WS-013751	8/13/2018	8/13/2019	Basement	Cooler	in cafeteria Low Left	WF-08132018-013751	8/23/2018	FT-FY19-082018-013751-A	< 1	FT-FY19-082018-013751-B	< 1
WS-013752	8/13/2018	8/13/2019	Basement	Cooler	in cafeteria High Right	WF-08132018-013752	8/23/2018	FT-FY19-082018-013752-A	< 1	FT-FY19-082018-013752-B	< 1
WS-013760	8/13/2018	8/13/2019	1	Health Suite	in health suite B110	WF-08132018-013760	8/23/2018	FT-FY19-082018-013760-A	< 1	FT-FY19-082018-013760-B	< 1
WS-013761	8/13/2018	8/13/2019	1	Combo Fountain	in health suite B110	WF-08132018-013761	8/23/2018	FT-FY19-082018-013761-A	< 1	FT-FY19-082018-013761-B	< 1
WS-013762	8/13/2018	8/13/2019	1	Break Room	in staff room B111	WF-08132018-013762	8/23/2018	FT-FY19-082018-013762-A	< 1	FT-FY19-082018-013762-B	< 1
WS-013763	8/13/2018	8/13/2019	1	Combo Fountain	in staff room B111	WF-08132018-013763	8/23/2018	FT-FY19-082018-013763-A	< 1	FT-FY19-082018-013763-B	< 1
WS-013764	8/13/2018	8/13/2019	1	Break Room	in staff room B112	WF-08132018-013764	8/23/2018	FT-FY19-082018-013764-A	< 1	FT-FY19-082018-013764-B	< 1
WS-013765	8/13/2018	8/13/2019	1	Combo Fountain	in staff room B112	WF-08132018-013765	8/23/2018	FT-FY19-082018-013765-A	< 1	FT-FY19-082018-013765-B	< 1
WS-013767	8/13/2018	8/13/2019	1	Combo Fountain	in office B109	WF-08132018-013767	8/23/2018	FT-FY19-082018-013767-A	< 1	FT-FY19-082018-013767-B	< 1
WS-013769	8/13/2018	8/13/2019	1	Combo Fountain	in office B108	WF-08132018-013769	8/23/2018	FT-FY19-082018-013769-A	< 1	FT-FY19-082018-013769-B	< 1
WS-013771	8/13/2018	8/13/2019	1	Combo Fountain	in office B107	WF-08132018-013771	8/23/2018	FT-FY19-082018-013771-A	< 1	FT-FY19-082018-013771-B	< 1
WS-013772	8/13/2018	8/13/2019	1	Bottle Filler	in hallway across from offices B100E	WF-08132018-013772	8/23/2018	FT-FY19-082018-013772-A	< 1	FT-FY19-082018-013772-B	< 1
WS-013773	8/13/2018	8/13/2019	1	Cooler	in hallway across from offices B100E Low Left	WF-08132018-013773	8/23/2018	FT-FY19-082018-013773-A	< 1	FT-FY19-082018-013773-B	< 1
WS-013774	8/13/2018	8/13/2019	1	Cooler	in hallway across from offices B100E High Right	WF-08132018-013774	8/23/2018	FT-FY19-082018-013774-A	< 1	FT-FY19-082018-013774-B	< 1
WS-013776	8/13/2018	8/13/2019	1	Combo Fountain	in classroom C105	WF-08132018-013776	8/23/2018	FT-FY19-082018-013776-A	< 1	FT-FY19-082018-013776-B	< 1
WS-013778	8/13/2018	8/13/2019	1	Combo Fountain	in classroom C106	WF-08132018-013778	8/23/2018	FT-FY19-082018-013778-A	< 1	FT-FY19-082018-013778-B	< 1
WS-013779	8/13/2018	8/13/2019	1	Bottle Filler	in hallway adjacent to classroom C105	WF-08132018-013779	8/23/2018	FT-FY19-082018-013779-A	< 1	FT-FY19-082018-013779-B	< 1
WS-013780	8/13/2018	8/13/2019	1	Cooler	in hallway adjacent to classroom C105 Low Left	WF-08132018-013780	8/23/2018	FT-FY19-082018-013780-A	< 1	FT-FY19-082018-013780-B	< 1
WS-013781	8/13/2018	8/13/2019	1	Cooler	in hallway adjacent to classroom C105 High Right	WF-08132018-013781	8/23/2018	FT-FY19-082018-013781-A	< 1	FT-FY19-082018-013781-B	< 1
WS-013783	8/13/2018	8/13/2019	1	Combo Fountain	in classroom C104	WF-08132018-013783	8/23/2018	FT-FY19-082018-013783-A	< 1	FT-FY19-082018-013783-B	< 1
WS-013785	8/13/2018	8/13/2019	1	Combo Fountain	in classroom C107	WF-08132018-013785	8/23/2018	FT-FY19-082018-013785-A	< 1	FT-FY19-082018-013785-B	< 1
WS-013787	8/13/2018	8/13/2019	1	Combo Fountain	in classroom C101	WF-08132018-013787	8/23/2018	FT-FY19-082018-013787-A	< 1	FT-FY19-082018-013787-B	< 1
WS-013788	8/13/2018	8/13/2019	1	Bottle Filler	in library/media center B119	WF-08132018-013788	8/23/2018	FT-FY19-082018-013788-A	< 1	FT-FY19-082018-013788-B	< 1
WS-013789	8/13/2018	8/13/2019	1	Cooler	in library/media center B119 Low Left	WF-08132018-013789	8/23/2018	FT-FY19-082018-013789-A	< 1	FT-FY19-082018-013789-B	< 1
WS-013790	8/13/2018	8/13/2019	1	Cooler	in library/media center B119 High Right	WF-08132018-013790	8/23/2018	FT-FY19-082018-013790-A	< 1	FT-FY19-082018-013790-B	< 1
WS-013792	8/13/2018	8/13/2019	1	Combo Fountain	in small group instruction room B120	WF-08132018-013792	8/23/2018	FT-FY19-082018-013792-A	< 1	FT-FY19-082018-013792-B	< 1
WS-013794	8/13/2018	8/13/2019	1	Combo Fountain	in office B126	WF-08132018-013794	8/23/2018	FT-FY19-082018-013794-A	< 1	FT-FY19-082018-013794-B	< 1
WS-013795	8/13/2018	8/13/2019	1	Bottle Filler	in hallway adjacent to gym/janitor room A112	WF-08132018-013795	8/23/2018	FT-FY19-082018-013795-A	< 1	FT-FY19-082018-013795-B	< 1
WS-013796	8/13/2018	8/13/2019	1	Cooler	in hallway adjacent to gym/janitor room A112 Low Left	WF-08132018-013796	8/23/2018	FT-FY19-082018-013796-A	< 1	FT-FY19-082018-013796-B	< 1
WS-013797	8/13/2018	8/13/2019	1	Cooler	in hallway adjacent to gym/janitor room A112 High Right	WF-08132018-013797	8/23/2018	FT-FY19-082018-013797-A	< 1	FT-FY19-082018-013797-B	< 1
WS-013798	8/13/2018	8/13/2019	1	Bottle Filler	in hallway across from classroom A104	WF-08132018-013798	8/23/2018	FT-FY19-082018-013798-A	< 1	FT-FY19-082018-013798-B	< 1
WS-013799	8/13/2018	8/13/2019	1	Cooler	in hallway across from classroom A104 Low Left	WF-08132018-013799	8/23/2018	FT-FY19-082018-013799-A	< 1	FT-FY19-082018-013799-B	< 1
WS-013800	8/13/2018	8/13/2019	1	Cooler	in hallway across from classroom A104 High Right	WF-08132018-013800	8/23/2018	FT-FY19-082018-013800-A	< 1	FT-FY19-082018-013800-B	< 1
WS-013801	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A104	WF-08132018-013801	8/23/2018	FT-FY19-082018-013801-A	< 1	FT-FY19-082018-013801-B	< 1

WS-013802	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A104	WF-08132018-013802	8/23/2018	FT-FY19-082018-013802-A	< 1	FT-FY19-082018-013802-B	< 1	
WS-013803	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A108	WF-08132018-013803	8/23/2018	FT-FY19-082018-013803-A	1.3	FT-FY19-082018-013803-B	< 1	
WS-013804	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A108	WF-08132018-013804	8/23/2018	FT-FY19-082018-013804-A	< 1	FT-FY19-082018-013804-B	< 1	
WS-013805	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A103	WF-08132018-013805	8/23/2018	FT-FY19-082018-013805-A	< 1	FT-FY19-082018-013805-B	< 1	
WS-013806	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A103	WF-08132018-013806	8/23/2018	FT-FY19-082018-013806-A	< 1	FT-FY19-082018-013806-B	< 1	
WS-013807	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A102	WF-08132018-013807	8/23/2018	FT-FY19-082018-013807-A	1.5	FT-FY19-082018-013807-B	< 1	
WS-013808	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A102	WF-08132018-013808	8/23/2018	FT-FY19-082018-013808-A	< 1	FT-FY19-082018-013808-B	< 1	
WS-013809	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A107	WF-08132018-013809	8/23/2018	FT-FY19-082018-013809-A	< 1	FT-FY19-082018-013809-B	< 1	
WS-013810	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A107	WF-08132018-013810	8/23/2018	FT-FY19-082018-013810-A	< 1	FT-FY19-082018-013810-B	< 1	
WS-013811	8/13/2018	8/13/2019	1	Combo Faucet	in early childhood commons A113 adjacent to room A109	WF-08132018-013811	8/23/2018	FT-FY19-082018-013811-A	< 1	FT-FY19-082018-013811-B	< 1	
WS-013812	8/13/2018	8/13/2019	1	Combo Fountain	in early childhood commons A113 adjacent to room A109	WF-08132018-013812	8/23/2018	FT-FY19-082018-013812-A	< 1	FT-FY19-082018-013812-B	< 1	
WS-013813	8/13/2018	8/13/2019	1	Combo Faucet	in early childhood commons A113 adjacent to room A116	WF-08132018-013813	8/23/2018	FT-FY19-082018-013813-A	1.3	FT-FY19-082018-013813-B	< 1	
WS-013814	8/13/2018	8/13/2019	1	Combo Fountain	in early childhood commons A113 adjacent to room A116	WF-08132018-013814	8/23/2018	FT-FY19-082018-013814-A	< 1	FT-FY19-082018-013814-B	< 1	
WS-013815	8/13/2018	8/13/2019	1	Bottle Filler	in hallway across from classroom A121	WF-08132018-013815	8/23/2018	FT-FY19-082018-013815-A	< 1	FT-FY19-082018-013815-B	< 1	
WS-013816	8/13/2018	8/13/2019	1	Cooler	in hallway across from classroom A121	Low Left	WF-08132018-013816	8/23/2018	FT-FY19-082018-013816-A	< 1	FT-FY19-082018-013816-B	< 1
WS-013817	8/13/2018	8/13/2019	1	Cooler	in hallway across from classroom A121	High Right	WF-08132018-013817	8/23/2018	FT-FY19-082018-013817-A	< 1	FT-FY19-082018-013817-B	< 1
WS-013818	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A121	WF-08132018-013818	8/23/2018	FT-FY19-082018-013818-A	2.4	FT-FY19-082018-013818-B	< 1	
WS-013819	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A121	WF-08132018-013819	8/23/2018	FT-FY19-082018-013819-A	< 1	FT-FY19-082018-013819-B	< 1	
WS-013820	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A120	WF-08132018-013820	8/23/2018	FT-FY19-082018-013820-A	6	FT-FY19-082018-013820-B	< 1	
WS-013821	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A120	WF-08132018-013821	8/23/2018	FT-FY19-082018-013821-A	< 1	FT-FY19-082018-013821-B	< 1	
WS-013822	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A115	WF-08132018-013822	8/23/2018	FT-FY19-082018-013822-A	1	FT-FY19-082018-013822-B	< 1	
WS-013823	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A115	WF-08132018-013823	8/23/2018	FT-FY19-082018-013823-A	< 1	FT-FY19-082018-013823-B	< 1	
WS-013824	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A114	WF-08132018-013824	8/23/2018	FT-FY19-082018-013824-A	< 1	FT-FY19-082018-013824-B	< 1	
WS-013825	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A114	WF-08132018-013825	8/23/2018	FT-FY19-082018-013825-A	< 1	FT-FY19-082018-013825-B	< 1	
WS-013826	8/13/2018	8/13/2019	1	Combo Faucet	in classroom A119	WF-08132018-013826	8/23/2018	FT-FY19-082018-013826-A	< 1	FT-FY19-082018-013826-B	< 1	
WS-013827	8/13/2018	8/13/2019	1	Combo Fountain	in classroom A119	WF-08132018-013827	8/23/2018	FT-FY19-082018-013827-A	< 1	FT-FY19-082018-013827-B	< 1	
WS-013829	8/13/2018	8/13/2019	2	Combo Fountain	in classroom B205	WF-08132018-013829	8/23/2018	FT-FY19-082018-013829-A	< 1	FT-FY19-082018-013829-B	< 1	
WS-013831	8/13/2018	8/13/2019	2	Combo Fountain	in classroom B204	WF-08132018-013831	8/23/2018	FT-FY19-082018-013831-A	< 1	FT-FY19-082018-013831-B	< 1	
WS-013832	8/13/2018	8/13/2019	2	Bottle Filler	in hallway adjacent to classroom B204	WF-08132018-013832	8/23/2018	FT-FY19-082018-013832-A	< 1	FT-FY19-082018-013832-B	< 1	
WS-013833	8/13/2018	8/13/2019	2	Cooler	in hallway adjacent to classroom B204	Low Left	WF-08132018-013833	8/23/2018	FT-FY19-082018-013833-A	< 1	FT-FY19-082018-013833-B	< 1
WS-013834	8/13/2018	8/13/2019	2	Cooler	in hallway adjacent to classroom B204	High Right	WF-08132018-013834	8/23/2018	FT-FY19-082018-013834-A	< 1	FT-FY19-082018-013834-B	< 1
WS-013836	8/13/2018	8/13/2019	2	Combo Fountain	in classroom B206	WF-08132018-013836	8/23/2018	FT-FY19-082018-013836-A	< 1	FT-FY19-082018-013836-B	< 1	
WS-013838	8/13/2018	8/13/2019	2	Combo Fountain	in classroom B203	WF-08132018-013838	8/23/2018	FT-FY19-082018-013838-A	< 1	FT-FY19-082018-013838-B	< 1	
WS-013840	8/13/2018	8/13/2019	2	Combo Fountain	in classroom C205	WF-08132018-013840	8/23/2018	FT-FY19-082018-013840-A	< 1	FT-FY19-082018-013840-B	< 1	
WS-013842	8/13/2018	8/13/2019	2	Combo Fountain	in classroom C206	WF-08132018-013842	8/23/2018	FT-FY19-082018-013842-A	< 1	FT-FY19-082018-013842-B	< 1	
WS-013844	8/13/2018	8/13/2019	2	Combo Fountain	in classroom C204	WF-08132018-013844	8/23/2018	FT-FY19-082018-013844-A	< 1	FT-FY19-082018-013844-B	< 1	
WS-013846	8/13/2018	8/13/2019	2	Combo Fountain	in classroom C207	WF-08132018-013846	8/23/2018	FT-FY19-082018-013846-A	< 1	FT-FY19-082018-013846-B	< 1	
WS-013847	8/13/2018	8/13/2019	2	Bottle Filler	in hallway adjacent to classroom C205	WF-08132018-013847	8/23/2018	FT-FY19-082018-013847-A	< 1	FT-FY19-082018-013847-B	< 1	
WS-013848	8/13/2018	8/13/2019	2	Cooler	in hallway adjacent to classroom C205	Low Left	WF-08132018-013848	8/23/2018	FT-FY19-082018-013848-A	< 1	FT-FY19-082018-013848-B	< 1
WS-013849	8/13/2018	8/13/2019	2	Cooler	in hallway adjacent to classroom C205	High Right	WF-08132018-013849	8/23/2018	FT-FY19-082018-013849-A	< 1	FT-FY19-082018-013849-B	< 1
WS-013851	8/13/2018	8/13/2019	2	Combo Fountain	in classroom C201	WF-08132018-013851	8/23/2018	FT-FY19-082018-013851-A	< 1	FT-FY19-082018-013851-B	< 1	

WS-013853	8/13/2018	8/13/2019	2	Combo Fountain	In classroom B201	WF-08132018-013853	8/23/2018	FT-FY19-082018-013853-A	< 1	FT-FY19-082018-013853-B	< 1	
WS-013855	8/13/2018	8/13/2019	2	Combo Fountain	In music classroom A207	WF-08132018-013855	8/23/2018	FT-FY19-082018-013855-A	< 1	FT-FY19-082018-013855-B	< 1	
WS-013856	8/13/2018	8/13/2019	2	Bottle Filler	In hallway across from small group instruction room A205	WF-08132018-013856	8/23/2018	FT-FY19-082018-013856-A	1.4	FT-FY19-082018-013856-B	3.4	
WS-013857	8/13/2018	8/13/2019	2	Cooler	In hallway across from small group instruction room A205	Low Left	WF-08132018-013857	8/23/2018	FT-FY19-082018-013857-A	< 1	FT-FY19-082018-013857-B	< 1
WS-013858	8/13/2018	8/13/2019	2	Cooler	In hallway across from small group instruction room A205	High Right	WF-08132018-013858	8/23/2018	FT-FY19-082018-013858-A	< 1	FT-FY19-082018-013858-B	< 1
WS-013860	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A209	WF-08132018-013860	8/23/2018	FT-FY19-082018-013860-A	< 1	FT-FY19-082018-013860-B	< 1	
WS-013862	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A203	WF-08132018-013862	8/23/2018	FT-FY19-082018-013862-A	< 1	FT-FY19-082018-013862-B	< 1	
WS-013864	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A202	WF-08132018-013864	8/23/2018	FT-FY19-082018-013864-A	< 1	FT-FY19-082018-013864-B	< 1	
WS-013866	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A208	WF-08132018-013866	8/23/2018	FT-FY19-082018-013866-A	< 1	FT-FY19-082018-013866-B	< 1	
WS-013868	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A210	WF-08132018-013868	8/23/2018	FT-FY19-082018-013868-A	< 1	FT-FY19-082018-013868-B	< 1	
WS-013869	8/13/2018	8/13/2019	2	Bottle Filler	In hallway adjacent to small group instruction room A213	WF-08132018-013869	8/23/2018	FT-FY19-082018-013869-A	< 1	FT-FY19-082018-013869-B	< 1	
WS-013870	8/13/2018	8/13/2019	2	Cooler	In hallway adjacent to small group instruction room A213	Low Left	WF-08132018-013870	8/23/2018	FT-FY19-082018-013870-A	< 1	FT-FY19-082018-013870-B	1.3
WS-013871	8/13/2018	8/13/2019	2	Cooler	In hallway adjacent to small group instruction room A213	High Right	WF-08132018-013871	8/23/2018	FT-FY19-082018-013871-A	< 1	FT-FY19-082018-013871-B	< 1
WS-013873	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A217	WF-08132018-013873	8/23/2018	FT-FY19-082018-013873-A	< 1	FT-FY19-082018-013873-B	< 1	
WS-013875	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A212	WF-08132018-013875	8/23/2018	FT-FY19-082018-013875-A	< 1	FT-FY19-082018-013875-B	< 1	
WS-013877	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A211	WF-08132018-013877	8/23/2018	FT-FY19-082018-013877-A	< 1	FT-FY19-082018-013877-B	< 1	
WS-013879	8/13/2018	8/13/2019	2	Combo Fountain	In classroom A216	WF-08132018-013879	8/23/2018	FT-FY19-082018-013879-A	< 1	FT-FY19-082018-013879-B	< 1	
WS-013881	8/13/2018	8/13/2019	2	Combo Fountain	In art classroom A220 first clockwise from entry	WF-08132018-013881	8/23/2018	FT-FY19-082018-013881-A	< 1	FT-FY19-082018-013881-B	< 1	
WS-013883	8/13/2018	8/13/2019	2	Combo Fountain	In art classroom A220 second clockwise from entry	WF-08132018-013883	8/23/2018	FT-FY19-082018-013883-A	< 1	FT-FY19-082018-013883-B	< 1	
WS-013885	8/13/2018	8/13/2019	2	Combo Fountain	In art classroom A220 third clockwise from entry	WF-08132018-013885	8/23/2018	FT-FY19-082018-013885-A	< 1	FT-FY19-082018-013885-B	< 1	

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013754	Basement	Food Prep Sink	In kitchen				8/23/2018	FT-FY19-082018-013754-A	< 1	FT-FY19-082018-013754-B	< 1

### FY19 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013820	8/13/2018	8/13/2019	1	Combo Faucet	In classroom A120		WF-08132018-013820	8/23/2018	FT-FY19-082018-013820-A	6	FT-FY19-082018-013820-B	< 1

### First Re-test (After Plumbing Check)

### FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013820	8/24/2018	8/24/2019	1	Combo Faucet	In classroom A120		WF-08242018-013820	8/30/2018	FT-FY19-082018-013820-A	3.2	FT-FY19-082018-013820-B	< 1