



# Nalle Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009258	5/19/2020	5/19/2021	Basement	Cooler	In hallway adjacent to stairwell 2	High Left	WF-05192020-009258	2/12/2021	FT-FY21-022021-009258-A	<1	FT-FY21-022021-009258-B	<1
WS- 009259	5/19/2020	5/19/2021	Basement	Cooler	In hallway adjacent to stairwell 2	Low Right	WF-05192020-009259	2/12/2021	FT-FY21-022021-009259-A	<1	FT-FY21-022021-009259-B	<1
WS- 009260	5/19/2020	5/19/2021	Basement	Cooler	In cafeteria adjacent kitchen 011		WF-05192020-009260	2/12/2021	FT-FY21-022021-009260-A	<1	FT-FY21-022021-009260-B	<1
WS- 009261	5/19/2020	5/19/2021	Basement	Cooler	In cafeteria		WF-05192020-009261	2/12/2021	FT-FY21-022021-009261-A	<1	FT-FY21-022021-009261-B	<1
WS- 009264	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to room 111	High Left	WF-05192020-009264	2/12/2021	FT-FY21-022021-009264-A	<1	FT-FY21-022021-009264-B	<1
WS- 009265	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to room 111	Low Right	WF-05192020-009265	2/12/2021	FT-FY21-022021-009265-A	<1	FT-FY21-022021-009265-B	<1
WS- 009268	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 112		WF-05192020-009268	2/12/2021	FT-FY21-022021-009268-A	1.2	FT-FY21-022021-009268-B	<1
WS- 009269	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 112		WF-09222020-009269	2/12/2021	FT-FY21-022021-009269-A	<1	FT-FY21-022021-009269-B	<1
WS- 009270	7/8/2020	7/8/2021	1	Combo Fountain	In health suite 107		WF-07082020-009270	2/12/2021	FT-FY21-022021-009270-A	<1	FT-FY21-022021-009270-B	<1
WS- 009271	7/8/2020	7/8/2021	1	Health Suite	In health suite 107		WF-07082020-009271	2/12/2021	FT-FY21-022021-009271-A	1.2	FT-FY21-022021-009271-B	<1
WS- 009272	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 106		WF-05192020-009272	2/12/2021	FT-FY21-022021-009272-A	<1	FT-FY21-022021-009272-B	<1
WS- 009273	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 106		WF-09222020-009273	2/12/2021	FT-FY21-022021-009273-A	<1	FT-FY21-022021-009273-B	<1
WS- 009274	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 104		WF-05192020-009274	2/12/2021	FT-FY21-022021-009274-A	1.1	FT-FY21-022021-009274-B	<1
WS- 009275	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 104		WF-09222020-009275	2/12/2021	FT-FY21-022021-009275-A	2.9	FT-FY21-022021-009275-B	<1
WS- 009276	7/8/2020	7/8/2021	1	Combo Fountain	In classroom 110		WF-07082020-009276	2/12/2021	FT-FY21-022021-009276-A	<1	FT-FY21-022021-009276-B	<1
WS- 009277	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 110		WF-09222020-009277	2/12/2021	FT-FY21-022021-009277-A	2.3	FT-FY21-022021-009277-B	<1
WS- 009278	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 118		WF-05192020-009278	2/12/2021	FT-FY21-022021-009278-A	<1	FT-FY21-022021-009278-B	<1
WS- 009280	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 120		WF-09222020-009280	2/12/2021	FT-FY21-022021-009280-A	2.3	FT-FY21-022021-009280-B	1.3
WS- 009281	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 123		WF-05192020-009281	2/12/2021	FT-FY21-022021-009281-A	1.2	FT-FY21-022021-009281-B	<1
WS- 009282	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 123		WF-09222020-009282	2/12/2021	FT-FY21-022021-009282-A	1.6	FT-FY21-022021-009282-B	<1
WS- 009283	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to room 127		WF-05192020-009283	2/12/2021	FT-FY21-022021-009283-A	<1	FT-FY21-022021-009283-B	<1
WS- 009284	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 128		WF-05192020-009284	2/12/2021	FT-FY21-022021-009284-A	1.2	FT-FY21-022021-009284-B	<1
WS- 009285	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 128		WF-09222020-009285	2/12/2021	FT-FY21-022021-009285-A	1.0	FT-FY21-022021-009285-B	<1
WS- 009286	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 130		WF-05192020-009286	2/12/2021	FT-FY21-022021-009286-A	<1	FT-FY21-022021-009286-B	<1
WS- 009287	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 130		WF-09222020-009287	2/12/2021	FT-FY21-022021-009287-A	<1	FT-FY21-022021-009287-B	<1
WS- 009288	5/19/2020	5/19/2021	1	Combo Fountain	In classroom 132		WF-05192020-009288	2/12/2021	FT-FY21-022021-009288-A	<1	FT-FY21-022021-009288-B	<1
WS- 009289	9/22/2020	9/22/2021	1	Combo Faucet	In classroom 132		WF-09222020-009289	2/12/2021	FT-FY21-022021-009289-A	2.1	FT-FY21-022021-009289-B	<1
WS- 009290	5/19/2020	5/19/2021	2	Cooler	In hallway adjacent to staff lounge 230		WF-05192020-009290	2/12/2021	FT-FY21-022021-009290-A	<1	FT-FY21-022021-009290-B	<1
WS- 009291	5/19/2020	5/19/2021	2	Break Room	In staff lounge 230		WF-05192020-009291	2/12/2021	FT-FY21-022021-009291-A	<1	FT-FY21-022021-009291-B	<1
WS- 009306	7/8/2020	7/8/2021	1	Break Room	In break room near main office		WF-07082020-009306	2/12/2021	FT-FY21-022021-009306-A	<1	FT-FY21-022021-009306-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009263	2/24/2020	2/24/2021	Basement	Food Prep Sink	In kitchen room 011 Left	WF-02242020-009263	2/12/2021	FT-FY21-022021-009263-A	<1	FT-FY21-022021-009263-B	<1