



Nalle ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009258	3/18/2025	3/18/2026	Basement	Cooler	In hallway adjacent to stairwell 2 High Left	WF-03182025-009258	1/28/2026	FT-FY26-01122026-009258-A	<2	FT-FY26-01122026-009258-B	<2
WS-009259	3/18/2025	3/18/2026	Basement	Cooler	In hallway adjacent to stairwell 2 Low Right	WF-03182025-009259	1/28/2026	FT-FY26-01122026-009259-A	<2	FT-FY26-01122026-009259-B	<2
WS-009260	3/18/2025	3/18/2026	Basement	Cooler	In cafeteria adjacent kitchen 011	WF-03182025-009260	1/28/2026	FT-FY26-01122026-009260-A	<2	FT-FY26-01122026-009260-B	<2
WS-009261	3/18/2025	3/18/2026	Basement	Cooler	In cafeteria	WF-03182025-009261	1/28/2026	FT-FY26-01122026-009261-A	<2	FT-FY26-01122026-009261-B	<2
WS-009264	3/18/2025	3/18/2026	1	Cooler	In hallway adjacent to room 111 High Left	WF-03182025-009264	1/28/2026	FT-FY26-01122026-009264-A	<2	FT-FY26-01122026-009264-B	<2
WS-009265	3/18/2025	3/18/2026	1	Cooler	In hallway adjacent to room 111 Low Right	WF-03182025-009265	1/28/2026	FT-FY26-01122026-009265-A	<2	FT-FY26-01122026-009265-B	<2
WS-009268	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 112	WF-03182025-009268	1/28/2026	FT-FY26-01122026-009268-A	<2	FT-FY26-01122026-009268-B	<2
WS-009269	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 112	WF-08252025-009269	1/28/2026	FT-FY26-01122026-009269-A	<2	FT-FY26-01122026-009269-B	<2
WS-009270	3/18/2025	3/18/2026	1	Combo Fountain	In health suite 107	WF-03182025-009270	1/28/2026	FT-FY26-01122026-009270-A	<2	FT-FY26-01122026-009270-B	<2
WS-009271	3/18/2025	3/18/2026	1	Health Suite	In health suite 107	WF-03182025-009271	1/28/2026	FT-FY26-01122026-009271-A	<2	FT-FY26-01122026-009271-B	<2
WS-009272	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 106	WF-03182025-009272	1/28/2026	FT-FY26-01122026-009272-A	<2	FT-FY26-01122026-009272-B	<2
WS-009273	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 106	WF-08252025-009273	1/28/2026	FT-FY26-01122026-009273-A	<2	FT-FY26-01122026-009273-B	<2
WS-009274	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 104	WF-03182025-009274	1/28/2026	FT-FY26-01122026-009274-A	<2	FT-FY26-01122026-009274-B	<2
WS-009275	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 104	WF-08252025-009275	1/28/2026	FT-FY26-01122026-009275-A	<2	FT-FY26-01122026-009275-B	<2
WS-009276	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 110	WF-03182025-009276	1/28/2026	FT-FY26-01122026-009276-A	2.0	FT-FY26-01122026-009276-B	<2
WS-009277	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 110	WF-08252025-009277	1/28/2026	FT-FY26-01122026-009277-A	2.8	FT-FY26-01122026-009277-B	<2
WS-009278	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 118	WF-03182025-009278	1/28/2026	FT-FY26-01122026-009278-A	<2	FT-FY26-01122026-009278-B	<2
WS-009280	8/25/2025	8/25/2026	1	Classroom Faucet	In classroom 120	WF-08252025-009280	1/28/2026	FT-FY26-01122026-009280-A	<2	FT-FY26-01122026-009280-B	<2
WS-009281	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 123	WF-03182025-009281	1/28/2026	FT-FY26-01122026-009281-A	<2	FT-FY26-01122026-009281-B	<2
WS-009282	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 123	WF-08252025-009282	1/28/2026	FT-FY26-01122026-009282-A	<2	FT-FY26-01122026-009282-B	<2
WS-009283	3/18/2025	3/18/2026	1	Cooler	In hallway adjacent to room 127	WF-03182025-009283	1/28/2026	FT-FY26-01122026-009283-A	<2	FT-FY26-01122026-009283-B	<2
WS-009284	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 128	WF-03182025-009284	1/28/2026	FT-FY26-01122026-009284-A	<2	FT-FY26-01122026-009284-B	<2
WS-009285	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 128	WF-08252025-009285	1/28/2026	FT-FY26-01122026-009285-A	<2	FT-FY26-01122026-009285-B	<2
WS-009286	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 130	WF-03182025-009286	1/28/2026	FT-FY26-01122026-009286-A	<2	FT-FY26-01122026-009286-B	<2
WS-009287	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 130	WF-08252025-009287	1/28/2026	FT-FY26-01122026-009287-A	<2	FT-FY26-01122026-009287-B	<2
WS-009288	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 132	WF-03182025-009288	1/28/2026	FT-FY26-01122026-009288-A	<2	FT-FY26-01122026-009288-B	<2
WS-009289	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 132	WF-08252025-009289	1/28/2026	FT-FY26-01122026-009289-A	<2	FT-FY26-01122026-009289-B	<2
WS-009290	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to staff lounge 230	WF-03182025-009290	1/28/2026	FT-FY26-01122026-009290-A	<2	FT-FY26-01122026-009290-B	<2
WS-009291	3/18/2025	3/18/2026	2	Break Room	In staff lounge 230	WF-03182025-009291	1/28/2026	FT-FY26-01122026-009291-A	<2	FT-FY26-01122026-009291-B	<2
WS-009297	3/18/2025	3/18/2026	2	Cooler	In hallway across from room 214 High Left	WF-03182025-009297	1/28/2026	FT-FY26-01122026-009297-A	<2	FT-FY26-01122026-009297-B	<2
WS-009298	3/18/2025	3/18/2026	2	Cooler	In hallway across from room 214 Low Right	WF-03182025-009298	1/28/2026	FT-FY26-01122026-009298-A	<2	FT-FY26-01122026-009298-B	<2
WS-009306	3/18/2025	3/18/2026	1	Break Room	In break room near main office	WF-03182025-009306	1/28/2026	FT-FY26-01122026-009306-A	<2	FT-FY26-01122026-009306-B	<2
WS-009791	3/18/2025	3/18/2026	2	Bottle Filler	In hallway across from room 214	WF-03182025-009791	1/28/2026	FT-FY26-01122026-009791-A	<2	FT-FY26-01122026-009791-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009263	12/10/2025	12/10/2026	Basement	Food Prep Sink	In kitchen room 011 Left	WF-12102025-009263	1/28/2026	FT-FY26-01122026-009263-A	<2	FT-FY26-01122026-009263-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.