



# Nalle Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009258	4/3/2023	4/3/2024	Basement	Cooler	In hallway adjacent to stairwell 2 High Left	WF-04032023-009258	1/13/2024	FT-FY24-11272023-009258-A	<1	FT-FY24-11272023-009258-B	<1
WS-009259	4/3/2023	4/3/2024	Basement	Cooler	In hallway adjacent to stairwell 2 Low Right	WF-04032023-009259	1/13/2024	FT-FY24-11272023-009259-A	<1	FT-FY24-11272023-009259-B	<1
WS-009260	4/3/2023	4/3/2024	Basement	Cooler	In cafeteria adjacent kitchen 011	WF-04032023-009260	1/13/2024	FT-FY24-11272023-009260-A	<1	FT-FY24-11272023-009260-B	<1
WS-009261	4/3/2023	4/3/2024	Basement	Cooler	In cafeteria	WF-04032023-009261	1/13/2024	FT-FY24-11272023-009261-A	<1	FT-FY24-11272023-009261-B	<1
WS-009264	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to room 111 High Left	WF-04032023-009264	1/13/2024	FT-FY24-11272023-009264-A	1.3	FT-FY24-11272023-009264-B	1.2
WS-009265	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to room 111 Low Right	WF-04032023-009265	1/13/2024	FT-FY24-11272023-009265-A	<1	FT-FY24-11272023-009265-B	<1
WS-009268	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 112	WF-04032023-009268	1/13/2024	FT-FY24-11272023-009268-A	<1	FT-FY24-11272023-009268-B	<1
WS-009269	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 112	WF-08292023-009269	1/13/2024	FT-FY24-11272023-009269-A	<1	FT-FY24-11272023-009269-B	<1
WS-009270	4/3/2023	4/3/2024	1	Combo Fountain	In health suite 107	WF-04032023-009270	1/13/2024	FT-FY24-11272023-009270-A	<1	FT-FY24-11272023-009270-B	<1
WS-009271	4/3/2023	4/3/2024	1	Health Suite	In health suite 107	WF-04032023-009271	1/13/2024	FT-FY24-11272023-009271-A	<1	FT-FY24-11272023-009271-B	<1
WS-009272	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 106	WF-04032023-009272	1/13/2024	FT-FY24-11272023-009272-A	<1	FT-FY24-11272023-009272-B	<1
WS-009273	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 106	WF-08292023-009273	1/13/2024	FT-FY24-11272023-009273-A	<1	FT-FY24-11272023-009273-B	<1
WS-009274	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 104	WF-04032023-009274	1/13/2024	FT-FY24-11272023-009274-A	<1	FT-FY24-11272023-009274-B	<1
WS-009275	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 104	WF-08292023-009275	1/13/2024	FT-FY24-11272023-009275-A	<1	FT-FY24-11272023-009275-B	<1
WS-009276	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 110	WF-04032023-009276	1/13/2024	FT-FY24-11272023-009276-A	<1	FT-FY24-11272023-009276-B	<1
WS-009277	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 110	WF-08292023-009277	1/13/2024	FT-FY24-11272023-009277-A	<1	FT-FY24-11272023-009277-B	<1
WS-009278	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 118	WF-04032023-009278	1/13/2024	FT-FY24-11272023-009278-A	<1	FT-FY24-11272023-009278-B	<1
WS-009280	8/29/2023	8/29/2024	1	Classroom Faucet	In classroom 120	WF-08292023-009280	1/13/2024	FT-FY24-11272023-009280-A	<1	FT-FY24-11272023-009280-B	<1
WS-009281	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 123	WF-04032023-009281	1/13/2024	FT-FY24-11272023-009281-A	<1	FT-FY24-11272023-009281-B	<1
WS-009282	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 123	WF-08292023-009282	1/13/2024	FT-FY24-11272023-009282-A	<1	FT-FY24-11272023-009282-B	<1
WS-009283	4/3/2023	4/3/2024	1	Cooler	In hallway adjacent to room 127	WF-04032023-009283	1/13/2024	FT-FY24-11272023-009283-A	<1	FT-FY24-11272023-009283-B	<1
WS-009284	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 128	WF-04032023-009284	1/13/2024	FT-FY24-11272023-009284-A	<1	FT-FY24-11272023-009284-B	<1
WS-009285	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 128	WF-08292023-009285	1/13/2024	FT-FY24-11272023-009285-A	<1	FT-FY24-11272023-009285-B	<1
WS-009286	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 130	WF-04032023-009286	1/13/2024	FT-FY24-11272023-009286-A	<1	FT-FY24-11272023-009286-B	<1
WS-009287	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 130	WF-08292023-009287	1/13/2024	FT-FY24-11272023-009287-A	<1	FT-FY24-11272023-009287-B	<1
WS-009288	4/3/2023	4/3/2024	1	Combo Fountain	In classroom 132	WF-04032023-009288	1/13/2024	FT-FY24-11272023-009288-A	<1	FT-FY24-11272023-009288-B	<1
WS-009289	8/29/2023	8/29/2024	1	Combo Faucet	In classroom 132	WF-08292023-009289	1/13/2024	FT-FY24-11272023-009289-A	<1	FT-FY24-11272023-009289-B	<1
WS-009290	4/3/2023	4/3/2024	2	Cooler	In hallway adjacent to staff lounge 230	WF-04032023-009290	1/13/2024	FT-FY24-11272023-009290-A	<1	FT-FY24-11272023-009290-B	<1
WS-009291	4/3/2023	4/3/2024	2	Break Room	In staff lounge 230	WF-04032023-009291	1/13/2024	FT-FY24-11272023-009291-A	<1	FT-FY24-11272023-009291-B	<1
WS-009297	4/3/2023	4/3/2024	2	Cooler	In hallway across from room 214 High Left	WF-04032023-009297	1/13/2024	FT-FY24-11272023-009297-A	<1	FT-FY24-11272023-009297-B	<1
WS-009298	4/3/2023	4/3/2024	2	Cooler	In hallway across from room 214 Low Right	WF-04032023-009298	1/13/2024	FT-FY24-11272023-009298-A	<1	FT-FY24-11272023-009298-B	<1
WS-009306	4/3/2023	4/3/2024	1	Break Room	In break room near main office	WF-04032023-009306	1/13/2024	FT-FY24-11272023-009306-A	<1	FT-FY24-11272023-009306-B	<1
WS-009791	4/3/2023	4/3/2024	2	Bottle Filler	In hallway across from room 214	WF-04032023-009791	1/13/2024	FT-FY24-11272023-009791-A	<1	FT-FY24-11272023-009791-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009263	1/17/2023	1/17/2024	Basement	Food Prep Sink	In kitchen room 011	Left	WF-01172023-009263	1/13/2024	FT-FY24-11272023-009263-A	<1	FT-FY24-11272023-009263-B	1.0