



Nalle Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009258	4/20/2021	4/20/2022	Basement	Cooler	In hallway adjacent to stairwell 2	High Left	WF-04202021-009258	2/2/2022	FT-FY22-01102022-009258-A	<1	FT-FY22-01102022-009258-B	<1
WS- 009259	4/20/2021	4/20/2022	Basement	Cooler	In hallway adjacent to stairwell 2	Low Right	WF-04202021-009259	2/2/2022	FT-FY22-01102022-009259-A	<1	FT-FY22-01102022-009259-B	<1
WS- 009264	4/20/2021	4/20/2022	1	Cooler	In hallway adjacent to room 111	High Left	WF-04202021-009264	2/2/2022	FT-FY22-01102022-009264-A	<1	FT-FY22-01102022-009264-B	<1
WS- 009265	4/20/2021	4/20/2022	1	Cooler	In hallway adjacent to room 111	Low Right	WF-04202021-009265	2/2/2022	FT-FY22-01102022-009265-A	<1	FT-FY22-01102022-009265-B	<1
WS- 009268	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 112		WF-04202021-009268	2/2/2022	FT-FY22-01102022-009268-A	1.5	FT-FY22-01102022-009268-B	<1
WS- 009269	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 112		WF-09152021-009269	2/2/2022	FT-FY22-01102022-009269-A	<1	FT-FY22-01102022-009269-B	<1
WS- 009270	4/20/2021	4/20/2022	1	Combo Fountain	In health suite 107		WF-04202021-009270	2/2/2022	FT-FY22-01102022-009270-A	<1	FT-FY22-01102022-009270-B	<1
WS- 009271	4/20/2021	4/20/2022	1	Health Suite	In health suite 107		WF-04202021-009271	2/2/2022	FT-FY22-01102022-009271-A	<1	FT-FY22-01102022-009271-B	<1
WS- 009272	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 106		WF-04202021-009272	2/2/2022	FT-FY22-01102022-009272-A	<1	FT-FY22-01102022-009272-B	<1
WS- 009273	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 106		WF-09152021-009273	2/2/2022	FT-FY22-01102022-009273-A	<1	FT-FY22-01102022-009273-B	<1
WS- 009274	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 104		WF-04202021-009274	2/2/2022	FT-FY22-01102022-009274-A	<1	FT-FY22-01102022-009274-B	<1
WS- 009275	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 104		WF-09152021-009275	2/2/2022	FT-FY22-01102022-009275-A	1.3	FT-FY22-01102022-009275-B	1.6
WS- 009276	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 110		WF-04202021-009276	2/2/2022	FT-FY22-01102022-009276-A	<1	FT-FY22-01102022-009276-B	<1
WS- 009277	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 110		WF-09152021-009277	2/2/2022	FT-FY22-01102022-009277-A	<1	FT-FY22-01102022-009277-B	<1
WS- 009278	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 118		WF-04202021-009278	2/2/2022	FT-FY22-01102022-009278-A	<1	FT-FY22-01102022-009278-B	<1
WS- 009280	9/15/2021	9/15/2022	1	Classroom Faucet	In classroom 120		WF-09152021-009280	2/2/2022	FT-FY22-01102022-009280-A	1.2	FT-FY22-01102022-009280-B	<1
WS- 009281	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 123		WF-04202021-009281	2/2/2022	FT-FY22-01102022-009281-A	<1	FT-FY22-01102022-009281-B	<1
WS- 009282	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 123		WF-09152021-009282	2/2/2022	FT-FY22-01102022-009282-A	<1	FT-FY22-01102022-009282-B	<1
WS- 009283	4/20/2021	4/20/2022	1	Cooler	In hallway adjacent to room 127		WF-04202021-009283	2/2/2022	FT-FY22-01102022-009283-A	<1	FT-FY22-01102022-009283-B	<1
WS- 009284	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 128		WF-04202021-009284	2/2/2022	FT-FY22-01102022-009284-A	<1	FT-FY22-01102022-009284-B	<1
WS- 009285	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 128		WF-09152021-009285	2/2/2022	FT-FY22-01102022-009285-A	<1	FT-FY22-01102022-009285-B	<1
WS- 009286	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 130		WF-04202021-009286	2/2/2022	FT-FY22-01102022-009286-A	<1	FT-FY22-01102022-009286-B	<1
WS- 009287	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 130		WF-09152021-009287	2/2/2022	FT-FY22-01102022-009287-A	<1	FT-FY22-01102022-009287-B	<1
WS- 009288	4/20/2021	4/20/2022	1	Combo Fountain	In classroom 132		WF-04202021-009288	2/2/2022	FT-FY22-01102022-009288-A	<1	FT-FY22-01102022-009288-B	<1
WS- 009289	9/15/2021	9/15/2022	1	Combo Faucet	In classroom 132		WF-09152021-009289	2/2/2022	FT-FY22-01102022-009289-A	<1	FT-FY22-01102022-009289-B	<1
WS- 009290	4/20/2021	4/20/2022	2	Cooler	In hallway adjacent to staff lounge 230		WF-04202021-009290	2/2/2022	FT-FY22-01102022-009290-A	<1	FT-FY22-01102022-009290-B	<1
WS- 009291	4/20/2021	4/20/2022	2	Break Room	In staff lounge 230		WF-04202021-009291	2/2/2022	FT-FY22-01102022-009291-A	<1	FT-FY22-01102022-009291-B	<1
WS- 009297	4/20/2021	4/20/2022	2	Cooler	In hallway across from room 214	High Left	WF-04202021-009297	2/2/2022	FT-FY22-01102022-009297-A	<1	FT-FY22-01102022-009297-B	<1
WS- 009298	4/20/2021	4/20/2022	2	Cooler	In hallway across from room 214	Low Right	WF-04202021-009298	2/2/2022	FT-FY22-01102022-009298-A	<1	FT-FY22-01102022-009298-B	<1
WS- 009306	4/20/2021	4/20/2022	1	Break Room	In break room near main office		WF-04202021-009306	2/2/2022	FT-FY22-01102022-009306-A	<1	FT-FY22-01102022-009306-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009263	2/17/2021	2/17/2022	Basement	Food Prep Sink	In kitchen room 011	Left	WF-02172021-009263	2/2/2022	FT-FY22-01102022-009263-A	<1	FT-FY22-01102022-009263-B	<1