



Nalle Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009258	4/10/2022	4/10/2023	Basement	Cooler	In hallway adjacent to stairwell 2	High Left	WF-04102022-009258	11/15/2022	FT-FY23-10102022-009258-A	<1	FT-FY23-10102022-009258-B	<1
WS- 009259	4/10/2022	4/10/2023	Basement	Cooler	In hallway adjacent to stairwell 2	Low Right	WF-04102022-009259	11/15/2022	FT-FY23-10102022-009259-A	<1	FT-FY23-10102022-009259-B	<1
WS- 009264	4/10/2022	4/10/2023	1	Cooler	In hallway adjacent to room 111	High Left	WF-04102022-009264	11/15/2022	FT-FY23-10102022-009264-A	<1	FT-FY23-10102022-009264-B	<1
WS- 009265	4/10/2022	4/10/2023	1	Cooler	In hallway adjacent to room 111	Low Right	WF-04102022-009265	11/15/2022	FT-FY23-10102022-009265-A	<1	FT-FY23-10102022-009265-B	<1
WS- 009268	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 112		WF-04102022-009268	11/15/2022	FT-FY23-10102022-009268-A	1.1	FT-FY23-10102022-009268-B	<1
WS- 009269	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 112		WF-09072022-009269	11/15/2022	FT-FY23-10102022-009269-A	<1	FT-FY23-10102022-009269-B	1.3
WS- 009270	4/10/2022	4/10/2023	1	Combo Fountain	In health suite 107		WF-04102022-009270	11/15/2022	FT-FY23-10102022-009270-A	<1	FT-FY23-10102022-009270-B	<1
WS- 009271	4/10/2022	4/10/2023	1	Health Suite	In health suite 107		WF-04102022-009271	11/15/2022	FT-FY23-10102022-009271-A	<1	FT-FY23-10102022-009271-B	<1
WS- 009272	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 106		WF-04102022-009272	11/15/2022	FT-FY23-10102022-009272-A	1.2	FT-FY23-10102022-009272-B	<1
WS- 009273	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 106		WF-09072022-009273	11/15/2022	FT-FY23-10102022-009273-A	<1	FT-FY23-10102022-009273-B	<1
WS- 009274	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 104		WF-04102022-009274	11/15/2022	FT-FY23-10102022-009274-A	2.0	FT-FY23-10102022-009274-B	<1
WS- 009275	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 104		WF-09072022-009275	11/15/2022	FT-FY23-10102022-009275-A	2.4	FT-FY23-10102022-009275-B	<1
WS- 009276	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 110		WF-04102022-009276	11/15/2022	FT-FY23-10102022-009276-A	<1	FT-FY23-10102022-009276-B	<1
WS- 009277	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 110		WF-09072022-009277	11/15/2022	FT-FY23-10102022-009277-A	<1	FT-FY23-10102022-009277-B	<1
WS- 009278	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 118		WF-04102022-009278	11/15/2022	FT-FY23-10102022-009278-A	<1	FT-FY23-10102022-009278-B	<1
WS- 009280	9/7/2022	9/7/2023	1	Classroom Faucet	In classroom 120		WF-09072022-009280	11/15/2022	FT-FY23-10102022-009280-A	<1	FT-FY23-10102022-009280-B	<1
WS- 009281	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 123		WF-04102022-009281	11/15/2022	FT-FY23-10102022-009281-A	2.3	FT-FY23-10102022-009281-B	<1
WS- 009282	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 123		WF-09072022-009282	11/15/2022	FT-FY23-10102022-009282-A	1.6	FT-FY23-10102022-009282-B	<1
WS- 009283	4/10/2022	4/10/2023	1	Cooler	In hallway adjacent to room 127		WF-04102022-009283	11/15/2022	FT-FY23-10102022-009283-A	<1	FT-FY23-10102022-009283-B	<1
WS- 009284	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 128		WF-04102022-009284	11/15/2022	FT-FY23-10102022-009284-A	2.2	FT-FY23-10102022-009284-B	<1
WS- 009286	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 130		WF-04102022-009286	11/15/2022	FT-FY23-10102022-009286-A	<1	FT-FY23-10102022-009286-B	<1
WS- 009287	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 130		WF-09072022-009287	11/15/2022	FT-FY23-10102022-009287-A	<1	FT-FY23-10102022-009287-B	<1
WS- 009288	4/10/2022	4/10/2023	1	Combo Fountain	In classroom 132		WF-04102022-009288	11/15/2022	FT-FY23-10102022-009288-A	2.7	FT-FY23-10102022-009288-B	<1
WS- 009289	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 132		WF-09072022-009289	11/15/2022	FT-FY23-10102022-009289-A	4.1	FT-FY23-10102022-009289-B	<1
WS- 009290	4/10/2022	4/10/2023	2	Cooler	In hallway adjacent to staff lounge 230		WF-04102022-009290	11/15/2022	FT-FY23-10102022-009290-A	<1	FT-FY23-10102022-009290-B	<1
WS- 009291	4/10/2022	4/10/2023	2	Break Room	In staff lounge 230		WF-04102022-009291	11/15/2022	FT-FY23-10102022-009291-A	<1	FT-FY23-10102022-009291-B	<1
WS- 009297	4/10/2022	4/10/2023	2	Cooler	In hallway across from room 214	High Left	WF-04102022-009297	11/15/2022	FT-FY23-10102022-009297-A	<1	FT-FY23-10102022-009297-B	<1
WS- 009298	4/10/2022	4/10/2023	2	Cooler	In hallway across from room 214	Low Right	WF-04102022-009298	11/15/2022	FT-FY23-10102022-009298-A	<1	FT-FY23-10102022-009298-B	<1
WS- 009306	4/10/2022	4/10/2023	1	Break Room	In break room near main office		WF-04102022-009306	11/15/2022	FT-FY23-10102022-009306-A	<1	FT-FY23-10102022-009306-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009263	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen room 011	Left	WF-02092022-009263	11/15/2022	FT-FY23-10102022-009263-A	<1	FT-FY23-10102022-009263-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009285	9/7/2022	9/7/2023	1	Combo Faucet	In classroom 128	WF-09072022-009285	11/15/2022	FT-FY23-10102022-009285-A	5.1	FT-FY23-10102022-009285-B	<1