



NALLE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009257	Utility	Basement	In custodian closet 002	WT-042916-9274-A	6.3	WT-042916-9274-B	< 1				
2 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009258	Cooler	Basement	In hallway near stairwell 2	High	WT-042916-9275-A	< 1	WT-042916-9275-B	< 1			
3 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009259	Cooler	Basement	In basement hallway near stair 2	Low	WT-042916-9276-A	< 1	WT-042916-9276-B	< 1			
4 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009260	Cooler	Basement	In cafeteria adjacent kitchen 011		WT-042916-9277-A	< 1	WT-042916-9277-B	< 1			
5 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009261	Cooler	Basement	In cafeteria		WT-042916-9278-A	< 1	WT-042916-9278-B	< 1			
6 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009262	Kitchen	Basement	In kitchen 011	Left	WT-042916-9279-A	< 1	WT-042916-9279-B	< 1			
7 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009263	Kitchen	Basement	In kitchen 011	Right	WT-042916-9280-A	< 1	WT-042916-9280-B	< 1			
8 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009264	Cooler	1	In hallway adjacent custodian closet 111	High	WT-042916-9281-A	< 1	WT-042916-9281-B	< 1			
9 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009265	Cooler	1	In first floor hallway adjacent to custodian closet 111	Low	WT-042916-9282-A	< 1	WT-042916-9282-B	< 1			
10 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009266	Classroom	1	In classroom 119		WT-042916-9283-A	2.1	WT-042916-9283-B	< 1			
11 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009267	Classroom	1	In classroom 117		WT-042916-9284-A	< 1	WT-042916-9284-B	< 1			
12 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009268	Fountain	1	In classroom 112		WT-042916-9285-A	< 1	WT-042916-9285-B	< 1			
13 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009269	Classroom	1	In classroom 112		WT-042916-9286-A	< 1	WT-042916-9286-B	< 1			
14 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009270	Fountain	1	In health suite 107		WT-042916-9287-A	< 1	WT-042916-9287-B	< 1			
15 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009271	Health Suite	1	In health suite 107		WT-042916-9288-A	< 1	WT-042916-9288-B	< 1			
16 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009272	Fountain	1	In classroom 106		WT-042916-9289-A	< 1	WT-042916-9289-B	< 1			
17 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009273	Classroom	1	In classroom 106		WT-042916-9290-A	< 1	WT-042916-9290-B	< 1			
18 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009274	Fountain	1	In classroom 104		WT-042916-9291-A	1.1	WT-042916-9291-B	< 1			
19 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009275	Classroom	1	In classroom 104		WT-042916-9292-A	< 1	WT-042916-9292-B	< 1			
20 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009276	Fountain	1	In classroom 110		WT-042916-9293-A	< 1	WT-042916-9293-B	< 1			
21 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009277	Classroom	1	In classroom 110		WT-042916-9294-A	< 1	WT-042916-9294-B	< 1			
22 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009278	Fountain	1	In classroom 118		WT-042916-9295-A	< 1	WT-042916-9295-B	< 1			
23 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009279	Classroom	1	In classroom 118		WT-042916-9296-A	< 1	WT-042916-9296-B	< 1			
24 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009280	Classroom	1	In classroom 120		WT-042916-9297-A	< 1	WT-042916-9297-B	< 1			
25 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009281	Fountain	1	In classroom 123		WT-042916-9298-A	< 1	WT-042916-9298-B	< 1			
26 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009282	Classroom	1	In classroom 123		WT-042916-9299-A	< 1	WT-042916-9299-B	< 1			
27 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009283	Cooler	1	In hallway adjacent custodial closet 127		WT-042916-9300-A	< 1	WT-042916-9300-B	< 1			
28 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009284	Fountain	1	In classroom 128		WT-042916-9301-A	< 1	WT-042916-9301-B	< 1			
29 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009285	Classroom	1	In classroom 128		WT-042916-9302-A	< 1	WT-042916-9302-B	< 1			
30 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009286	Fountain	1	In classroom 130		WT-042916-9303-A	< 1	WT-042916-9303-B	< 1			
31 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009287	Classroom	1	In classroom 130		WT-042916-9304-A	< 1	WT-042916-9304-B	< 1			
32 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009288	Fountain	1	In classroom 132		WT-042916-9305-A	< 1	WT-042916-9305-B	< 1			
33 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009289	Classroom	1	In classroom 132		WT-042916-9306-A	< 1	WT-042916-9306-B	< 1			
34 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009290	Cooler	2	In hallway adjacent teacher's lounge 230		WT-042916-9307-A	< 1	WT-042916-9307-B	< 1			
35 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009291	Break Room	2	In teacher's lounge 230		WT-042916-9308-A	1.6	WT-042916-9308-B	< 1			
36 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009292	Classroom	2	In classroom 203		WT-042916-9309-A	< 1	WT-042916-9309-B	< 1			
37 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009293	Classroom	2	In classroom 207		WT-042916-9310-A	< 1	WT-042916-9310-B	< 1			
38 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009294	Classroom	2	In art room 208	Left	WT-042916-9311-A	2	WT-042916-9311-B	< 1			
39 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009295	Classroom	2	In art room 208	Right	WT-042916-9312-A	1.1	WT-042916-9312-B	< 1			
40 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009296	Classroom	2	In classroom 209		WT-042916-9313-A	< 1	WT-042916-9313-B	< 1			
41 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009297	Cooler	2	In hallway across from classroom 214	High	WT-042916-9314-A	< 1	WT-042916-9314-B	< 1			
42 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009298	Cooler	2	In hallway across from classroom 214	Low	WT-042916-9315-A	< 1	WT-042916-9315-B	< 1			
43 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009299	Classroom	2	In classroom 214		WT-042916-9316-A	< 1	WT-042916-9316-B	< 1			
44 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009300	Classroom	2	In classroom 219		WT-042916-9317-A	< 1	WT-042916-9317-B	< 1			
45 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009301	Classroom	2	In classroom 222		WT-042916-9318-A	< 1	WT-042916-9318-B	< 1			
46 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009302	Classroom	2	In classroom 221		WT-042916-9319-A	2.2	WT-042916-9319-B	< 1			
47 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009303	Classroom	2	In classroom 213		WT-042916-9320-A	< 1	WT-042916-9320-B	< 1			
48 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009304	Classroom	2	In classroom 220		WT-042916-9321-A	< 1	WT-042916-9321-B	< 1			
49 NALLE ELEMENTARY SCHOOL	5/10/2016	WS-009305	Classroom	1	In classroom 130 in storage room 130A		WT-042916-9322-A	< 1	WT-042916-9322-B	< 1			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.