



# NALLE ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	NALLE ELEMENTARY SCHOOL	WS- 009291	12/23/2016	2	Break Room	In staff lounge 230	FT-102016-009291-A	< 1	FT-102016-009291-B	< 1
2	NALLE ELEMENTARY SCHOOL	WS- 009277	12/23/2016	1	Combo Faucet	In classroom 110	FT-122016-009277-A	< 1	FT-122016-009277-B	< 1
3	NALLE ELEMENTARY SCHOOL	WS- 009287	12/23/2016	1	Combo Faucet	In classroom 130	FT-122016-009287-A	< 1	FT-122016-009287-B	< 1
4	NALLE ELEMENTARY SCHOOL	WS- 009282	12/23/2016	1	Combo Faucet	In classroom 123	FT-122016-009282-A	< 1	FT-122016-009282-B	< 1
5	NALLE ELEMENTARY SCHOOL	WS- 009275	12/23/2016	1	Combo Faucet	In classroom 104	FT-122016-009275-A	< 1	FT-122016-009275-B	< 1
6	NALLE ELEMENTARY SCHOOL	WS- 009289	12/23/2016	1	Combo Faucet	In classroom 132	FT-122016-009289-A	< 1	FT-122016-009289-B	< 1
7	NALLE ELEMENTARY SCHOOL	WS- 009280	12/23/2016	1	Classroom Faucet	In classroom 120	FT-122016-009280-A	< 1	FT-122016-009280-B	< 1
8	NALLE ELEMENTARY SCHOOL	WS- 009273	12/23/2016	1	Combo Faucet	In classroom 106	FT-122016-009273-A	< 1	FT-122016-009273-B	< 1
9	NALLE ELEMENTARY SCHOOL	WS- 009269	12/23/2016	1	Combo Faucet	In classroom 112	FT-122016-009269-A	< 1	FT-122016-009269-B	< 1
10	NALLE ELEMENTARY SCHOOL	WS- 009285	12/23/2016	1	Combo Faucet	In classroom 128	FT-122016-009285-A	< 1	FT-122016-009285-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb