



Nalle ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009260	6/23/2017	6/23/2018	Basement	Cooler	In cafeteria adjacent kitchen 011	WF-62017-009260	11/16/2017	FT-FY18-62017-009260-A	<1	FT-FY18-62017-009260-B	<1
WS- 009265	6/23/2017	6/23/2018	1	Cooler	In hallway adjacent to room 111 Right Low	WF-62017-009265	11/16/2017	FT-FY18-62017-009265-A	<1	FT-FY18-62017-009265-B	<1
WS- 009268	6/23/2017	6/23/2018	1	Combo Fountain	In classroom 112	WF-62017-009268	11/16/2017	FT-FY18-62017-009268-A	<1	FT-FY18-62017-009268-B	<1
WS- 009270	6/23/2017	6/23/2018	1	Combo Fountain	In health suite 107	WF-62017-009270	11/16/2017	FT-FY18-62017-009270-A	<1	FT-FY18-62017-009270-B	<1
WS- 009275	10/31/2017	10/31/2018	1	Combo Faucet	In classroom 104	WF-102017-009275	11/16/2017	FT-FY18-102017-009275-A	<1	FT-FY18-102017-009275-B	<1
WS- 009277	10/31/2017	10/31/2018	1	Combo Faucet	In classroom 110	WF-102017-009277	11/16/2017	FT-FY18-102017-009277-A	4.3	FT-FY18-102017-009277-B	<1
WS- 009280	10/31/2017	10/31/2018	1	Classroom Faucet	In classroom 120	WF-102017-009280	11/16/2017	FT-FY18-102017-009280-A	<1	FT-FY18-102017-009280-B	<1
WS- 009281	6/23/2017	6/23/2018	1	Combo Fountain	In classroom 123	WF-62017-009281	11/16/2017	FT-FY18-62017-009281-A	<1	FT-FY18-62017-009281-B	<1
WS- 009283	6/23/2017	6/23/2018	1	Cooler	In hallway adjacent to room 127	WF-62017-009283	11/16/2017	FT-FY18-62017-009283-A	<1	FT-FY18-62017-009283-B	<1
WS- 009284	6/23/2017	6/23/2018	1	Combo Fountain	In classroom 128	WF-62017-009284	11/16/2017	FT-FY18-62017-009284-A	<1	FT-FY18-62017-009284-B	<1
WS- 009298	6/23/2017	6/23/2018	2	Cooler	In hallway across from room 214 Right Low	WF-62017-009298	11/16/2017	FT-FY18-62017-009298-A	<1	FT-FY18-62017-009298-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009263	Basement	Food Prep Sink	In kitchen room 011 Left	11/16/2017	FT-FY18-102017-009263-A	<1	FT-FY18-102017-009263-B	<1	