



Nalle ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009258	6/4/2018	6/4/2019	Basement	Cooler	In hallway adjacent to stairwell 2 High Left	WF-06042018-009258	11/7/2018	FT-FY19-102018-009258-A	< 1	FT-FY19-102018-009258-B	< 1
WS-009259	6/4/2018	6/4/2019	Basement	Cooler	In hallway adjacent to stairwell 2 Low Right	WF-06042018-009259	11/7/2018	FT-FY19-102018-009259-A	< 1	FT-FY19-102018-009259-B	< 1
WS-009260	6/4/2018	6/4/2019	Basement	Cooler	In cafeteria adjacent kitchen 011	WF-06042018-009260	11/7/2018	FT-FY19-102018-009260-A	< 1	FT-FY19-102018-009260-B	< 1
WS-009261	6/4/2018	6/4/2019	Basement	Cooler	In cafeteria	WF-06042018-009261	11/7/2018	FT-FY19-102018-009261-A	< 1	FT-FY19-102018-009261-B	< 1
WS-009264	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room 111 High Left	WF-06042018-009264	11/7/2018	FT-FY19-102018-009264-A	< 1	FT-FY19-102018-009264-B	< 1
WS-009265	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room 111 Low Right	WF-06042018-009265	11/7/2018	FT-FY19-102018-009265-A	< 1	FT-FY19-102018-009265-B	< 1
WS-009268	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 112	WF-06042018-009268	11/7/2018	FT-FY19-102018-009268-A	< 1	FT-FY19-102018-009268-B	< 1
WS-009269	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 112	WF-10112018-009269	11/7/2018	FT-FY19-102018-009269-A	< 1	FT-FY19-102018-009269-B	< 1
WS-009270	6/4/2018	6/4/2019	1	Combo Fountain	In health suite 107	WF-06042018-009270	11/7/2018	FT-FY19-102018-009270-A	< 1	FT-FY19-102018-009270-B	< 1
WS-009271	6/4/2018	6/4/2019	1	Health Suite	In health suite 107	WF-06042018-009271	11/7/2018	FT-FY19-102018-009271-A	< 1	FT-FY19-102018-009271-B	< 1
WS-009272	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 106	WF-06042018-009272	11/7/2018	FT-FY19-102018-009272-A	< 1	FT-FY19-102018-009272-B	< 1
WS-009273	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 106	WF-10112018-009273	11/7/2018	FT-FY19-102018-009273-A	< 1	FT-FY19-102018-009273-B	< 1
WS-009274	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 104	WF-06042018-009274	11/7/2018	FT-FY19-102018-009274-A	< 1	FT-FY19-102018-009274-B	< 1
WS-009275	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 104	WF-10112018-009275	11/7/2018	FT-FY19-102018-009275-A	< 1	FT-FY19-102018-009275-B	< 1
WS-009276	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 110	WF-06042018-009276	11/7/2018	FT-FY19-102018-009276-A	< 1	FT-FY19-102018-009276-B	< 1
WS-009277	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 110	WF-10112018-009277	11/7/2018	FT-FY19-102018-009277-A	< 1	FT-FY19-102018-009277-B	< 1
WS-009278	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 118	WF-06042018-009278	11/7/2018	FT-FY19-102018-009278-A	< 1	FT-FY19-102018-009278-B	< 1
WS-009280	10/11/2018	10/11/2019	1	Classroom Faucet	In classroom 120	WF-10112018-009280	11/7/2018	FT-FY19-102018-009280-A	< 1	FT-FY19-102018-009280-B	< 1
WS-009281	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 123	WF-06042018-009281	11/7/2018	FT-FY19-102018-009281-A	< 1	FT-FY19-102018-009281-B	< 1
WS-009282	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 123	WF-10112018-009282	11/7/2018	FT-FY19-102018-009282-A	< 1	FT-FY19-102018-009282-B	< 1
WS-009283	6/4/2018	6/4/2019	1	Cooler	In hallway adjacent to room 127	WF-06042018-009283	11/7/2018	FT-FY19-102018-009283-A	< 1	FT-FY19-102018-009283-B	< 1
WS-009284	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 128	WF-06042018-009284	11/7/2018	FT-FY19-102018-009284-A	< 1	FT-FY19-102018-009284-B	< 1
WS-009285	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 128	WF-10112018-009285	11/7/2018	FT-FY19-102018-009285-A	< 1	FT-FY19-102018-009285-B	< 1
WS-009286	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 130	WF-06042018-009286	11/7/2018	FT-FY19-102018-009286-A	< 1	FT-FY19-102018-009286-B	< 1
WS-009287	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 130	WF-10112018-009287	11/7/2018	FT-FY19-102018-009287-A	< 1	FT-FY19-102018-009287-B	< 1
WS-009288	6/4/2018	6/4/2019	1	Combo Fountain	In classroom 132	WF-06042018-009288	11/7/2018	FT-FY19-102018-009288-A	< 1	FT-FY19-102018-009288-B	< 1
WS-009289	10/11/2018	10/11/2019	1	Combo Faucet	In classroom 132	WF-10112018-009289	11/7/2018	FT-FY19-102018-009289-A	< 1	FT-FY19-102018-009289-B	< 1
WS-009290	6/4/2018	6/4/2019	2	Cooler	In hallway adjacent to staff lounge 230	WF-06042018-009290	11/7/2018	FT-FY19-102018-009290-A	< 1	FT-FY19-102018-009290-B	< 1
WS-009291	6/4/2018	6/4/2019	2	Break Room	In staff lounge 230	WF-06042018-009291	11/7/2018	FT-FY19-102018-009291-A	< 1	FT-FY19-102018-009291-B	< 1
WS-009297	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 214 High Left	WF-06042018-009297	11/7/2018	FT-FY19-102018-009297-A	< 1	FT-FY19-102018-009297-B	< 1

WS- 009298	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 214	Low Right	WF-06042018-009298	11/7/2018	FT-FY19-102018-009298-A	< 1	FT-FY19-102018-009298-B	< 1
------------	----------	----------	---	--------	---------------------------------	-----------	--------------------	-----------	-------------------------	-----	-------------------------	-----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009263	Basement	Food Prep Sink	In kitchen room 011			Left	11/7/2018	FT-FY19-102018-009263-A	< 1	FT-FY19-102018-009263-B	< 1	