



# North Michigan Park Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011556	3/28/2024	3/28/2025	1	Cooler	In hallway adjacent to women's restroom Low Left	WF-03282024-011556	4/18/2024	FT-FY24-04022024-011556-A	<1	FT-FY24-04022024-011556-B	<1
WS-011557	3/28/2024	3/28/2025	1	Cooler	In hallway adjacent to women's restroom High Right	WF-03282024-011557	4/18/2024	FT-FY24-04022024-011557-A	<1	FT-FY24-04022024-011557-B	<1
WS-011559	3/28/2024	3/28/2025	1	Cooler	In hallway adjacent to men's restroom Low Right	WF-03282024-011559	4/18/2024	FT-FY24-04022024-011559-A	<1	FT-FY24-04022024-011559-B	2.8
WS-011560	12/11/2023	12/11/2024	1	Food Prep Sink	In kitchenette 107 within activity room 108	WF-12112023-011560	4/18/2024	FT-FY24-04022024-011560-A	<1	FT-FY24-04022024-011560-B	<1
WS-011561	12/11/2023	12/11/2024	1	Food Prep Sink	In main kitchen within the community room	WF-12112023-011561	4/18/2024	FT-FY24-04022024-011561-A	<1	FT-FY24-04022024-011561-B	<1

## FY24 Filter Test

Greater than 5ppb - Devices requiring remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011558	3/28/2024	3/28/2025	1	Cooler	In hallway adjacent to men's restroom High Left	WF-03282024-011558	4/18/2024	FT-FY24-04022024-011558-A	<1	FT-FY24-04022024-011558-B	11.5

## First Re-test (After Plumbing Check)

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011558	4/24/2024	4/24/2025	1	Cooler	In hallway adjacent to men's restroom High Left	WF-04242024-011558	5/8/2024	FT-FY24-04242024-011558-A	<1	FT-FY24-04242024-011558-B	<1