



Northwest One/RH Terrell RC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006160	11/18/2021	11/18/2022	1	Cooler	In lobby across from elevator	High	Left	WF-11182021-006160	3/2/2022	FT-FY22-02092022-006160-A	<1	FT-FY22-02092022-006160-B	<1
WS- 006161	11/18/2021	11/18/2022	1	Cooler	In lobby across from elevator	Low	Right	WF-11182021-006161	3/2/2022	FT-FY22-02092022-006161-A	<1	FT-FY22-02092022-006161-B	<1