



Noyes Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004054	4/14/2021	4/14/2022	1	Health Suite	In health suite 103	WF-04142021-004054	1/4/2022	FT-FY22-12012021-004054-A	<1	FT-FY22-12012021-004054-B	<1	
WS-004059	4/14/2021	4/14/2022	1	Break Room	In staff lounge 106	WF-04142021-004059	1/4/2022	FT-FY22-12012021-004059-A	<1	FT-FY22-12012021-004059-B	<1	
WS-004061	4/14/2021	4/14/2022	1	Cooler	In hallway across from room 108	Low Left	WF-04142021-004061	1/4/2022	FT-FY22-12012021-004061-A	<1	FT-FY22-12012021-004061-B	<1
WS-004062	4/14/2021	4/14/2022	1	Cooler	In hallway across from room 108	High Right	WF-04142021-004062	1/4/2022	FT-FY22-12012021-004062-A	<1	FT-FY22-12012021-004062-B	<1
WS-004070	4/14/2021	4/14/2022	1	Break Room	In staff lounge 115	Left	WF-04142021-004070	1/4/2022	FT-FY22-12012021-004070-A	<1	FT-FY22-12012021-004070-B	<1
WS-004072	4/14/2021	4/14/2022	1	Break Room	In staff lounge 115	Right	WF-04142021-004072	1/4/2022	FT-FY22-12012021-004072-A	<1	FT-FY22-12012021-004072-B	<1
WS-004074	4/14/2021	4/14/2022	1	Cooler	In hallway across from room 121	Low Left	WF-04142021-004074	1/4/2022	FT-FY22-12012021-004074-A	<1	FT-FY22-12012021-004074-B	<1
WS-004075	4/14/2021	4/14/2022	1	Cooler	In hallway across from room 121	High Right	WF-04142021-004075	1/4/2022	FT-FY22-12012021-004075-A	<1	FT-FY22-12012021-004075-B	<1
WS-004079	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 112	Left	WF-09212021-004079	1/4/2022	FT-FY22-12012021-004079-A	<1	FT-FY22-12012021-004079-B	<1
WS-004080	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 112	Right	WF-04142021-004080	1/4/2022	FT-FY22-12012021-004080-A	<1	FT-FY22-12012021-004080-B	<1
WS-004081	4/14/2021	4/14/2022	1	Cooler	In hallway adjacent to room 116	Low Left	WF-04142021-004081	1/4/2022	FT-FY22-12012021-004081-A	<1	FT-FY22-12012021-004081-B	<1
WS-004082	4/14/2021	4/14/2022	1	Cooler	In hallway adjacent to room 116	High Right	WF-04142021-004082	1/4/2022	FT-FY22-12012021-004082-A	<1	FT-FY22-12012021-004082-B	<1
WS-004083	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 128		WF-09212021-004083	1/4/2022	FT-FY22-12012021-004083-A	<1	FT-FY22-12012021-004083-B	<1
WS-004084	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 128		WF-04142021-004084	1/4/2022	FT-FY22-12012021-004084-A	<1	FT-FY22-12012021-004084-B	<1
WS-004085	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 130		WF-09212021-004085	1/4/2022	FT-FY22-12012021-004085-A	<1	FT-FY22-12012021-004085-B	<1
WS-004086	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 130		WF-04142021-004086	1/4/2022	FT-FY22-12012021-004086-A	<1	FT-FY22-12012021-004086-B	<1
WS-004087	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 129		WF-09212021-004087	1/4/2022	FT-FY22-12012021-004087-A	<1	FT-FY22-12012021-004087-B	<1
WS-004089	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 131		WF-09212021-004089	1/4/2022	FT-FY22-12012021-004089-A	<1	FT-FY22-12012021-004089-B	<1
WS-004090	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 131		WF-04142021-004090	1/4/2022	FT-FY22-12012021-004090-A	<1	FT-FY22-12012021-004090-B	<1
WS-004091	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 135		WF-09212021-004091	1/4/2022	FT-FY22-12012021-004091-A	<1	FT-FY22-12012021-004091-B	<1
WS-004092	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 135		WF-04142021-004092	1/4/2022	FT-FY22-12012021-004092-A	<1	FT-FY22-12012021-004092-B	<1
WS-004093	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 132		WF-09212021-004093	1/4/2022	FT-FY22-12012021-004093-A	<1	FT-FY22-12012021-004093-B	<1
WS-004094	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 132		WF-04142021-004094	1/4/2022	FT-FY22-12012021-004094-A	<1	FT-FY22-12012021-004094-B	<1
WS-004095	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 133		WF-09212021-004095	1/4/2022	FT-FY22-12012021-004095-A	<1	FT-FY22-12012021-004095-B	<1
WS-004096	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 133		WF-04142021-004096	1/4/2022	FT-FY22-12012021-004096-A	<1	FT-FY22-12012021-004096-B	<1
WS-004097	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 134		WF-09212021-004097	1/4/2022	FT-FY22-12012021-004097-A	<1	FT-FY22-12012021-004097-B	<1
WS-004098	4/14/2021	4/14/2022	1	Combo Fountain	In classroom 134		WF-04142021-004098	1/4/2022	FT-FY22-12012021-004098-A	<1	FT-FY22-12012021-004098-B	<1
WS-004099	4/14/2021	4/14/2022	2	Cooler	In hallway adjacent to room 202	High Right	WF-04142021-004099	1/4/2022	FT-FY22-12012021-004099-A	<1	FT-FY22-12012021-004099-B	<1
WS-004100	4/14/2021	4/14/2022	2	Cooler	In hallway adjacent to room 202	Low Left	WF-04142021-004100	1/4/2022	FT-FY22-12012021-004100-A	<1	FT-FY22-12012021-004100-B	<1
WS-004101	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 203		WF-04142021-004101	1/4/2022	FT-FY22-12012021-004101-A	<1	FT-FY22-12012021-004101-B	<1
WS-004102	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 203		WF-09212021-004102	1/4/2022	FT-FY22-12012021-004102-A	<1	FT-FY22-12012021-004102-B	<1
WS-004103	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 205		WF-09212021-004103	1/4/2022	FT-FY22-12012021-004103-A	<1	FT-FY22-12012021-004103-B	<1
WS-004104	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 205		WF-04142021-004104	1/4/2022	FT-FY22-12012021-004104-A	<1	FT-FY22-12012021-004104-B	<1
WS-004105	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 204		WF-09212021-004105	1/4/2022	FT-FY22-12012021-004105-A	<1	FT-FY22-12012021-004105-B	<1
WS-004106	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 204		WF-04142021-004106	1/4/2022	FT-FY22-12012021-004106-A	<1	FT-FY22-12012021-004106-B	<1

WS-004107	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 206		WF-04142021-004107	1/4/2022	FT-FY22-12012021-004107-A	<1	FT-FY22-12012021-004107-B	<1
WS-004108	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 206		WF-09212021-004108	1/4/2022	FT-FY22-12012021-004108-A	<1	FT-FY22-12012021-004108-B	<1
WS-004111	4/14/2021	4/14/2022	2	Cooler	In hallway adjacent to stairwell A	Low Left	WF-04142021-004111	1/4/2022	FT-FY22-12012021-004111-A	<1	FT-FY22-12012021-004111-B	<1
WS-004112	4/14/2021	4/14/2022	2	Cooler	In hallway adjacent to stairwell A	High Right	WF-04142021-004112	1/4/2022	FT-FY22-12012021-004112-A	<1	FT-FY22-12012021-004112-B	<1
WS-004113	9/21/2021	9/21/2022	2	Combo Faucet	In speech room 212		WF-09212021-004113	1/4/2022	FT-FY22-12012021-004113-A	<1	FT-FY22-12012021-004113-B	<1
WS-004114	4/14/2021	4/14/2022	2	Combo Fountain	In speech room 212		WF-04142021-004114	1/4/2022	FT-FY22-12012021-004114-A	<1	FT-FY22-12012021-004114-B	<1
WS-004115	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 213		WF-09212021-004115	1/4/2022	FT-FY22-12012021-004115-A	<1	FT-FY22-12012021-004115-B	<1
WS-004116	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 213		WF-04142021-004116	1/4/2022	FT-FY22-12012021-004116-A	<1	FT-FY22-12012021-004116-B	<1
WS-004117	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 214		WF-09212021-004117	1/4/2022	FT-FY22-12012021-004117-A	<1	FT-FY22-12012021-004117-B	<1
WS-004118	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 214		WF-04142021-004118	1/4/2022	FT-FY22-12012021-004118-A	<1	FT-FY22-12012021-004118-B	<1
WS-004119	9/21/2021	9/21/2022	2	Combo Faucet	In classroom 216		WF-09212021-004119	1/4/2022	FT-FY22-12012021-004119-A	<1	FT-FY22-12012021-004119-B	<1
WS-004120	4/14/2021	4/14/2022	2	Combo Fountain	In classroom 216		WF-04142021-004120	1/4/2022	FT-FY22-12012021-004120-A	<1	FT-FY22-12012021-004120-B	<1
WS-004121	4/14/2021	4/14/2022	2	Break Room	In break room 220		WF-04142021-004121	1/4/2022	FT-FY22-12012021-004121-A	<1	FT-FY22-12012021-004121-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004077	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen	Left	WF-01182021-004077	1/4/2022	FT-FY22-12012021-004077-A	<1	FT-FY22-12012021-004077-B	<1
WS-004078	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen	Right	WF-01182021-004078	1/4/2022	FT-FY22-12012021-004078-A	<1	FT-FY22-12012021-004078-B	<1