



Noyes Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004054	4/7/2022	4/7/2023	1	Health Suite	In health suite 103	WF-04072022-004054	12/16/2022	FT-FY23-11182022-004054-A	<1	FT-FY23-11182022-004054-B	<1	
WS- 004059	4/7/2022	4/7/2023	1	Break Room	In staff lounge 106	WF-04072022-004059	12/16/2022	FT-FY23-11182022-004059-A	1.0	FT-FY23-11182022-004059-B	<1	
WS- 004061	4/7/2022	4/7/2023	1	Cooler	In hallway across from room 108	Low Left	WF-04072022-004061	12/16/2022	FT-FY23-11182022-004061-A	<1	FT-FY23-11182022-004061-B	<1
WS- 004062	4/7/2022	4/7/2023	1	Cooler	In hallway across from room 108	High Right	WF-04072022-004062	12/16/2022	FT-FY23-11182022-004062-A	<1	FT-FY23-11182022-004062-B	<1
WS- 004070	4/7/2022	4/7/2023	1	Break Room	In staff lounge 115	Left	WF-04072022-004070	12/16/2022	FT-FY23-11182022-004070-A	<1	FT-FY23-11182022-004070-B	<1
WS- 004072	4/7/2022	4/7/2023	1	Break Room	In staff lounge 115	Right	WF-04072022-004072	12/16/2022	FT-FY23-11182022-004072-A	<1	FT-FY23-11182022-004072-B	<1
WS- 004074	4/7/2022	4/7/2023	1	Cooler	In hallway across from room 121	Low Left	WF-04072022-004074	12/16/2022	FT-FY23-11182022-004074-A	<1	FT-FY23-11182022-004074-B	<1
WS- 004075	4/7/2022	4/7/2023	1	Cooler	In hallway across from room 121	High Right	WF-04072022-004075	12/16/2022	FT-FY23-11182022-004075-A	<1	FT-FY23-11182022-004075-B	<1
WS- 004079	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 112	Left	WF-09142022-004079	12/16/2022	FT-FY23-11182022-004079-A	<1	FT-FY23-11182022-004079-B	<1
WS- 004080	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 112	Right	WF-04072022-004080	12/16/2022	FT-FY23-11182022-004080-A	<1	FT-FY23-11182022-004080-B	<1
WS- 004081	4/7/2022	4/7/2023	1	Cooler	In hallway adjacent to room 116	Low Left	WF-04072022-004081	12/16/2022	FT-FY23-11182022-004081-A	<1	FT-FY23-11182022-004081-B	<1
WS- 004082	4/7/2022	4/7/2023	1	Cooler	In hallway adjacent to room 116	High Right	WF-04072022-004082	12/16/2022	FT-FY23-11182022-004082-A	<1	FT-FY23-11182022-004082-B	<1
WS- 004083	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 128		WF-09142022-004083	12/16/2022	FT-FY23-11182022-004083-A	<1	FT-FY23-11182022-004083-B	<1
WS- 004084	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 128		WF-04072022-004084	12/16/2022	FT-FY23-11182022-004084-A	<1	FT-FY23-11182022-004084-B	<1
WS- 004085	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 130		WF-09142022-004085	12/16/2022	FT-FY23-11182022-004085-A	2.2	FT-FY23-11182022-004085-B	<1
WS- 004086	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 130		WF-04072022-004086	12/16/2022	FT-FY23-11182022-004086-A	<1	FT-FY23-11182022-004086-B	<1
WS- 004087	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 129		WF-09142022-004087	12/16/2022	FT-FY23-11182022-004087-A	<1	FT-FY23-11182022-004087-B	<1
WS- 004088	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 129		WF-04072022-004088	12/16/2022	FT-FY23-11182022-004088-A	<1	FT-FY23-11182022-004088-B	<1
WS- 004089	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 131		WF-09142022-004089	12/16/2022	FT-FY23-11182022-004089-A	<1	FT-FY23-11182022-004089-B	<1
WS- 004090	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 131		WF-04072022-004090	12/16/2022	FT-FY23-11182022-004090-A	<1	FT-FY23-11182022-004090-B	<1
WS- 004091	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 135		WF-09142022-004091	12/16/2022	FT-FY23-11182022-004091-A	<1	FT-FY23-11182022-004091-B	<1
WS- 004092	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 135		WF-04072022-004092	12/16/2022	FT-FY23-11182022-004092-A	<1	FT-FY23-11182022-004092-B	<1
WS- 004093	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 132		WF-09142022-004093	12/16/2022	FT-FY23-11182022-004093-A	2.2	FT-FY23-11182022-004093-B	<1
WS- 004094	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 132		WF-04072022-004094	12/16/2022	FT-FY23-11182022-004094-A	<1	FT-FY23-11182022-004094-B	<1
WS- 004095	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 133		WF-09142022-004095	12/16/2022	FT-FY23-11182022-004095-A	<1	FT-FY23-11182022-004095-B	<1
WS- 004096	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 133		WF-04072022-004096	12/16/2022	FT-FY23-11182022-004096-A	<1	FT-FY23-11182022-004096-B	<1
WS- 004097	9/14/2022	9/14/2023	1	Combo Faucet	In classroom 134		WF-09142022-004097	12/16/2022	FT-FY23-11182022-004097-A	1.0	FT-FY23-11182022-004097-B	<1
WS- 004098	4/7/2022	4/7/2023	1	Combo Fountain	In classroom 134		WF-04072022-004098	12/16/2022	FT-FY23-11182022-004098-A	<1	FT-FY23-11182022-004098-B	<1
WS- 004099	4/7/2022	4/7/2023	2	Cooler	In hallway adjacent to room 202	High Right	WF-04072022-004099	12/16/2022	FT-FY23-11182022-004099-A	<1	FT-FY23-11182022-004099-B	<1
WS- 004100	4/7/2022	4/7/2023	2	Cooler	In hallway adjacent to room 202	Low Left	WF-04072022-004100	12/16/2022	FT-FY23-11182022-004100-A	<1	FT-FY23-11182022-004100-B	<1
WS- 004101	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 203		WF-04072022-004101	12/16/2022	FT-FY23-11182022-004101-A	<1	FT-FY23-11182022-004101-B	<1
WS- 004102	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 203		WF-09142022-004102	12/16/2022	FT-FY23-11182022-004102-A	<1	FT-FY23-11182022-004102-B	<1
WS- 004103	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 205		WF-09142022-004103	12/16/2022	FT-FY23-11182022-004103-A	2.0	FT-FY23-11182022-004103-B	<1
WS- 004104	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 205		WF-04072022-004104	12/16/2022	FT-FY23-11182022-004104-A	<1	FT-FY23-11182022-004104-B	<1
WS- 004105	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 204		WF-09142022-004105	12/16/2022	FT-FY23-11182022-004105-A	<1	FT-FY23-11182022-004105-B	<1

WS- 004106	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 204		WF-04072022-004106	12/16/2022	FT-FY23-11182022-004106-A	2.2	FT-FY23-11182022-004106-B	<1
WS- 004107	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 206		WF-04072022-004107	12/16/2022	FT-FY23-11182022-004107-A	<1	FT-FY23-11182022-004107-B	<1
WS- 004108	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 206		WF-09142022-004108	12/16/2022	FT-FY23-11182022-004108-A	4.3	FT-FY23-11182022-004108-B	<1
WS- 004111	4/7/2022	4/7/2023	2	Cooler	In hallway adjacent to stairwell A	Low Left	WF-04072022-004111	12/16/2022	FT-FY23-11182022-004111-A	<1	FT-FY23-11182022-004111-B	<1
WS- 004112	4/7/2022	4/7/2023	2	Cooler	In hallway adjacent to stairwell A	High Right	WF-04072022-004112	12/16/2022	FT-FY23-11182022-004112-A	<1	FT-FY23-11182022-004112-B	<1
WS- 004113	9/14/2022	9/14/2023	2	Combo Faucet	In speech room 212		WF-09142022-004113	12/16/2022	FT-FY23-11182022-004113-A	<1	FT-FY23-11182022-004113-B	<1
WS- 004114	4/7/2022	4/7/2023	2	Combo Fountain	In speech room 212		WF-04072022-004114	12/16/2022	FT-FY23-11182022-004114-A	<1	FT-FY23-11182022-004114-B	<1
WS- 004115	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 213		WF-09142022-004115	12/16/2022	FT-FY23-11182022-004115-A	3.4	FT-FY23-11182022-004115-B	<1
WS- 004116	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 213		WF-04072022-004116	12/16/2022	FT-FY23-11182022-004116-A	<1	FT-FY23-11182022-004116-B	<1
WS- 004117	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 214		WF-09142022-004117	12/16/2022	FT-FY23-11182022-004117-A	2.5	FT-FY23-11182022-004117-B	<1
WS- 004118	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 214		WF-04072022-004118	12/16/2022	FT-FY23-11182022-004118-A	1.1	FT-FY23-11182022-004118-B	<1
WS- 004119	9/14/2022	9/14/2023	2	Combo Faucet	In classroom 216		WF-09142022-004119	12/16/2022	FT-FY23-11182022-004119-A	<1	FT-FY23-11182022-004119-B	<1
WS- 004120	4/7/2022	4/7/2023	2	Combo Fountain	In classroom 216		WF-04072022-004120	12/16/2022	FT-FY23-11182022-004120-A	<1	FT-FY23-11182022-004120-B	<1
WS- 004121	4/7/2022	4/7/2023	2	Break Room	In break room 220		WF-04072022-004121	12/16/2022	FT-FY23-11182022-004121-A	<1	FT-FY23-11182022-004121-B	<1

Food Prep Sink

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004077	1/12/2022	1/12/2023	1	Food Prep Sink	In kitchen	Left	WF-01122022-004077	12/16/2022	FT-FY23-11182022-004077-A	8.1	FT-FY23-11182022-004077-B	2.7
WS- 004078	1/12/2022	1/12/2023	1	Food Prep Sink	In kitchen	Right	WF-01122022-004078	12/16/2022	FT-FY23-11182022-004078-A	15.4	FT-FY23-11182022-004078-B	8.7