



# Noyes Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001576	3/29/2023	3/29/2024	1	Bottle Filler	In hallway across from room 108	WF-03292023-001576	12/10/2023	FT-FY24-11012023-001576-A	<1	FT-FY24-11012023-001576-B	<1	
WS- 004054	3/29/2023	3/29/2024	1	Health Suite	In health suite 103	WF-03292023-004054	12/10/2023	FT-FY24-11012023-004054-A	<1	FT-FY24-11012023-004054-B	<1	
WS- 004059	3/29/2023	3/29/2024	1	Break Room	In staff lounge 106	WF-03292023-004059	12/10/2023	FT-FY24-11012023-004059-A	<1	FT-FY24-11012023-004059-B	<1	
WS- 004061	3/29/2023	3/29/2024	1	Cooler	In hallway across from room 108	Low Left	WF-03292023-004061	12/10/2023	FT-FY24-11012023-004061-A	4.0	FT-FY24-11012023-004061-B	<1
WS- 004062	3/29/2023	3/29/2024	1	Cooler	In hallway across from room 108	High Right	WF-03292023-004062	12/10/2023	FT-FY24-11012023-004062-A	<1	FT-FY24-11012023-004062-B	<1
WS- 004070	3/29/2023	3/29/2024	1	Break Room	In staff lounge 115	Left	WF-03292023-004070	12/10/2023	FT-FY24-11012023-004070-A	<1	FT-FY24-11012023-004070-B	<1
WS- 004072	3/29/2023	3/29/2024	1	Break Room	In staff lounge 115	Right	WF-03292023-004072	12/10/2023	FT-FY24-11012023-004072-A	<1	FT-FY24-11012023-004072-B	<1
WS- 004074	3/29/2023	3/29/2024	1	Cooler	In hallway across from room 121	Low Left	WF-03292023-004074	12/10/2023	FT-FY24-11012023-004074-A	<1	FT-FY24-11012023-004074-B	<1
WS- 004075	3/29/2023	3/29/2024	1	Cooler	In hallway across from room 121	High Right	WF-03292023-004075	12/10/2023	FT-FY24-11012023-004075-A	<1	FT-FY24-11012023-004075-B	<1
WS- 004080	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 112	Right	WF-03292023-004080	12/10/2023	FT-FY24-11012023-004080-A	<1	FT-FY24-11012023-004080-B	<1
WS- 004081	3/29/2023	3/29/2024	1	Cooler	In hallway adjacent to room 116	Low Left	WF-03292023-004081	12/10/2023	FT-FY24-11012023-004081-A	<1	FT-FY24-11012023-004081-B	<1
WS- 004082	3/29/2023	3/29/2024	1	Cooler	In hallway adjacent to room 116	High Right	WF-03292023-004082	12/10/2023	FT-FY24-11012023-004082-A	<1	FT-FY24-11012023-004082-B	<1
WS- 004083	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 128		WF-09072023-004083	12/10/2023	FT-FY24-11012023-004083-A	<1	FT-FY24-11012023-004083-B	<1
WS- 004084	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 128		WF-03292023-004084	12/10/2023	FT-FY24-11012023-004084-A	<1	FT-FY24-11012023-004084-B	<1
WS- 004085	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 130		WF-09072023-004085	12/10/2023	FT-FY24-11012023-004085-A	<1	FT-FY24-11012023-004085-B	<1
WS- 004086	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 130		WF-03292023-004086	12/10/2023	FT-FY24-11012023-004086-A	<1	FT-FY24-11012023-004086-B	<1
WS- 004087	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 129		WF-09072023-004087	12/10/2023	FT-FY24-11012023-004087-A	<1	FT-FY24-11012023-004087-B	<1
WS- 004088	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 129		WF-03292023-004088	12/10/2023	FT-FY24-11012023-004088-A	<1	FT-FY24-11012023-004088-B	<1
WS- 004089	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 131		WF-09072023-004089	12/10/2023	FT-FY24-11012023-004089-A	<1	FT-FY24-11012023-004089-B	<1
WS- 004090	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 131		WF-03292023-004090	12/10/2023	FT-FY24-11012023-004090-A	<1	FT-FY24-11012023-004090-B	<1
WS- 004091	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 135		WF-09072023-004091	12/10/2023	FT-FY24-11012023-004091-A	<1	FT-FY24-11012023-004091-B	<1
WS- 004092	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 135		WF-03292023-004092	12/10/2023	FT-FY24-11012023-004092-A	<1	FT-FY24-11012023-004092-B	1.7
WS- 004093	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 132		WF-09072023-004093	12/10/2023	FT-FY24-11012023-004093-A	<1	FT-FY24-11012023-004093-B	<1
WS- 004094	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 132		WF-03292023-004094	12/10/2023	FT-FY24-11012023-004094-A	<1	FT-FY24-11012023-004094-B	<1
WS- 004095	9/26/2023	9/26/2024	1	Combo Faucet	In classroom 133		WF-09262023-004095	12/10/2023	FT-FY24-11012023-004095-A	<1	FT-FY24-11012023-004095-B	<1
WS- 004096	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 133		WF-03292023-004096	12/10/2023	FT-FY24-11012023-004096-A	<1	FT-FY24-11012023-004096-B	<1
WS- 004097	9/7/2023	9/7/2024	1	Combo Faucet	In classroom 134		WF-09072023-004097	12/10/2023	FT-FY24-11012023-004097-A	<1	FT-FY24-11012023-004097-B	<1
WS- 004098	3/29/2023	3/29/2024	1	Combo Fountain	In classroom 134		WF-03292023-004098	12/10/2023	FT-FY24-11012023-004098-A	<1	FT-FY24-11012023-004098-B	<1
WS- 004099	3/29/2023	3/29/2024	2	Cooler	In hallway adjacent to room 202	High Right	WF-03292023-004099	12/10/2023	FT-FY24-11012023-004099-A	<1	FT-FY24-11012023-004099-B	<1
WS- 004101	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 203		WF-03292023-004101	12/10/2023	FT-FY24-11012023-004101-A	<1	FT-FY24-11012023-004101-B	<1
WS- 004102	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 203		WF-09072023-004102	12/10/2023	FT-FY24-11012023-004102-A	<1	FT-FY24-11012023-004102-B	<1
WS- 004103	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 205		WF-09072023-004103	12/10/2023	FT-FY24-11012023-004103-A	<1	FT-FY24-11012023-004103-B	<1
WS- 004104	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 205		WF-03292023-004104	12/10/2023	FT-FY24-11012023-004104-A	<1	FT-FY24-11012023-004104-B	<1
WS- 004105	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 204		WF-09072023-004105	12/10/2023	FT-FY24-11012023-004105-A	1.5	FT-FY24-11012023-004105-B	1.1

WS- 004106	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 204		WF-03292023-004106	12/10/2023	FT-FY24-11012023-004106-A	<1	FT-FY24-11012023-004106-B	<1
WS- 004107	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 206		WF-03292023-004107	12/10/2023	FT-FY24-11012023-004107-A	<1	FT-FY24-11012023-004107-B	<1
WS- 004108	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 206		WF-09072023-004108	12/10/2023	FT-FY24-11012023-004108-A	<1	FT-FY24-11012023-004108-B	<1
WS- 004111	3/29/2023	3/29/2024	2	Cooler	In hallway adjacent to stairwell A	Low Left	WF-03292023-004111	12/10/2023	FT-FY24-11012023-004111-A	<1	FT-FY24-11012023-004111-B	<1
WS- 004112	3/29/2023	3/29/2024	2	Cooler	In hallway adjacent to stairwell A	High Right	WF-03292023-004112	12/10/2023	FT-FY24-11012023-004112-A	<1	FT-FY24-11012023-004112-B	<1
WS- 004115	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 213		WF-09072023-004115	12/10/2023	FT-FY24-11012023-004115-A	<1	FT-FY24-11012023-004115-B	<1
WS- 004116	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 213		WF-03292023-004116	12/10/2023	FT-FY24-11012023-004116-A	<1	FT-FY24-11012023-004116-B	<1
WS- 004117	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 214		WF-09072023-004117	12/10/2023	FT-FY24-11012023-004117-A	<1	FT-FY24-11012023-004117-B	<1
WS- 004118	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 214		WF-03292023-004118	12/10/2023	FT-FY24-11012023-004118-A	<1	FT-FY24-11012023-004118-B	<1
WS- 004119	9/7/2023	9/7/2024	2	Combo Faucet	In classroom 216		WF-09072023-004119	12/10/2023	FT-FY24-11012023-004119-A	<1	FT-FY24-11012023-004119-B	<1
WS- 004120	3/29/2023	3/29/2024	2	Combo Fountain	In classroom 216		WF-03292023-004120	12/10/2023	FT-FY24-11012023-004120-A	<1	FT-FY24-11012023-004120-B	<1
WS- 004121	3/29/2023	3/29/2024	2	Break Room	In break room 220		WF-03292023-004121	12/10/2023	FT-FY24-11012023-004121-A	<1	FT-FY24-11012023-004121-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004077	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen	Left	WF-12202022-004077	12/10/2023	FT-FY24-11012023-004077-A	<1	FT-FY24-11012023-004077-B	<1
WS- 004078	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen	Right	WF-12202022-004078	12/10/2023	FT-FY24-11012023-004078-A	<1	FT-FY24-11012023-004078-B	<1