



Noyes Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004054	5/13/2020	5/13/2021	1	Health Suite	In health suite 103	WF-05132020-004054	1/30/2021	FT-FY21-012021-004054-A	<1	FT-FY21-012021-004054-B	<1
WS- 004059	5/13/2020	5/13/2021	1	Break Room	In staff lounge 106	WF-05132020-004059	1/30/2021	FT-FY21-012021-004059-A	<1	FT-FY21-012021-004059-B	<1
WS- 004061	5/13/2020	5/13/2021	1	Cooler	In hallway across from room 108	Low Left	WF-05132020-004061	1/30/2021	FT-FY21-012021-004061-A	<1	FT-FY21-012021-004061-B
WS- 004062	5/13/2020	5/13/2021	1	Cooler	In hallway across from room 108	High Right	WF-05132020-004062	1/30/2021	FT-FY21-012021-004062-A	<1	FT-FY21-012021-004062-B
WS- 004070	5/13/2020	5/13/2021	1	Break Room	In staff lounge 115	Left	WF-05132020-004070	1/30/2021	FT-FY21-012021-004070-A	<1	FT-FY21-012021-004070-B
WS- 004072	5/13/2020	5/13/2021	1	Break Room	In staff lounge 115	Right	WF-05132020-004072	1/30/2021	FT-FY21-012021-004072-A	<1	FT-FY21-012021-004072-B
WS- 004074	5/13/2020	5/13/2021	1	Cooler	In hallway across from room 121	Low Left	WF-05132020-004074	1/30/2021	FT-FY21-012021-004074-A	<1	FT-FY21-012021-004074-B
WS- 004075	5/13/2020	5/13/2021	1	Cooler	In hallway across from room 121	High Right	WF-05132020-004075	1/30/2021	FT-FY21-012021-004075-A	<1	FT-FY21-012021-004075-B
WS- 004079	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 112	Left	WF-09292020-004079	1/30/2021	FT-FY21-012021-004079-A	1.6	FT-FY21-012021-004079-B
WS- 004080	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 112	Right	WF-05132020-004080	1/30/2021	FT-FY21-012021-004080-A	<1	FT-FY21-012021-004080-B
WS- 004081	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to room 116	Low Left	WF-05132020-004081	1/30/2021	FT-FY21-012021-004081-A	<1	FT-FY21-012021-004081-B
WS- 004082	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to room 116	High Right	WF-05132020-004082	1/30/2021	FT-FY21-012021-004082-A	<1	FT-FY21-012021-004082-B
WS- 004083	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 128		WF-09292020-004083	1/30/2021	FT-FY21-012021-004083-A	<1	FT-FY21-012021-004083-B
WS- 004084	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 128		WF-05132020-004084	1/30/2021	FT-FY21-012021-004084-A	<1	FT-FY21-012021-004084-B
WS- 004085	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 130		WF-09292020-004085	1/30/2021	FT-FY21-012021-004085-A	<1	FT-FY21-012021-004085-B
WS- 004086	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 130		WF-05132020-004086	1/30/2021	FT-FY21-012021-004086-A	<1	FT-FY21-012021-004086-B
WS- 004087	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 129		WF-09292020-004087	1/30/2021	FT-FY21-012021-004087-A	<1	FT-FY21-012021-004087-B
WS- 004088	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 129		WF-05132020-004088	1/30/2021	FT-FY21-012021-004088-A	<1	FT-FY21-012021-004088-B
WS- 004089	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 131		WF-09292020-004089	1/30/2021	FT-FY21-012021-004089-A	<1	FT-FY21-012021-004089-B
WS- 004090	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 131		WF-05132020-004090	1/30/2021	FT-FY21-012021-004090-A	<1	FT-FY21-012021-004090-B
WS- 004091	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 135		WF-09292020-004091	1/30/2021	FT-FY21-012021-004091-A	<1	FT-FY21-012021-004091-B
WS- 004092	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 135		WF-05132020-004092	1/30/2021	FT-FY21-012021-004092-A	<1	FT-FY21-012021-004092-B
WS- 004093	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 132		WF-09292020-004093	1/30/2021	FT-FY21-012021-004093-A	<1	FT-FY21-012021-004093-B
WS- 004094	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 132		WF-05132020-004094	1/30/2021	FT-FY21-012021-004094-A	<1	FT-FY21-012021-004094-B
WS- 004095	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 133		WF-09292020-004095	1/30/2021	FT-FY21-012021-004095-A	<1	FT-FY21-012021-004095-B
WS- 004096	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 133		WF-05132020-004096	1/30/2021	FT-FY21-012021-004096-A	<1	FT-FY21-012021-004096-B
WS- 004097	9/29/2020	9/29/2021	1	Combo Faucet	In classroom 134		WF-09292020-004097	1/30/2021	FT-FY21-012021-004097-A	<1	FT-FY21-012021-004097-B
WS- 004098	5/13/2020	5/13/2021	1	Combo Fountain	In classroom 134		WF-05132020-004098	1/30/2021	FT-FY21-012021-004098-A	<1	FT-FY21-012021-004098-B
WS- 004099	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to room 202	High Right	WF-05132020-004099	1/30/2021	FT-FY21-012021-004099-A	<1	FT-FY21-012021-004099-B
WS- 004100	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to room 202	Low Left	WF-05132020-004100	1/30/2021	FT-FY21-012021-004100-A	<1	FT-FY21-012021-004100-B
WS- 004101	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 203		WF-05132020-004101	1/30/2021	FT-FY21-012021-004101-A	<1	FT-FY21-012021-004101-B
WS- 004102	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 203		WF-09292020-004102	1/30/2021	FT-FY21-012021-004102-A	<1	FT-FY21-012021-004102-B
WS- 004103	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 205		WF-09292020-004103	1/30/2021	FT-FY21-012021-004103-A	<1	FT-FY21-012021-004103-B

WS- 004104	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 205		WF-05132020-004104	1/30/2021	FT-FY21-012021-004104-A	<1	FT-FY21-012021-004104-B	<1
WS- 004105	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 204		WF-09292020-004105	1/30/2021	FT-FY21-012021-004105-A	<1	FT-FY21-012021-004105-B	<1
WS- 004106	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 204		WF-05132020-004106	1/30/2021	FT-FY21-012021-004106-A	<1	FT-FY21-012021-004106-B	<1
WS- 004107	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 206		WF-05132020-004107	1/30/2021	FT-FY21-012021-004107-A	<1	FT-FY21-012021-004107-B	<1
WS- 004108	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 206		WF-09292020-004108	1/30/2021	FT-FY21-012021-004108-A	<1	FT-FY21-012021-004108-B	<1
WS- 004111	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to stairwell A	Low Left	WF-05132020-004111	1/30/2021	FT-FY21-012021-004111-A	<1	FT-FY21-012021-004111-B	<1
WS- 004112	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to stairwell A	High Right	WF-05132020-004112	1/30/2021	FT-FY21-012021-004112-A	<1	FT-FY21-012021-004112-B	<1
WS- 004113	9/29/2020	9/29/2021	2	Combo Faucet	In speech room 212		WF-09292020-004113	1/30/2021	FT-FY21-012021-004113-A	<1	FT-FY21-012021-004113-B	<1
WS- 004114	5/13/2020	5/13/2021	2	Combo Fountain	In speech room 212		WF-05132020-004114	1/30/2021	FT-FY21-012021-004114-A	<1	FT-FY21-012021-004114-B	<1
WS- 004115	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 213		WF-09292020-004115	1/30/2021	FT-FY21-012021-004115-A	<1	FT-FY21-012021-004115-B	<1
WS- 004116	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 213		WF-05132020-004116	1/30/2021	FT-FY21-012021-004116-A	<1	FT-FY21-012021-004116-B	<1
WS- 004117	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 214		WF-09292020-004117	1/30/2021	FT-FY21-012021-004117-A	<1	FT-FY21-012021-004117-B	<1
WS- 004118	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 214		WF-05132020-004118	1/30/2021	FT-FY21-012021-004118-A	<1	FT-FY21-012021-004118-B	<1
WS- 004119	9/29/2020	9/29/2021	2	Combo Faucet	In classroom 216		WF-09292020-004119	1/30/2021	FT-FY21-012021-004119-A	<1	FT-FY21-012021-004119-B	<1
WS- 004120	5/13/2020	5/13/2021	2	Combo Fountain	In classroom 216		WF-05132020-004120	1/30/2021	FT-FY21-012021-004120-A	<1	FT-FY21-012021-004120-B	<1
WS- 004121	5/13/2020	5/13/2021	2	Break Room	In break room 220		WF-05132020-004121	1/30/2021	FT-FY21-012021-004121-A	<1	FT-FY21-012021-004121-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004077	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen Left	WF-01182021-004077	1/30/2021	FT-FY21-012021-004077-A	3.0	FT-FY21-012021-004077-B	<1
WS- 004078	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen Right	WF-01182021-004078	1/30/2021	FT-FY21-012021-004078-A	<1	FT-FY21-012021-004078-B	<1