



Noyes ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004054	5/21/2019	5/21/2020	1	Health Suite	In health suite 103	WF-05212019-004054	12/9/2019	FT-FY20-112019-004054-A	<1	FT-FY20-112019-004054-B	<1	
WS- 004059	5/21/2019	5/21/2020	1	Break Room	In staff lounge 106	WF-05212019-004059	12/9/2019	FT-FY20-112019-004059-A	<1	FT-FY20-112019-004059-B	<1	
WS- 004061	5/21/2019	5/21/2020	1	Cooler	In hallway across from room 108	Low Left	WF-05212019-004061	12/9/2019	FT-FY20-112019-004061-A	<1	FT-FY20-112019-004061-B	<1
WS- 004062	5/21/2019	5/21/2020	1	Cooler	In hallway across from room 108	High Right	WF-05212019-004062	12/9/2019	FT-FY20-112019-004062-A	<1	FT-FY20-112019-004062-B	<1
WS- 004070	5/21/2019	5/21/2020	1	Break Room	In staff lounge 115	Left	WF-05212019-004070	12/9/2019	FT-FY20-112019-004070-A	<1	FT-FY20-112019-004070-B	<1
WS- 004072	5/21/2019	5/21/2020	1	Break Room	In staff lounge 115	Right	WF-05212019-004072	12/9/2019	FT-FY20-112019-004072-A	<1	FT-FY20-112019-004072-B	<1
WS- 004074	5/21/2019	5/21/2020	1	Cooler	In hallway across from room 121	Low Left	WF-05212019-004074	12/9/2019	FT-FY20-112019-004074-A	<1	FT-FY20-112019-004074-B	<1
WS- 004075	5/21/2019	5/21/2020	1	Cooler	In hallway across from room 121	High Right	WF-05212019-004075	12/9/2019	FT-FY20-112019-004075-A	<1	FT-FY20-112019-004075-B	<1
WS- 004079	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 112	Left	WF-10082019-004079	12/9/2019	FT-FY20-112019-004079-A	<1	FT-FY20-112019-004079-B	<1
WS- 004080	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 112	Right	WF-05212019-004080	12/9/2019	FT-FY20-112019-004080-A	<1	FT-FY20-112019-004080-B	<1
WS- 004081	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to room 116	Low Left	WF-05212019-004081	12/9/2019	FT-FY20-112019-004081-A	<1	FT-FY20-112019-004081-B	<1
WS- 004082	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to room 116	High Right	WF-05212019-004082	12/9/2019	FT-FY20-112019-004082-A	<1	FT-FY20-112019-004082-B	<1
WS- 004083	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 128		WF-10082019-004083	12/9/2019	FT-FY20-112019-004083-A	<1	FT-FY20-112019-004083-B	<1
WS- 004084	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 128		WF-05212019-004084	12/9/2019	FT-FY20-112019-004084-A	<1	FT-FY20-112019-004084-B	<1
WS- 004085	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 130		WF-10082019-004085	12/9/2019	FT-FY20-112019-004085-A	<1	FT-FY20-112019-004085-B	<1
WS- 004086	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 130		WF-05212019-004086	12/9/2019	FT-FY20-112019-004086-A	<1	FT-FY20-112019-004086-B	<1
WS- 004087	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 129		WF-10082019-004087	12/9/2019	FT-FY20-112019-004087-A	<1	FT-FY20-112019-004087-B	<1
WS- 004088	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 129		WF-05212019-004088	12/9/2019	FT-FY20-112019-004088-A	<1	FT-FY20-112019-004088-B	<1
WS- 004089	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 131		WF-10082019-004089	12/9/2019	FT-FY20-112019-004089-A	<1	FT-FY20-112019-004089-B	<1
WS- 004090	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 131		WF-05212019-004090	12/9/2019	FT-FY20-112019-004090-A	<1	FT-FY20-112019-004090-B	<1
WS- 004091	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 135		WF-10082019-004091	12/9/2019	FT-FY20-112019-004091-A	<1	FT-FY20-112019-004091-B	<1
WS- 004092	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 135		WF-05212019-004092	12/9/2019	FT-FY20-112019-004092-A	<1	FT-FY20-112019-004092-B	<1
WS- 004093	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 132		WF-10082019-004093	12/9/2019	FT-FY20-112019-004093-A	<1	FT-FY20-112019-004093-B	<1
WS- 004094	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 132		WF-05212019-004094	12/9/2019	FT-FY20-112019-004094-A	<1	FT-FY20-112019-004094-B	<1
WS- 004095	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 133		WF-10082019-004095	12/9/2019	FT-FY20-112019-004095-A	<1	FT-FY20-112019-004095-B	<1
WS- 004096	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 133		WF-05212019-004096	12/9/2019	FT-FY20-112019-004096-A	<1	FT-FY20-112019-004096-B	<1
WS- 004097	10/8/2019	10/8/2020	1	Combo Faucet	In classroom 134		WF-10082019-004097	12/9/2019	FT-FY20-112019-004097-A	<1	FT-FY20-112019-004097-B	<1
WS- 004098	5/21/2019	5/21/2020	1	Combo Fountain	In classroom 134		WF-05212019-004098	12/9/2019	FT-FY20-112019-004098-A	<1	FT-FY20-112019-004098-B	<1
WS- 004099	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to room 202	High Right	WF-05212019-004099	12/9/2019	FT-FY20-112019-004099-A	<1	FT-FY20-112019-004099-B	<1
WS- 004100	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to room 202	Low Left	WF-05212019-004100	12/9/2019	FT-FY20-112019-004100-A	<1	FT-FY20-112019-004100-B	<1
WS- 004101	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 203		WF-05212019-004101	12/9/2019	FT-FY20-112019-004101-A	<1	FT-FY20-112019-004101-B	<1
WS- 004102	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 203		WF-10082019-004102	12/9/2019	FT-FY20-112019-004102-A	<1	FT-FY20-112019-004102-B	<1
WS- 004103	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 205		WF-10082019-004103	12/9/2019	FT-FY20-112019-004103-A	2.2	FT-FY20-112019-004103-B	<1

WS- 004104	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 205		WF-05212019-004104	12/9/2019	FT-FY20-112019-004104-A	<1	FT-FY20-112019-004104-B	<1
WS- 004105	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 204		WF-10082019-004105	12/9/2019	FT-FY20-112019-004105-A	1.8	FT-FY20-112019-004105-B	<1
WS- 004106	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 204		WF-05212019-004106	12/9/2019	FT-FY20-112019-004106-A	<1	FT-FY20-112019-004106-B	<1
WS- 004107	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 206		WF-05212019-004107	12/9/2019	FT-FY20-112019-004107-A	<1	FT-FY20-112019-004107-B	<1
WS- 004108	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 206		WF-10082019-004108	12/9/2019	FT-FY20-112019-004108-A	1.2	FT-FY20-112019-004108-B	<1
WS- 004111	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to stairwell A	Low Left	WF-05212019-004111	12/9/2019	FT-FY20-112019-004111-A	<1	FT-FY20-112019-004111-B	<1
WS- 004112	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to stairwell A	High Right	WF-05212019-004112	12/9/2019	FT-FY20-112019-004112-A	<1	FT-FY20-112019-004112-B	<1
WS- 004113	10/8/2019	10/8/2020	2	Combo Faucet	In speech room 212		WF-10082019-004113	12/9/2019	FT-FY20-112019-004113-A	<1	FT-FY20-112019-004113-B	<1
WS- 004114	5/21/2019	5/21/2020	2	Combo Fountain	In speech room 212		WF-05212019-004114	12/9/2019	FT-FY20-112019-004114-A	<1	FT-FY20-112019-004114-B	<1
WS- 004115	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 213		WF-10082019-004115	12/9/2019	FT-FY20-112019-004115-A	<1	FT-FY20-112019-004115-B	<1
WS- 004116	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 213		WF-05212019-004116	12/9/2019	FT-FY20-112019-004116-A	<1	FT-FY20-112019-004116-B	<1
WS- 004117	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 214		WF-10082019-004117	12/9/2019	FT-FY20-112019-004117-A	1.7	FT-FY20-112019-004117-B	<1
WS- 004118	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 214		WF-05212019-004118	12/9/2019	FT-FY20-112019-004118-A	<1	FT-FY20-112019-004118-B	<1
WS- 004119	10/8/2019	10/8/2020	2	Combo Faucet	In classroom 216		WF-10082019-004119	12/9/2019	FT-FY20-112019-004119-A	<1	FT-FY20-112019-004119-B	<1
WS- 004120	5/21/2019	5/21/2020	2	Combo Fountain	In classroom 216		WF-05212019-004120	12/9/2019	FT-FY20-112019-004120-A	<1	FT-FY20-112019-004120-B	<1
WS- 004121	5/21/2019	5/21/2020	2	Break Room	In break room 220		WF-05212019-004121	12/9/2019	FT-FY20-112019-004121-A	<1	FT-FY20-112019-004121-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004077	6/24/2019	6/24/2020	1	Food Prep Sink	In kitchen Left	WF-06242019-004077	12/9/2019	FT-FY20-112019-004077-A	<1	FT-FY20-112019-004077-B	<1
WS- 004078	6/24/2019	6/24/2020	1	Food Prep Sink	In kitchen Right	WF-06242019-004078	12/9/2019	FT-FY20-112019-004078-A	<1	FT-FY20-112019-004078-B	<1