



NOYES LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
1	NOYES EC	5/6/2016	WS-004121	Break Room	2	In teacher's area 220	WT-042916-4138-A	< 1	WT-042916-4138-B	< 1					
2	NOYES EC	5/6/2016	WS-004120	Fountain	2	In classroom 216	WT-042916-4137-A	2.09	WT-042916-4137-B	< 1					
3	NOYES EC	5/6/2016	WS-004119	Classroom	2	In classroom 216	WT-042916-4136-A	< 1	WT-042916-4136-B	< 1					
4	NOYES EC	5/6/2016	WS-004118	Fountain	2	In classroom 214	WT-042916-4135-A	< 1	WT-042916-4135-B	< 1					
5	NOYES EC	5/6/2016	WS-004117	Classroom	2	In classroom 214	WT-042916-4134-A	< 1	WT-042916-4134-B	< 1					
6	NOYES EC	5/6/2016	WS-004116	Fountain	2	In classroom 213	WT-042916-4133-A	2.26	WT-042916-4133-B	< 1					
7	NOYES EC	5/6/2016	WS-004115	Classroom	2	In classroom 213	WT-042916-4132-A	1.21	WT-042916-4132-B	< 1					
8	NOYES EC	5/6/2016	WS-004114	Fountain	2	In speech room 212	WT-042916-4131-A	2.02	WT-042916-4131-B	2.21					
9	NOYES EC	5/6/2016	WS-004113	Classroom	2	In speech room 212	WT-042916-4130-A	3.18	WT-042916-4130-B	1.9					
10	NOYES EC	5/6/2016	WS-004112	Cooler	2	In hallway adjacent to stairwell A	WT-042916-4129-A	< 1	WT-042916-4129-B	< 1					
11	NOYES EC	5/6/2016	WS-004111	Cooler	2	In hallway adjacent stairwell A	WT-042916-4128-A	< 1	WT-042916-4128-B	< 1					
12	NOYES EC	5/6/2016	WS-004108	Classroom	2	In classroom 206	WT-042916-4125-A	< 1	WT-042916-4125-B	< 1					
13	NOYES EC	5/6/2016	WS-004107	Fountain	2	In classroom 206	WT-042916-4124-A	< 1	WT-042916-4124-B	< 1					
14	NOYES EC	5/6/2016	WS-004106	Fountain	2	In classroom 204	WT-042916-4123-A	< 1	WT-042916-4123-B	< 1					
15	NOYES EC	5/6/2016	WS-004105	Classroom	2	In classroom 204	WT-042916-4122-A	< 1	WT-042916-4122-B	< 1					
16	NOYES EC	5/6/2016	WS-004104	Fountain	2	In classroom 205	WT-042916-4121-A	< 1	WT-042916-4121-B	< 1					
17	NOYES EC	5/6/2016	WS-004103	Classroom	2	In classroom 205	WT-042916-4120-A	< 1	WT-042916-4120-B	< 1					
18	NOYES EC	5/6/2016	WS-004102	Classroom	2	In classroom 203	WT-042916-4119-A	< 1	WT-042916-4119-B	< 1					
19	NOYES EC	5/6/2016	WS-004101	Fountain	2	In classroom 203	WT-042916-4118-A	< 1	WT-042916-4118-B	< 1					
20	NOYES EC	5/6/2016	WS-004100	Cooler	2	In hallway adjacent classroom 202	WT-042916-4117-A	< 1	WT-042916-4117-B	< 1					
21	NOYES EC	5/6/2016	WS-004099	Cooler	2	In hallway adjacent classroom 202	WT-042916-4116-A	< 1	WT-042916-4116-B	< 1					
22	NOYES EC	5/6/2016	WS-004098	Fountain	1	In classroom 134	WT-042916-4115-A	< 1	WT-042916-4115-B	< 1					
23	NOYES EC	5/6/2016	WS-004097	Classroom	1	In classroom 134	WT-042916-4114-A	< 1	WT-042916-4114-B	< 1					
24	NOYES EC	5/6/2016	WS-004096	Fountain	1	In classroom 133	WT-042916-4113-A	< 1	WT-042916-4113-B	< 1					
25	NOYES EC	5/6/2016	WS-004095	Classroom	1	In classroom 133	WT-042916-4112-A	< 1	WT-042916-4112-B	< 1					
26	NOYES EC	5/6/2016	WS-004094	Fountain	1	In classroom 132	WT-042916-4111-A	< 1	WT-042916-4111-B	< 1					
27	NOYES EC	5/6/2016	WS-004093	Classroom	1	In classroom 132	WT-042916-4110-A	< 1	WT-042916-4110-B	< 1					
28	NOYES EC	5/6/2016	WS-004092	Fountain	1	In classroom 135	WT-042916-4109-A	< 1	WT-042916-4109-B	< 1					
29	NOYES EC	5/6/2016	WS-004091	Classroom	1	In classroom 135	WT-042916-4108-A	< 1	WT-042916-4108-B	< 1					
30	NOYES EC	5/6/2016	WS-004090	Fountain	1	In classroom 131	WT-042916-4107-A	< 1	WT-042916-4107-B	< 1					
31	NOYES EC	5/6/2016	WS-004089	Classroom	1	In classroom 131	WT-042916-4106-A	< 1	WT-042916-4106-B	< 1					
32	NOYES EC	5/6/2016	WS-004088	Fountain	1	In classroom 129	WT-042916-4105-A	< 1	WT-042916-4105-B	< 1					
33	NOYES EC	5/6/2016	WS-004087	Classroom	1	In classroom 129	WT-042916-4104-A	< 1	WT-042916-4104-B	< 1					
34	NOYES EC	5/6/2016	WS-004086	Fountain	1	In classroom 130	WT-042916-4103-A	< 1	WT-042916-4103-B	< 1					
35	NOYES EC	5/6/2016	WS-004085	Classroom	1	In classroom 130	WT-042916-4102-A	< 1	WT-042916-4102-B	< 1					
36	NOYES EC	5/6/2016	WS-004084	Fountain	1	In classroom 128	WT-042916-4101-A	< 1	WT-042916-4101-B	< 1					
37	NOYES EC	5/6/2016	WS-004083	Classroom	1	In classroom 128	WT-042916-4100-A	< 1	WT-042916-4100-B	< 1					
38	NOYES EC	5/6/2016	WS-004082	Cooler	1	In hallway adjacent to room 116	WT-042916-4099-A	< 1	WT-042916-4099-B	< 1					
39	NOYES EC	5/6/2016	WS-004081	Cooler	1	In hallway adjacent to room 116	WT-042916-4098-A	< 1	WT-042916-4098-B	< 1					
40	NOYES EC	5/6/2016	WS-004080	Fountain	1	In classroom 112	WT-042916-4097-A	4.4	WT-042916-4097-B	2.49					
41	NOYES EC	5/6/2016	WS-004079	Classroom	1	In classroom 112	WT-042916-4096-A	2.46	WT-042916-4096-B	2.05					
42	NOYES EC	5/6/2016	WS-004078	Kitchen	1	In kitchen	WT-042916-4095-A	< 1	WT-042916-4095-B	< 1					
43	NOYES EC	5/6/2016	WS-004077	Kitchen	1	In kitchen	WT-042916-4094-A	< 1	WT-042916-4094-B	< 1					
44	NOYES EC	5/6/2016	WS-004076	Kitchen	1	In kitchen (spray nozzle)	WT-042916-4093-A	< 1	WT-042916-4093-B	< 1					
45	NOYES EC	5/6/2016	WS-004075	Cooler	1	In hallway across from room 121	WT-042916-4092-A	< 1	WT-042916-4092-B	< 1					
46	NOYES EC	5/6/2016	WS-004074	Cooler	1	In hallway across from room 121	WT-042916-4091-A	< 1	WT-042916-4091-B	< 1					
47	NOYES EC	5/6/2016	WS-004073	Kitchen	1	In kitchen room 115 (spray nozzle)	WT-042916-4090-A	7.17	WT-042916-4090-B	2.37					
48	NOYES EC	5/6/2016	WS-004072	Kitchen	1	In kitchen room 115	WT-042916-4089-A	< 1	WT-042916-4089-B	< 1					
49	NOYES EC	5/6/2016	WS-004070	Kitchen	1	In kitchen room 115	WT-042916-4088-A	< 1	WT-042916-4088-B	< 1					
50	NOYES EC	5/6/2016	WS-004069	Classroom	1	In classroom 110	WT-042916-4086-A	1.36	WT-042916-4086-B	2.39					
51	NOYES EC	5/6/2016	WS-004068	Classroom	1	In classroom 110	WT-042916-4085-A	< 1	WT-042916-4085-B	1.51					
52	NOYES EC	5/6/2016	WS-004066	Classroom	1	In classroom 108 first from left	WT-042916-4083-A	4.8	WT-042916-4083-B	8.31					
53	NOYES EC	5/6/2016	WS-004065	Classroom	1	In classroom 108 second from left	WT-042916-4082-A	1.09	WT-042916-4082-B	13.5					
54	NOYES EC	5/6/2016	WS-004064	Classroom	1	In classroom 108 third from left	WT-042916-4081-A	2.98	WT-042916-4081-B	2.95					
55	NOYES EC	5/6/2016	WS-004063	Classroom	1	In classroom 108 fourth from left	WT-042916-4080-A	4.09	WT-042916-4080-B	3.07					
56	NOYES EC	5/6/2016	WS-004062	Cooler	1	In hallway adjacent to stair A	WT-042916-4079-A	< 1	WT-042916-4079-B	< 1					
57	NOYES EC	5/6/2016	WS-004061	Cooler	1	In hallway adjacent to stair A	WT-042916-4078-A	< 1	WT-042916-4078-B	< 1					
58	NOYES EC	5/6/2016	WS-004060	Break Room	1	In room 106 (spray nozzle)	WT-042916-4077-A	2.6	WT-042916-4077-B	< 1					
59	NOYES EC	5/6/2016	WS-004059	Classroom	1	In room 106	WT-042916-4076-A	< 1	WT-042916-4076-B	< 1					
60	NOYES EC	5/6/2016	WS-004058	Other	1	In room 100F (spray nozzle)	WT-042916-4075-A	1.24	WT-042916-4075-B	< 1					
61	NOYES EC	5/6/2016	WS-004057	Classroom	1	In room 100F	WT-042916-4074-A	< 1	WT-042916-4074-B	< 1					
62	NOYES EC	5/6/2016	WS-004056	Other	1	In room 100E (spray nozzle)	WT-042916-4073-A	< 1	WT-042916-4073-B	< 1					
63	NOYES EC	5/6/2016	WS-004055	Classroom	1	In room 100E	WT-042916-4072-A	< 1	WT-042916-4072-B	< 1					
64	NOYES EC	5/6/2016	WS-004054	Classroom	1	In room 103	WT-042916-4071-A	1.73	WT-042916-4071-B	< 1					
65	NOYES EC	5/6/2016	WS-004053	Classroom	1	In room 101	WT-042916-4070-A	160	WT-042916-4070-B	2.09	Filter will be installed and then retested				



NOYES LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
66	NOYES EC	5/6/2016	WS-004052	Utility	Basement	Main water source in room 111 in room B0001	WT-042916-4069- A	56.7	WT-042916-4069- B	9.04	Non-drinking water source - Not accessible to children			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.