



NOYES EC LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	NOYES EDUCATIONAL CAMPUS	WS- 004121	12/12/2016	2	Break Room	In break room 220	FT-102016-004121-A	< 1	FT-102016-004121-B	< 1
2	NOYES EDUCATIONAL CAMPUS	WS- 004070	12/12/2016	1	Break Room	In staff lounge 115 Left	FT-102016-004070-A	< 1	FT-102016-004070-B	< 1
3	NOYES EDUCATIONAL CAMPUS	WS- 004059	12/12/2016	1	Break Room	In staff lounge 106	FT-102016-004059-A	< 1	FT-102016-004059-B	< 1
4	NOYES EDUCATIONAL CAMPUS	WS- 004085	12/12/2016	1	Combo Faucet	In classroom 130	FT-122016-004085-A	< 1	FT-122016-004085-B	< 1
5	NOYES EDUCATIONAL CAMPUS	WS- 004115	12/12/2016	2	Combo Faucet	In classroom 213	FT-122016-004115-A	< 1	FT-122016-004115-B	< 1
6	NOYES EDUCATIONAL CAMPUS	WS- 004089	12/12/2016	1	Combo Faucet	In classroom 131	FT-122016-004089-A	< 1	FT-122016-004089-B	< 1
7	NOYES EDUCATIONAL CAMPUS	WS- 004093	12/12/2016	1	Combo Faucet	In classroom 132	FT-122016-004093-A	< 1	FT-122016-004093-B	< 1
8	NOYES EDUCATIONAL CAMPUS	WS- 004083	12/12/2016	1	Combo Faucet	In classroom 128	FT-122016-004083-A	< 1	FT-122016-004083-B	< 1
9	NOYES EDUCATIONAL CAMPUS	WS- 004079	12/12/2016	1	Combo Faucet	In classroom 112 Left	FT-122016-004079-A	< 1	FT-122016-004079-B	< 1
10	NOYES EDUCATIONAL CAMPUS	WS- 004091	12/12/2016	1	Combo Faucet	In classroom 135	FT-122016-004091-A	< 1	FT-122016-004091-B	< 1
11	NOYES EDUCATIONAL CAMPUS	WS- 004087	12/12/2016	1	Combo Faucet	In classroom 129	FT-122016-004087-A	< 1	FT-122016-004087-B	< 1
12	NOYES EDUCATIONAL CAMPUS	WS- 004103	12/12/2016	2	Combo Faucet	In classroom 205	FT-122016-004103-A	< 1	FT-122016-004103-B	< 1
13	NOYES EDUCATIONAL CAMPUS	WS- 004113	12/12/2016	2	Combo Faucet	In speech room 212	FT-122016-004113-A	< 1	FT-122016-004113-B	< 1
14	NOYES EDUCATIONAL CAMPUS	WS- 004105	12/12/2016	2	Combo Faucet	In classroom 204	FT-122016-004105-A	< 1	FT-122016-004105-B	< 1
15	NOYES EDUCATIONAL CAMPUS	WS- 004102	12/12/2016	2	Combo Faucet	In classroom 203	FT-122016-004102-A	< 1	FT-122016-004102-B	< 1
16	NOYES EDUCATIONAL CAMPUS	WS- 004095	12/12/2016	1	Combo Faucet	In classroom 133	FT-122016-004095-A	< 1	FT-122016-004095-B	< 1
17	NOYES EDUCATIONAL CAMPUS	WS- 004108	12/12/2016	2	Combo Faucet	In classroom 206	FT-122016-004108-A	< 1	FT-122016-004108-B	< 1
18	NOYES EDUCATIONAL CAMPUS	WS- 004117	12/12/2016	2	Combo Faucet	In classroom 214	FT-122016-004117-A	< 1	FT-122016-004117-B	< 1
19	NOYES EDUCATIONAL CAMPUS	WS- 004097	12/12/2016	1	Combo Faucet	In classroom 134	FT-122016-004097-A	< 1	FT-122016-004097-B	< 1
20	NOYES EDUCATIONAL CAMPUS	WS- 004119	12/12/2016	2	Combo Faucet	In classroom 216	FT-122016-004119-A	< 1	FT-122016-004119-B	< 1
21	NOYES EDUCATIONAL CAMPUS	WS- 004072	12/12/2016	1	Break Room	In staff lounge 115 Right	FT-112016-004072-A	< 1	FT-112016-004072-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb