



# Noyes ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004061	6/20/2017	6/20/2018	1	Cooler	In hallway across from room 108 Left Low	WF-62017-004061	11/28/2017	FT-FY18-62017-004061-A	<1	FT-FY18-62017-004061-B	<1
WS-004080	6/20/2017	6/20/2018	1	Combo Fountain	In classroom 112 Right	WF-62017-004080	11/28/2017	FT-FY18-62017-004080-A	<1	FT-FY18-62017-004080-B	<1
WS-004083	11/10/2017	11/10/2018	1	Combo Faucet	In classroom 128	WF-112017-004083	11/28/2017	FT-FY18-112017-004083-A	<1	FT-FY18-112017-004083-B	<1
WS-004085	11/10/2017	11/10/2018	1	Combo Faucet	In classroom 130	WF-112017-004085	11/28/2017	FT-FY18-112017-004085-A	<1	FT-FY18-112017-004085-B	<1
WS-004088	6/20/2017	6/20/2018	1	Combo Fountain	In classroom 129	WF-62017-004088	11/28/2017	FT-FY18-62017-004088-A	<1	FT-FY18-62017-004088-B	<1
WS-004091	11/10/2017	11/10/2018	1	Combo Faucet	In classroom 135	WF-112017-004091	11/28/2017	FT-FY18-112017-004091-A	<1	FT-FY18-112017-004091-B	<1
WS-004096	6/20/2017	6/20/2018	1	Combo Fountain	In classroom 133	WF-62017-004096	11/28/2017	FT-FY18-62017-004096-A	<1	FT-FY18-62017-004096-B	<1
WS-004100	6/20/2017	6/20/2018	2	Cooler	In hallway adjacent to room 202 Right High	WF-62017-004100	11/28/2017	FT-FY18-62017-004100-A	<1	FT-FY18-62017-004100-B	<1
WS-004104	6/20/2017	6/20/2018	2	Combo Fountain	In classroom 205	WF-62017-004104	11/28/2017	FT-FY18-62017-004104-A	<1	FT-FY18-62017-004104-B	<1
WS-004105	11/10/2017	11/10/2018	2	Combo Faucet	In classroom 204	WF-112017-004105	11/28/2017	FT-FY18-112017-004105-A	<1	FT-FY18-112017-004105-B	<1
WS-004107	6/20/2017	6/20/2018	2	Combo Fountain	In classroom 206	WF-62017-004107	11/28/2017	FT-FY18-62017-004107-A	<1	FT-FY18-62017-004107-B	<1
WS-004112	6/20/2017	6/20/2018	2	Cooler	In hallway adjacent to stairwell A Right High	WF-62017-004112	11/28/2017	FT-FY18-62017-004112-A	<1	FT-FY18-62017-004112-B	<1
WS-004114	6/20/2017	6/20/2018	2	Combo Fountain	In speech room 212	WF-62017-004114	11/28/2017	FT-FY18-62017-004114-A	<1	FT-FY18-62017-004114-B	<1
WS-004116	6/20/2017	6/20/2018	2	Combo Fountain	In classroom 213	WF-62017-004116	11/28/2017	FT-FY18-62017-004116-A	<1	FT-FY18-62017-004116-B	<1
WS-004117	11/10/2017	11/10/2018	2	Combo Faucet	In classroom 214	WF-112017-004117	11/28/2017	FT-FY18-112017-004117-A	<1	FT-FY18-112017-004117-B	<1
WS-004119	11/10/2017	11/10/2018	2	Combo Faucet	In classroom 216	WF-112017-004119	11/28/2017	FT-FY18-112017-004119-A	<1	FT-FY18-112017-004119-B	<1
WS-004121	6/20/2017	6/20/2018	2	Break Room	In break room 220	WF-62017-004121	11/28/2017	FT-FY18-62017-004121-A	<1	FT-FY18-62017-004121-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004077	1	Food Prep Sink	In kitchen Left	11/28/2017	FT-FY18-102017-004077-A	<1	FT-FY18-102017-004077-B	<1