



Noyes ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004054	5/30/2018	5/30/2019	1	Health Suite	In health suite 103	WF-05302018-004054	12/3/2018	FT-FY19-112018-004054-A	<1	FT-FY19-112018-004054-B	<1
WS- 004059	5/30/2018	5/30/2019	1	Break Room	In staff lounge 106	WF-05302018-004059	12/3/2018	FT-FY19-112018-004059-A	<1	FT-FY19-112018-004059-B	<1
WS- 004061	5/30/2018	5/30/2019	1	Cooler	In hallway across from room 108 Low Left	WF-05302018-004061	12/3/2018	FT-FY19-112018-004061-A	<1	FT-FY19-112018-004061-B	<1
WS- 004062	5/30/2018	5/30/2019	1	Cooler	In hallway across from room 108 High Right	WF-05302018-004062	12/3/2018	FT-FY19-112018-004062-A	<1	FT-FY19-112018-004062-B	<1
WS- 004070	5/30/2018	5/30/2019	1	Break Room	In staff lounge 115 Left	WF-05302018-004070	12/3/2018	FT-FY19-112018-004070-A	<1	FT-FY19-112018-004070-B	<1
WS- 004072	5/30/2018	5/30/2019	1	Break Room	In staff lounge 115 Right	WF-05302018-004072	12/3/2018	FT-FY19-112018-004072-A	<1	FT-FY19-112018-004072-B	<1
WS- 004074	5/30/2018	5/30/2019	1	Cooler	In hallway across from room 121 Low Left	WF-05302018-004074	12/3/2018	FT-FY19-112018-004074-A	<1	FT-FY19-112018-004074-B	<1
WS- 004075	5/30/2018	5/30/2019	1	Cooler	In hallway across from room 121 High Right	WF-05302018-004075	12/3/2018	FT-FY19-112018-004075-A	<1	FT-FY19-112018-004075-B	<1
WS- 004079	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 112 Left	WF-10162018-004079	12/3/2018	FT-FY19-112018-004079-A	<1	FT-FY19-112018-004079-B	1
WS- 004080	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 112 Right	WF-05302018-004080	12/3/2018	FT-FY19-112018-004080-A	<1	FT-FY19-112018-004080-B	<1
WS- 004081	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to room 116 Low Left	WF-05302018-004081	12/3/2018	FT-FY19-112018-004081-A	<1	FT-FY19-112018-004081-B	<1
WS- 004082	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to room 116 High Right	WF-05302018-004082	12/3/2018	FT-FY19-112018-004082-A	<1	FT-FY19-112018-004082-B	<1
WS- 004083	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 128	WF-10162018-004083	12/3/2018	FT-FY19-112018-004083-A	<1	FT-FY19-112018-004083-B	<1
WS- 004084	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 128	WF-05302018-004084	12/3/2018	FT-FY19-112018-004084-A	<1	FT-FY19-112018-004084-B	<1
WS- 004085	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 130	WF-10162018-004085	12/3/2018	FT-FY19-112018-004085-A	<1	FT-FY19-112018-004085-B	<1
WS- 004086	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 130	WF-05302018-004086	12/3/2018	FT-FY19-112018-004086-A	<1	FT-FY19-112018-004086-B	<1
WS- 004087	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 129	WF-10162018-004087	12/3/2018	FT-FY19-112018-004087-A	<1	FT-FY19-112018-004087-B	<1
WS- 004088	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 129	WF-05302018-004088	12/3/2018	FT-FY19-112018-004088-A	<1	FT-FY19-112018-004088-B	<1
WS- 004089	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 131	WF-10162018-004089	12/3/2018	FT-FY19-112018-004089-A	<1	FT-FY19-112018-004089-B	<1
WS- 004090	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 131	WF-05302018-004090	12/3/2018	FT-FY19-112018-004090-A	<1	FT-FY19-112018-004090-B	<1
WS- 004091	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 135	WF-10162018-004091	12/3/2018	FT-FY19-112018-004091-A	<1	FT-FY19-112018-004091-B	<1
WS- 004092	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 135	WF-05302018-004092	12/3/2018	FT-FY19-112018-004092-A	<1	FT-FY19-112018-004092-B	<1
WS- 004093	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 132	WF-10162018-004093	12/3/2018	FT-FY19-112018-004093-A	<1	FT-FY19-112018-004093-B	<1
WS- 004094	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 132	WF-05302018-004094	12/3/2018	FT-FY19-112018-004094-A	<1	FT-FY19-112018-004094-B	<1
WS- 004095	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 133	WF-10162018-004095	12/3/2018	FT-FY19-112018-004095-A	<1	FT-FY19-112018-004095-B	<1
WS- 004096	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 133	WF-05302018-004096	12/3/2018	FT-FY19-112018-004096-A	<1	FT-FY19-112018-004096-B	<1
WS- 004097	10/16/2018	10/16/2019	1	Combo Faucet	In classroom 134	WF-10162018-004097	12/3/2018	FT-FY19-112018-004097-A	<1	FT-FY19-112018-004097-B	<1
WS- 004098	5/30/2018	5/30/2019	1	Combo Fountain	In classroom 134	WF-05302018-004098	12/3/2018	FT-FY19-112018-004098-A	<1	FT-FY19-112018-004098-B	<1
WS- 004099	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to room 202 High Right	WF-05302018-004099	12/3/2018	FT-FY19-112018-004099-A	<1	FT-FY19-112018-004099-B	<1

WS- 004100	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to room 202	Low Left	WF-05302018-004100	12/3/2018	FT-FY19-112018-004100-A	<1	FT-FY19-112018-004100-B	<1
WS- 004101	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 203		WF-05302018-004101	12/3/2018	FT-FY19-112018-004101-A	<1	FT-FY19-112018-004101-B	<1
WS- 004102	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 203		WF-10162018-004102	12/3/2018	FT-FY19-112018-004102-A	<1	FT-FY19-112018-004102-B	<1
WS- 004103	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 205		WF-10162018-004103	12/3/2018	FT-FY19-112018-004103-A	<1	FT-FY19-112018-004103-B	<1
WS- 004104	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 205		WF-05302018-004104	12/3/2018	FT-FY19-112018-004104-A	<1	FT-FY19-112018-004104-B	<1
WS- 004105	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 204		WF-10162018-004105	12/3/2018	FT-FY19-112018-004105-A	<1	FT-FY19-112018-004105-B	<1
WS- 004106	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 204		WF-05302018-004106	12/3/2018	FT-FY19-112018-004106-A	<1	FT-FY19-112018-004106-B	<1
WS- 004107	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 206		WF-05302018-004107	12/3/2018	FT-FY19-112018-004107-A	<1	FT-FY19-112018-004107-B	<1
WS- 004108	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 206		WF-10162018-004108	12/3/2018	FT-FY19-112018-004108-A	<1	FT-FY19-112018-004108-B	<1
WS- 004111	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to stairwell A	Low Left	WF-05302018-004111	12/3/2018	FT-FY19-112018-004111-A	<1	FT-FY19-112018-004111-B	<1
WS- 004112	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to stairwell A	High Right	WF-05302018-004112	12/3/2018	FT-FY19-112018-004112-A	<1	FT-FY19-112018-004112-B	<1
WS- 004113	10/16/2018	10/16/2019	2	Combo Faucet	In speech room 212		WF-10162018-004113	12/3/2018	FT-FY19-112018-004113-A	<1	FT-FY19-112018-004113-B	<1
WS- 004114	5/30/2018	5/30/2019	2	Combo Fountain	In speech room 212		WF-05302018-004114	12/3/2018	FT-FY19-112018-004114-A	<1	FT-FY19-112018-004114-B	<1
WS- 004115	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 213		WF-10162018-004115	12/3/2018	FT-FY19-112018-004115-A	<1	FT-FY19-112018-004115-B	<1
WS- 004116	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 213		WF-05302018-004116	12/3/2018	FT-FY19-112018-004116-A	<1	FT-FY19-112018-004116-B	<1
WS- 004117	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 214		WF-10162018-004117	12/3/2018	FT-FY19-112018-004117-A	<1	FT-FY19-112018-004117-B	<1
WS- 004118	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 214		WF-05302018-004118	12/3/2018	FT-FY19-112018-004118-A	<1	FT-FY19-112018-004118-B	<1
WS- 004119	10/16/2018	10/16/2019	2	Combo Faucet	In classroom 216		WF-10162018-004119	12/3/2018	FT-FY19-112018-004119-A	<1	FT-FY19-112018-004119-B	<1
WS- 004120	5/30/2018	5/30/2019	2	Combo Fountain	In classroom 216		WF-05302018-004120	12/3/2018	FT-FY19-112018-004120-A	<1	FT-FY19-112018-004120-B	<1
WS- 004121	5/30/2018	5/30/2019	2	Break Room	In break room 220		WF-05302018-004121	12/3/2018	FT-FY19-112018-004121-A	<1	FT-FY19-112018-004121-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004077	1	Food Prep Sink	In kitchen Left	12/3/2018	FT-FY19-112018-004077-A	<1	FT-FY19-112018-004077-B	<1