



# Old Banneker Swing Space Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011900	4/4/2023	4/4/2024	Basement	Cooler	In cafeteria adjacent to kitchen area	WF-04042023-011900	10/13/2023	FT-FY24-09182023-011900-A	<1	FT-FY24-09182023-011900-B	<1
WS- 011929	4/4/2023	4/4/2024	1	Cooler	In hallway adjacent to room 102	WF-04042023-011929	10/13/2023	FT-FY24-09182023-011929-A	<1	FT-FY24-09182023-011929-B	<1
WS- 011940	4/4/2023	4/4/2024	1	Cooler	In hallway across from gym	WF-04042023-011940	10/13/2023	FT-FY24-09182023-011940-A	<1	FT-FY24-09182023-011940-B	<1
WS- 011961	4/4/2023	4/4/2024	1	Cooler	In hallway adjacent to guidance room 103	WF-04042023-011961	10/13/2023	FT-FY24-09182023-011961-A	<1	FT-FY24-09182023-011961-B	<1
WS- 012040	4/4/2023	4/4/2024	2	Bottle Filler	In hallway adjacent to stairwell 6	WF-04042023-012040	10/13/2023	FT-FY24-09182023-012040-A	<1	FT-FY24-09182023-012040-B	<1
WS- 012041	4/4/2023	4/4/2024	2	Cooler	In hallway adjacent to stairwell 6	WF-04042023-012041	10/13/2023	FT-FY24-09182023-012041-A	<1	FT-FY24-09182023-012041-B	<1
WS- 012043	4/4/2023	4/4/2024	2	Cooler	In hallway adjacent to stairwell 1	WF-04042023-012043	10/13/2023	FT-FY24-09182023-012043-A	<1	FT-FY24-09182023-012043-B	<1
WS- 012044	6/20/2023	6/20/2024	2	Break Room	In media center dining area 200 F	WF-06202023-012044	10/13/2023	FT-FY24-09182023-012044-A	<1	FT-FY24-09182023-012044-B	<1
WS- 012498	4/4/2023	4/4/2024	2	Cooler	In hallway across from stairwell 3	WF-04042023-012498	10/13/2023	FT-FY24-09182023-012498-A	<1	FT-FY24-09182023-012498-B	<1
WS- 012499	4/4/2023	4/4/2024	2	Cooler	In hallway across from stairwell 4	WF-04042023-012499	10/13/2023	FT-FY24-09182023-012499-A	<1	FT-FY24-09182023-012499-B	<1
WS- 012500	4/4/2023	4/4/2024	2	Break Room	In staff lounge	WF-04042023-012500	10/13/2023	FT-FY24-09182023-012500-A	<1	FT-FY24-09182023-012500-B	<1
WS- 012503	4/4/2023	4/4/2024	3	Cooler	In hallway adjacent to room 305	WF-04042023-012503	10/13/2023	FT-FY24-09182023-012503-A	<1	FT-FY24-09182023-012503-B	<1
WS- 012505	4/4/2023	4/4/2024	3	Cooler	In hallway across from stairwell 3	WF-04042023-012505	10/13/2023	FT-FY24-09182023-012505-A	<1	FT-FY24-09182023-012505-B	<1
WS- 012506	4/4/2023	4/4/2024	3	Cooler	In hallway across from stairwell 5	WF-04042023-012506	10/13/2023	FT-FY24-09182023-012506-A	<1	FT-FY24-09182023-012506-B	<1
WS- 012526	4/4/2023	4/4/2024	3	Cooler	In hallway adjacent to room 306	WF-04042023-012526	10/13/2023	FT-FY24-09182023-012526-A	<1	FT-FY24-09182023-012526-B	<1
WS- 012568	4/4/2023	4/4/2024	Basement	Cooler	In hallway adjacent to room 09A	WF-04042023-012568	10/13/2023	FT-FY24-09182023-012568-A	<1	FT-FY24-09182023-012568-B	<1
WS- 012602	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 020B	WF-04042023-012602	10/13/2023	FT-FY24-09182023-012602-A	<1	FT-FY24-09182023-012602-B	<1
WS- 012604	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 020A	WF-04042023-012604	10/13/2023	FT-FY24-09182023-012604-A	<1	FT-FY24-09182023-012604-B	<1
WS- 012606	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 023	WF-04042023-012606	10/13/2023	FT-FY24-09182023-012606-A	1.8	FT-FY24-09182023-012606-B	<1
WS- 012608	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 09A	WF-04042023-012608	10/13/2023	FT-FY24-09182023-012608-A	<1	FT-FY24-09182023-012608-B	<1
WS- 012610	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 09B	WF-04042023-012610	10/13/2023	FT-FY24-09182023-012610-A	1.1	FT-FY24-09182023-012610-B	<1
WS- 012612	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 05B	WF-04042023-012612	10/13/2023	FT-FY24-09182023-012612-A	1.7	FT-FY24-09182023-012612-B	<1
WS- 012614	4/4/2023	4/4/2024	Basement	Combo Fountain	In classroom 05A	WF-04042023-012614	10/13/2023	FT-FY24-09182023-012614-A	<1	FT-FY24-09182023-012614-B	<1
WS- 012618	4/4/2023	4/4/2024	Basement	Combo Fountain	In test kitchen 010 along wall	WF-04042023-012618	10/13/2023	FT-FY24-09182023-012618-A	<1	FT-FY24-09182023-012618-B	<1
WS- 012620	6/23/2023	6/23/2024	1	Health Suite	In health suite 112	WF-06232023-012620	10/13/2023	FT-FY24-09182023-012620-A	1.5	FT-FY24-09182023-012620-B	<1
WS- 012621	6/20/2023	6/20/2024	1	Health Suite	In health suite 112	WF-06202023-012621	10/13/2023	FT-FY24-09182023-012621-A	<1	FT-FY24-09182023-012621-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011902	12/22/2022	12/22/2023	Basement	Food Prep Sink	In kitchen first clockwise from cafeteria entry door	WF-12222022-011902	10/13/2023	FT-FY24-09182023-011902-A	<1	FT-FY24-09182023-011902-B	<1
WS- 012615	12/22/2022	12/22/2023	Basement	Food Prep Sink	In test kitchen 010 on island Left	WF-12222022-012615	10/13/2023	FT-FY24-09182023-012615-A	2.2	FT-FY24-09182023-012615-B	<1
WS- 012616	12/22/2022	12/22/2023	Basement	Food Prep Sink	In test kitchen 010 on island Right	WF-12222022-012616	10/13/2023	FT-FY24-09182023-012616-A	<1	FT-FY24-09182023-012616-B	<1
WS- 012617	12/22/2022	12/22/2023	Basement	Food Prep Sink	In test kitchen 010 along wall	WF-12222022-012617	10/13/2023	FT-FY24-09182023-012617-A	4.6	FT-FY24-09182023-012617-B	<1