



Old Banneker Swing Space Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011900	3/18/2025	3/18/2026	Basement	Cooler	In cafeteria adjacent to kitchen area	WF-03182025-011900	10/3/2025	FT-FY26-09232025-011900-A	<2	FT-FY26-09232025-011900-B	<2
WS- 011901	3/18/2025	3/18/2026	Basement	Cooler	In cafeteria across from kitchen area	WF-03182025-011901	10/3/2025	FT-FY26-09232025-011901-A	<2	FT-FY26-09232025-011901-B	<2
WS- 011907	3/18/2025	3/18/2026	Basement	Cooler	In hallway across from room 0208	WF-03182025-011907	10/3/2025	FT-FY26-09232025-011907-A	<2	FT-FY26-09232025-011907-B	<2
WS- 011908	3/18/2025	3/18/2026	Basement	Cooler	In hallway across from 009	WF-03182025-011908	10/3/2025	FT-FY26-09232025-011908-A	<2	FT-FY26-09232025-011908-B	<2
WS- 011928	3/18/2025	3/18/2026	Basement	Cooler	In hallway adjacent to head custodian's office	WF-03182025-011928	10/3/2025	FT-FY26-09232025-011928-A	<2	FT-FY26-09232025-011928-B	<2
WS- 011929	3/18/2025	3/18/2026	1	Cooler	In hallway adjacent to room 102	WF-03182025-011929	10/3/2025	FT-FY26-09232025-011929-A	<2	FT-FY26-09232025-011929-B	<2
WS- 011940	3/18/2025	3/18/2026	1	Cooler	In hallway across from gym	WF-03182025-011940	10/3/2025	FT-FY26-09232025-011940-A	<2	FT-FY26-09232025-011940-B	<2
WS- 011961	3/18/2025	3/18/2026	1	Cooler	In hallway adjacent to guidance room 103	WF-03182025-011961	10/3/2025	FT-FY26-09232025-011961-A	<2	FT-FY26-09232025-011961-B	<2
WS- 012040	3/18/2025	3/18/2026	2	Bottle Filler	In hallway adjacent to stairwell 6	WF-03182025-012040	10/3/2025	FT-FY26-09232025-012040-A	<2	FT-FY26-09232025-012040-B	<2
WS- 012041	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to stairwell 6	WF-03182025-012041	10/3/2025	FT-FY26-09232025-012041-A	<2	FT-FY26-09232025-012041-B	<2
WS- 012043	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to stairwell 1	WF-03182025-012043	10/3/2025	FT-FY26-09232025-012043-A	<2	FT-FY26-09232025-012043-B	<2
WS- 012044	3/18/2025	3/18/2026	2	Break Room	In media center dining area 200 F	WF-03182025-012044	10/3/2025	FT-FY26-09232025-012044-A	<2	FT-FY26-09232025-012044-B	<2
WS- 012498	3/18/2025	3/18/2026	2	Cooler	In hallway across from stairwell 3	WF-03182025-012498	10/3/2025	FT-FY26-09232025-012498-A	<2	FT-FY26-09232025-012498-B	<2
WS- 012499	3/18/2025	3/18/2026	2	Cooler	In hallway across from stairwell 4	WF-03182025-012499	10/3/2025	FT-FY26-09232025-012499-A	<2	FT-FY26-09232025-012499-B	<2
WS- 012500	3/18/2025	3/18/2026	2	Break Room	In staff lounge	WF-03182025-012500	10/3/2025	FT-FY26-09232025-012500-A	<2	FT-FY26-09232025-012500-B	<2
WS- 012503	3/18/2025	3/18/2026	3	Cooler	In hallway adjacent to room 305	WF-03182025-012503	10/3/2025	FT-FY26-09232025-012503-A	<2	FT-FY26-09232025-012503-B	<2
WS- 012505	3/18/2025	3/18/2026	3	Cooler	In hallway across from stairwell 3	WF-03182025-012505	10/3/2025	FT-FY26-09232025-012505-A	<2	FT-FY26-09232025-012505-B	<2
WS- 012506	3/18/2025	3/18/2026	3	Cooler	In hallway across from stairwell 5	WF-03182025-012506	10/3/2025	FT-FY26-09232025-012506-A	<2	FT-FY26-09232025-012506-B	<2
WS- 012526	3/18/2025	3/18/2026	3	Cooler	In hallway adjacent to room 306	WF-03182025-012526	10/3/2025	FT-FY26-09232025-012526-A	<2	FT-FY26-09232025-012526-B	<2
WS- 012568	3/18/2025	3/18/2026	Basement	Cooler	In hallway adjacent to room 09A	WF-03182025-012568	10/3/2025	FT-FY26-09232025-012568-A	<2	FT-FY26-09232025-012568-B	<2
WS- 012602	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 020	WF-03182025-012602	10/3/2025	FT-FY26-09232025-012602-A	<2	FT-FY26-09232025-012602-B	<2
WS- 012604	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 020A	WF-03182025-012604	10/3/2025	FT-FY26-09232025-012604-A	<2	FT-FY26-09232025-012604-B	<2
WS- 012606	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 023	WF-03182025-012606	10/3/2025	FT-FY26-09232025-012606-A	<2	FT-FY26-09232025-012606-B	<2
WS- 012608	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 009	WF-03182025-012608	10/3/2025	FT-FY26-09232025-012608-A	<2	FT-FY26-09232025-012608-B	<2
WS- 012610	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 009A	WF-03182025-012610	10/3/2025	FT-FY26-09232025-012610-A	<2	FT-FY26-09232025-012610-B	<2
WS- 012612	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 05B	WF-03182025-012612	10/3/2025	FT-FY26-09232025-012612-A	<2	FT-FY26-09232025-012612-B	<2
WS- 012614	3/18/2025	3/18/2026	Basement	Combo Fountain	In classroom 05A	WF-03182025-012614	10/3/2025	FT-FY26-09232025-012614-A	<2	FT-FY26-09232025-012614-B	<2
WS- 012618	3/18/2025	3/18/2026	Basement	Combo Fountain	In test kitchen 010 along wall	WF-03182025-012618	10/3/2025	FT-FY26-09232025-012618-A	<2	FT-FY26-09232025-012618-B	<2
WS- 012620	3/18/2025	3/18/2026	1	Health Suite	In health suite 112	WF-03182025-012620	10/3/2025	FT-FY26-09232025-012620-A	<2	FT-FY26-09232025-012620-B	<2
WS- 012621	3/18/2025	3/18/2026	1	Health Suite	In health suite 112	WF-03182025-012621	10/3/2025	FT-FY26-09232025-012621-A	<2	FT-FY26-09232025-012621-B	<2
WS- 012630	6/18/2025	6/18/2026	1	Cooler	In hallway adjacent to stairwell 4	WF-06182025-012630	10/3/2025	FT-FY26-09232025-012630-A	<2	FT-FY26-09232025-012630-B	<2
WS- 012631	6/18/2025	6/18/2026	1	Bottle Filler	In hallway adjacent to stairwell 4	WF-06182025-012631	10/3/2025	FT-FY26-09232025-012631-A	<2	FT-FY26-09232025-012631-B	<2
WS- 012632	6/18/2025	6/18/2026	3	Bottle Filler	In hallway adjacent to room 306	WF-06182025-012632	10/3/2025	FT-FY26-09232025-012632-A	<2	FT-FY26-09232025-012632-B	<2
WS- 012633	6/18/2025	6/18/2026	Basement	Bottle Filler	In hallway adjacent to room 09A	WF-06182025-012633	10/3/2025	FT-FY26-09232025-012633-A	<2	FT-FY26-09232025-012633-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011902	11/12/2024	11/12/2025	Basement	Food Prep Sink	In kitchen first clockwise from cafeteria entry door	WF-11122024-011902	10/3/2025	FT-FY26-09232025-011902-A	<2	FT-FY26-09232025-011902-B	<2
WS- 012615	11/12/2024	11/12/2025	Basement	Food Prep Sink	In test kitchen 010 on island Left	WF-11122024-012615	10/3/2025	FT-FY26-09232025-012615-A	<2	FT-FY26-09232025-012615-B	<2
WS- 012616	11/12/2024	11/12/2025	Basement	Food Prep Sink	In test kitchen 010 on island Right	WF-11122024-012616	10/3/2025	FT-FY26-09232025-012616-A	<2	FT-FY26-09232025-012616-B	<2
WS- 012617	11/12/2024	11/12/2025	Basement	Food Prep Sink	In test kitchen 010 along wall	WF-11122024-012617	10/3/2025	FT-FY26-09232025-012617-A	<2	FT-FY26-09232025-012617-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.