



Orr ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009810	6/8/2017	6/8/2018	1	Cooler	In multi-purpose room adjacent to kitchen	WF-62017-009810	11/21/2017	FT-FY18--62017-009810-A	<1	FT-FY18--62017-009810-B	<1
WS- 009813	6/8/2017	6/8/2018	1	Cooler	In hallway across from main security desk	WF-62017-009813	11/21/2017	FT-FY18--62017-009813-A	<1	FT-FY18--62017-009813-B	<1
WS- 009815	6/8/2017	6/8/2018	1	Cooler	In health suite	WF-62017-009815	11/21/2017	FT-FY18--62017-009815-A	<1	FT-FY18--62017-009815-B	<1
WS- 009818	10/31/2017	10/31/2018	1	Classroom Faucet	In classroom Pre-K3 fourth clockwise around restrooms Left	WF-102017-009818	11/21/2017	FT-FY18-102017-009818-A	<1	FT-FY18-102017-009818-B	<1
WS- 009823	6/8/2017	6/8/2018	1	Cooler	In classroom Pre-K3 on north wall	WF-62017-009823	11/21/2017	FT-FY18--62017-009823-A	<1	FT-FY18--62017-009823-B	<1
WS- 009824	10/31/2017	10/31/2018	1	Classroom Faucet	In classroom Pre-K3 south section fifth clockwise around restrooms Right	WF-102017-009824	11/21/2017	FT-FY18-102017-009824-A	<1	FT-FY18-102017-009824-B	<1
WS- 009830	10/31/2017	10/31/2018	1	Classroom Faucet	In classroom Pre-K3 south section first clockwise around restrooms Left	WF-102017-009830	11/21/2017	FT-FY18-102017-009830-A	<1	FT-FY18-102017-009830-B	<1
WS- 009833	10/31/2017	10/31/2018	2	Classroom Faucet	In classroom Kindergarten fourth clockwise around restrooms Right	WF-102017-009833	11/21/2017	FT-FY18-102017-009833-A	<1	FT-FY18-102017-009833-B	<1
WS- 009836	6/8/2017	6/8/2018	2	Cooler	In hallway adjacent to boys' restroom	WF-62017-009836	11/21/2017	FT-FY18--62017-009836-A	<1	FT-FY18--62017-009836-B	<1
WS- 009843	6/8/2017	6/8/2018	4	Cooler	In hallway adjacent to girls' restroom	WF-62017-009843	11/21/2017	FT-FY18--62017-009843-A	<1	FT-FY18--62017-009843-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 009809	1	Food Prep Sink	In kitchen	11/21/2017	FT-FY18-102017-009809-A	<1	FT-FY18-102017-009809-B	<1			