



OYSTER ADAMS (OYSTER) LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002751	Utility	Basement	In boiler room north wall spicket	WT-042916-2768-A	99.5	WT-042916-2768-B	< 1	Non-drinking water source - Not accessible to children (boilers)			
2	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002752	Health Suite	1	In health suite	WT-042916-2769-A	< 1	WT-042916-2769-B	< 1				
3	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002753	Kitchen	1	In kitchen west wall Left	WT-042916-2770-A	< 1	WT-042916-2770-B	< 1				
4	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002754	Kitchen	1	In kitchen west wall Right	WT-042916-2771-A	1.11	WT-042916-2771-B	< 1				
5	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002755	Fountain	1	In art room 104 south wall	WT-042916-2772-A	< 1	WT-042916-2772-B	< 1				
6	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002756	Classroom	1	In art room 104 south wall	WT-042916-2773-A	< 1	WT-042916-2773-B	< 1				
7	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002757	Classroom	Ground Floor	In art room 104 north wall	WT-042916-2774-A	4.23	WT-042916-2774-B	< 1				
8	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002758	Cooler	1	In hallway across to 108 Left Low	WT-042916-2775-A	< 1	WT-042916-2775-B	< 1				
9	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002759	Cooler	1	In hallway across from room 108 High	WT-042916-2776-A	< 1	WT-042916-2776-B	< 1				
10	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002760	Classroom	1	In classroom 107	WT-042916-2777-A	< 1	WT-042916-2777-B	< 1				
11	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002761	Fountain	1	In classroom 107	WT-042916-2778-A	< 1	WT-042916-2778-B	< 1				
12	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002762	Classroom	2	In classroom 201	WT-042916-2779-A	< 1	WT-042916-2779-B	< 1				
13	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002763	Classroom	2	In classroom 201 south wall	WT-042916-2780-A	< 1	WT-042916-2780-B	< 1				
14	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002764	Fountain	2	In classroom 202	WT-042916-2781-A	< 1	WT-042916-2781-B	< 1				
15	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002765	Classroom	2	In classroom 202	WT-042916-2782-A	< 1	WT-042916-2782-B	< 1				
16	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002766	Cooler	2	In gym Low	WT-042916-2783-A	< 1	WT-042916-2783-B	< 1				
17	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002767	Fountain	2	In gym Right High	WT-042916-2784-A	< 1	WT-042916-2784-B	< 1				
18	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002768	Cooler	2	In hallway adjacent room 206 Low	WT-042916-2785-A	< 1	WT-042916-2785-B	< 1				
19	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002769	Cooler	2	In hallway adjacent to room 206 Right High	WT-042916-2786-A	< 1	WT-042916-2786-B	< 1				
20	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002770	Break Room	2	In teacher's lounge room 208	WT-042916-2787-A	< 1	WT-042916-2787-B	< 1				
21	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002771	Classroom	2	In classroom 210	WT-042916-2788-A	< 1	WT-042916-2788-B	< 1				
22	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002772	Fountain	2	In classroom 210	WT-042916-2789-A	< 1	WT-042916-2789-B	< 1				
23	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002773	Classroom	2	In classroom 211	WT-042916-2790-A	< 1	WT-042916-2790-B	< 1				
24	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002774	Fountain	2	In classroom 211	WT-042916-2791-A	< 1	WT-042916-2791-B	< 1				
25	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002775	Classroom	2	In classroom 316	WT-042916-2792-A	< 1	WT-042916-2792-B	< 1				
26	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002776	Fountain	2	In classroom 316	WT-042916-2793-A	< 1	WT-042916-2793-B	< 1				
27	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002777	Fountain	2	In classroom 313	WT-042916-2794-A	< 1	WT-042916-2794-B	< 1				
28	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002778	Fountain	2	In classroom 313	WT-042916-2795-A	< 1	WT-042916-2795-B	< 1				
29	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002779	Cooler	2	In hallway across from 312 Right High	WT-042916-2796-A	< 1	WT-042916-2796-B	< 1				
30	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002780	Cooler	2	In hallway across from pump room 312	WT-042916-2797-A	< 1	WT-042916-2797-B	< 1				
31	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS-002781	Fountain	2	In room 309	WT-042916-2798-A	< 1	WT-042916-2798-B	< 1				



OYSTER ADAMS (OYSTER) LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
32	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002782	Classroom	2	In room 309	WT-042916-2799- A	< 1	WT-042916-2799- B	< 1				
33	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002783	Fountain	2	In classroom 308	WT-042916-2800- A	< 1	WT-042916-2800- B	< 1				
34	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002784	Classroom	2	In classroom 308	WT-042916-2801- A	< 1	WT-042916-2801- B	< 1				
35	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002785	Classroom	2	In classroom 304	WT-042916-2802- A	< 1	WT-042916-2802- B	< 1				
36	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002786	Fountain	2	In classroom 304	WT-042916-2803- A	< 1	WT-042916-2803- B	< 1				
37	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002787	Classroom	2	In classroom 301	WT-042916-2804- A	< 1	WT-042916-2804- B	< 1				
38	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002788	Fountain	2	In classroom 301	WT-042916-2805- A	< 1	WT-042916-2805- B	< 1				
39	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002789	Classroom	3	In classroom 401	WT-042916-2806- A	< 1	WT-042916-2806- B	< 1				
40	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002790	Fountain	3	In classroom 401	WT-042916-2807- A	< 1	WT-042916-2807- B	< 1				
41	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002791	Classroom	3	In classroom 304	WT-042916-2808- A	< 1	WT-042916-2808- B	< 1				
42	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002792	Fountain	3	In classroom 304	WT-042916-2809- A	< 1	WT-042916-2809- B	< 1				
43	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002793	Classroom	3	In classroom 407	WT-042916-2810- A	< 1	WT-042916-2810- B	< 1				
44	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002794	Fountain	3	In classroom 307	WT-042916-2811- A	< 1	WT-042916-2811- B	< 1				
45	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002795	Cooler	3	In hallway between restroom 408 and 409	WT-042916-2812- A	< 1	WT-042916-2812- B	< 1				
46	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002796	Cooler	3	In hallway between both room 409 and 408 Left Low	WT-042916-2813- A	< 1	WT-042916-2813- B	< 1				
47	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002797	Classroom	3	In classroom 410	WT-042916-2814- A	< 1	WT-042916-2814- B	< 1				
48	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 002798	Fountain	3	In classroom 410	WT-042916-2815- A	< 1	WT-042916-2815- B	< 1				
49	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 004808	Classroom	3	In classroom 412	WT-042916-4825- A	< 1	WT-042916-4825- B	< 1				
50	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 004809	Fountain	3	In classroom 412	WT-042916-4826- A	< 1	WT-042916-4826- B	< 1				
51	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 004810	Classroom	3	In classroom 415	WT-042916-4827- A	< 1	WT-042916-4827- B	< 1				
52	OYSTER ADAMS BILINGUAL SCHOOL (OYSTER)	5/13/2016	WS- 004811	Fountain	3	In classroom 415	WT-042916-4828- A	< 1	WT-042916-4828- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.