



Oyster Adams @ Adams Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003970	3/20/2019	3/20/2020	1	Cooler	In hallway adjacent to room 102	WF-03202019-003970	1/2/2020	FT-FY20-122019-003970-A	<1	FT-FY20-122019-003970-B	<1
WS- 003973	3/20/2019	3/20/2020	1	Health Suite	In health suite Mid	WF-03202019-003973	1/2/2020	FT-FY20-122019-003973-A	<1	FT-FY20-122019-003973-B	<1
WS- 003974	3/20/2019	3/20/2020	1	Health Suite	In health suite Right	WF-03202019-003974	1/2/2020	FT-FY20-122019-003974-A	<1	FT-FY20-122019-003974-B	<1
WS- 003975	3/20/2019	3/20/2020	1	Health Suite	In health suite Left	WF-03202019-003975	1/2/2020	FT-FY20-122019-003975-A	<1	FT-FY20-122019-003975-B	<1
WS- 003976	3/20/2019	3/20/2020	1	Fountain	In cafeteria	WF-03202019-003976	1/2/2020	FT-FY20-122019-003976-A	<1	FT-FY20-122019-003976-B	<1
WS- 003978	3/20/2019	3/20/2020	1	Cooler	In hallway adjacent to room 103	WF-03202019-003978	1/2/2020	FT-FY20-122019-003978-A	<1	FT-FY20-122019-003978-B	<1
WS- 003980	3/20/2019	3/20/2020	1	Break Room	In staff lounge	WF-03202019-003980	1/2/2020	FT-FY20-122019-003980-A	<1	FT-FY20-122019-003980-B	<1
WS- 003981	3/20/2019	3/20/2020	2	Break Room	In staff lounge 209	WF-03202019-003981	1/2/2020	FT-FY20-122019-003981-A	<1	FT-FY20-122019-003981-B	<1
WS- 003982	3/20/2019	3/20/2020	2	Fountain	In gym on south wall	WF-03202019-003982	1/2/2020	FT-FY20-122019-003982-A	<1	FT-FY20-122019-003982-B	<1
WS- 003983	3/20/2019	3/20/2020	2	Fountain	In gym on north wall	WF-03202019-003983	1/2/2020	FT-FY20-122019-003983-A	<1	FT-FY20-122019-003983-B	<1
WS- 003984	3/20/2019	3/20/2020	2	Cooler	In hallway adjacent to room 201	WF-03202019-003984	1/2/2020	FT-FY20-122019-003984-A	<1	FT-FY20-122019-003984-B	<1
WS- 003985	3/20/2019	3/20/2020	2	Cooler	In hallway adjacent to room 202	WF-03202019-003985	1/2/2020	FT-FY20-122019-003985-A	<1	FT-FY20-122019-003985-B	<1
WS- 003986	3/20/2019	3/20/2020	3	Cooler	In hallway adjacent to room 302	WF-03202019-003986	1/2/2020	FT-FY20-122019-003986-A	<1	FT-FY20-122019-003986-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003977	6/26/2019	6/26/2020	1	Food Prep Sink	In kitchen	WF-06262019-003977	1/2/2020	FT-FY20-122019-003977-A	<1	FT-FY20-122019-003977-B	<1