



Oyster Adams ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002594	9/23/2019	9/23/2020	2	Classroom Faucet	In music room 205	WF-09232019-002594	12/18/2019	FT-FY20-112019-002594-A	<1	FT-FY20-112019-002594-B	<1
WS- 002752	4/30/2019	4/30/2020	1	Health Suite	In health suite	WF-04302019-002752	12/18/2019	FT-FY20-112019-002752-A	<1	FT-FY20-112019-002752-B	<1
WS- 002755	4/30/2019	4/30/2020	1	Combo Fountain	In art room 104	WF-04302019-002755	12/18/2019	FT-FY20-112019-002755-A	<1	FT-FY20-112019-002755-B	<1
WS- 002756	9/23/2019	9/23/2020	1	Combo Faucet	In art room 104 Left	WF-09232019-002756	12/18/2019	FT-FY20-112019-002756-A	<1	FT-FY20-112019-002756-B	<1
WS- 002757	9/23/2019	9/23/2020	1	Classroom Faucet	In art room 104 Right	WF-09232019-002757	12/18/2019	FT-FY20-112019-002757-A	<1	FT-FY20-112019-002757-B	<1
WS- 002758	4/30/2019	4/30/2020	1	Cooler	In hallway across from room 108 Low Left	WF-04302019-002758	12/18/2019	FT-FY20-112019-002758-A	<1	FT-FY20-112019-002758-B	<1
WS- 002759	4/30/2019	4/30/2020	1	Cooler	In hallway across from room 108 High Right	WF-04302019-002759	12/18/2019	FT-FY20-112019-002759-A	<1	FT-FY20-112019-002759-B	<1
WS- 002760	9/23/2019	9/23/2020	1	Combo Faucet	In classroom 107	WF-09232019-002760	12/18/2019	FT-FY20-112019-002760-A	<1	FT-FY20-112019-002760-B	<1
WS- 002761	4/30/2019	4/30/2020	1	Combo Fountain	In classroom 107	WF-04302019-002761	12/18/2019	FT-FY20-112019-002761-A	<1	FT-FY20-112019-002761-B	<1
WS- 002762	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 201	WF-09232019-002762	12/18/2019	FT-FY20-112019-002762-A	<1	FT-FY20-112019-002762-B	<1
WS- 002763	4/30/2019	4/30/2020	2	Combo Fountain	In classroom 201	WF-04302019-002763	12/18/2019	FT-FY20-112019-002763-A	<1	FT-FY20-112019-002763-B	<1
WS- 002764	4/30/2019	4/30/2020	2	Combo Fountain	In classroom 202	WF-04302019-002764	12/18/2019	FT-FY20-112019-002764-A	<1	FT-FY20-112019-002764-B	<1
WS- 002765	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 202	WF-09232019-002765	12/18/2019	FT-FY20-112019-002765-A	<1	FT-FY20-112019-002765-B	<1
WS- 002766	4/30/2019	4/30/2020	2	Cooler	In gym Low Left	WF-04302019-002766	12/18/2019	FT-FY20-112019-002766-A	<1	FT-FY20-112019-002766-B	<1
WS- 002767	4/30/2019	4/30/2020	2	Cooler	In gym High Right	WF-04302019-002767	12/18/2019	FT-FY20-112019-002767-A	<1	FT-FY20-112019-002767-B	<1
WS- 002768	4/30/2019	4/30/2020	2	Cooler	In hallway adjacent to room 206 Low Left	WF-04302019-002768	12/18/2019	FT-FY20-112019-002768-A	<1	FT-FY20-112019-002768-B	<1
WS- 002769	4/30/2019	4/30/2020	2	Cooler	In hallway adjacent to room 206 High Right	WF-04302019-002769	12/18/2019	FT-FY20-112019-002769-A	<1	FT-FY20-112019-002769-B	<1
WS- 002770	4/30/2019	4/30/2020	2	Break Room	In staff lounge 208	WF-04302019-002770	12/18/2019	FT-FY20-112019-002770-A	<1	FT-FY20-112019-002770-B	<1
WS- 002771	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 210	WF-09232019-002771	12/18/2019	FT-FY20-112019-002771-A	<1	FT-FY20-112019-002771-B	<1
WS- 002772	4/30/2019	4/30/2020	2	Combo Fountain	In classroom 210	WF-04302019-002772	12/18/2019	FT-FY20-112019-002772-A	<1	FT-FY20-112019-002772-B	<1
WS- 002773	9/23/2019	9/23/2020	2	Combo Faucet	In classroom 211	WF-09232019-002773	12/18/2019	FT-FY20-112019-002773-A	<1	FT-FY20-112019-002773-B	<1
WS- 002774	4/30/2019	4/30/2020	2	Combo Fountain	In classroom 211	WF-04302019-002774	12/18/2019	FT-FY20-112019-002774-A	<1	FT-FY20-112019-002774-B	<1
WS- 002775	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 316	WF-09232019-002775	12/18/2019	FT-FY20-112019-002775-A	<1	FT-FY20-112019-002775-B	<1
WS- 002776	4/30/2019	4/30/2020	3	Combo Fountain	In classroom 316	WF-04302019-002776	12/18/2019	FT-FY20-112019-002776-A	<1	FT-FY20-112019-002776-B	<1
WS- 002777	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 313	WF-09232019-002777	12/18/2019	FT-FY20-112019-002777-A	<1	FT-FY20-112019-002777-B	<1
WS- 002778	4/30/2019	4/30/2020	3	Combo Fountain	In classroom 313	WF-04302019-002778	12/18/2019	FT-FY20-112019-002778-A	<1	FT-FY20-112019-002778-B	<1
WS- 002779	4/30/2019	4/30/2020	3	Cooler	In hallway across from room 312 High Right	WF-04302019-002779	12/18/2019	FT-FY20-112019-002779-A	<1	FT-FY20-112019-002779-B	<1
WS- 002780	4/30/2019	4/30/2020	3	Cooler	In hallway across from room 312 Low Left	WF-04302019-002780	12/18/2019	FT-FY20-112019-002780-A	<1	FT-FY20-112019-002780-B	<1
WS- 002781	4/30/2019	4/30/2020	3	Combo Fountain	In classroom 309	WF-04302019-002781	12/18/2019	FT-FY20-112019-002781-A	<1	FT-FY20-112019-002781-B	<1
WS- 002782	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 309	WF-09232019-002782	12/18/2019	FT-FY20-112019-002782-A	<1	FT-FY20-112019-002782-B	<1
WS- 002783	4/30/2019	4/30/2020	3	Combo Fountain	In classroom 308	WF-04302019-002783	12/18/2019	FT-FY20-112019-002783-A	<1	FT-FY20-112019-002783-B	<1
WS- 002784	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 308	WF-09232019-002784	12/18/2019	FT-FY20-112019-002784-A	<1	FT-FY20-112019-002784-B	<1
WS- 002785	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 304	WF-09232019-002785	12/18/2019	FT-FY20-112019-002785-A	<1	FT-FY20-112019-002785-B	<1

WS- 002786	4/30/2019	4/30/2020	3	Combo Fountain	In classroom 304		WF-04302019-002786	12/18/2019	FT-FY20-112019-002786-A	<1	FT-FY20-112019-002786-B	<1
WS- 002787	9/23/2019	9/23/2020	3	Combo Faucet	In classroom 301		WF-09232019-002787	12/18/2019	FT-FY20-112019-002787-A	<1	FT-FY20-112019-002787-B	<1
WS- 002788	4/30/2019	4/30/2020	3	Combo Fountain	In classroom 301		WF-04302019-002788	12/18/2019	FT-FY20-112019-002788-A	<1	FT-FY20-112019-002788-B	<1
WS- 002789	9/23/2019	9/23/2020	4	Combo Faucet	In classroom 401		WF-09232019-002789	12/18/2019	FT-FY20-112019-002789-A	<1	FT-FY20-112019-002789-B	<1
WS- 002790	4/30/2019	4/30/2020	4	Combo Fountain	In classroom 401		WF-04302019-002790	12/18/2019	FT-FY20-112019-002790-A	<1	FT-FY20-112019-002790-B	<1
WS- 002791	9/23/2019	9/23/2020	4	Combo Faucet	In classroom 405		WF-09232019-002791	12/18/2019	FT-FY20-112019-002791-A	<1	FT-FY20-112019-002791-B	<1
WS- 002792	4/30/2019	4/30/2020	4	Combo Fountain	In classroom 405		WF-04302019-002792	12/18/2019	FT-FY20-112019-002792-A	<1	FT-FY20-112019-002792-B	<1
WS- 002793	9/23/2019	9/23/2020	4	Combo Faucet	In classroom 407		WF-09232019-002793	12/18/2019	FT-FY20-112019-002793-A	<1	FT-FY20-112019-002793-B	<1
WS- 002795	4/30/2019	4/30/2020	4	Cooler	In hallway adjacent to room 408	High Right	WF-04302019-002795	12/18/2019	FT-FY20-112019-002795-A	<1	FT-FY20-112019-002795-B	<1
WS- 002796	4/30/2019	4/30/2020	4	Cooler	In hallway adjacent to room 408	Low Left	WF-04302019-002796	12/18/2019	FT-FY20-112019-002796-A	<1	FT-FY20-112019-002796-B	<1
WS- 002797	9/23/2019	9/23/2020	4	Combo Faucet	In classroom 410		WF-09232019-002797	12/18/2019	FT-FY20-112019-002797-A	<1	FT-FY20-112019-002797-B	<1
WS- 002798	4/30/2019	4/30/2020	4	Combo Fountain	In classroom 410		WF-04302019-002798	12/18/2019	FT-FY20-112019-002798-A	<1	FT-FY20-112019-002798-B	<1
WS- 004808	9/23/2019	9/23/2020	4	Combo Faucet	In classroom 412		WF-09232019-004808	12/18/2019	FT-FY20-112019-004808-A	<1	FT-FY20-112019-004808-B	<1
WS- 004809	4/30/2019	4/30/2020	4	Combo Fountain	In classroom 412		WF-04302019-004809	12/18/2019	FT-FY20-112019-004809-A	<1	FT-FY20-112019-004809-B	<1
WS- 004810	9/23/2019	9/23/2020	4	Combo Faucet	In classroom 415		WF-09232019-004810	12/18/2019	FT-FY20-112019-004810-A	<1	FT-FY20-112019-004810-B	<1
WS- 004811	4/30/2019	4/30/2020	4	Combo Fountain	In classroom 415		WF-04302019-004811	12/18/2019	FT-FY20-112019-004811-A	<1	FT-FY20-112019-004811-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002753	7/15/2019	7/15/2020	1	Food Prep Sink	In kitchen	Left	WF-07152019-002753	12/18/2019	FT-FY20-112019-002753-A	<1	FT-FY20-112019-002753-B	<1
WS- 002754	7/15/2019	7/15/2020	1	Food Prep Sink	In kitchen	Right	WF-07152019-002754	12/18/2019	FT-FY20-112019-002754-A	<1	FT-FY20-112019-002754-B	<1