



Oyster Adams Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002594	8/31/2022	8/31/2023	2	Classroom Faucet	In music room 205	WF-08312022-002594	12/30/2022	FT-FY23-11182022-002594-A	<1	FT-FY23-11182022-002594-B	<1
WS- 002752	5/10/2022	5/10/2023	1	Health Suite	In health suite	WF-05102022-002752	12/30/2022	FT-FY23-11182022-002752-A	<1	FT-FY23-11182022-002752-B	<1
WS- 002755	5/10/2022	5/10/2023	1	Combo Fountain	In art room 104	WF-05102022-002755	12/30/2022	FT-FY23-11182022-002755-A	<1	FT-FY23-11182022-002755-B	<1
WS- 002756	8/31/2022	8/31/2023	1	Combo Faucet	In art room 104 Left	WF-08312022-002756	12/30/2022	FT-FY23-11182022-002756-A	<1	FT-FY23-11182022-002756-B	<1
WS- 002757	8/31/2022	8/31/2023	1	Classroom Faucet	In art room 104 Right	WF-08312022-002757	12/30/2022	FT-FY23-11182022-002757-A	<1	FT-FY23-11182022-002757-B	<1
WS- 002758	5/10/2022	5/10/2023	1	Cooler	In hallway across from room 108 Low Left	WF-05102022-002758	12/30/2022	FT-FY23-11182022-002758-A	<1	FT-FY23-11182022-002758-B	<1
WS- 002759	5/10/2022	5/10/2023	1	Cooler	In hallway across from room 108 High Right	WF-05102022-002759	12/30/2022	FT-FY23-11182022-002759-A	<1	FT-FY23-11182022-002759-B	<1
WS- 002760	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 107	WF-08312022-002760	12/30/2022	FT-FY23-11182022-002760-A	<1	FT-FY23-11182022-002760-B	<1
WS- 002761	5/10/2022	5/10/2023	1	Combo Fountain	In classroom 107	WF-05102022-002761	12/30/2022	FT-FY23-11182022-002761-A	<1	FT-FY23-11182022-002761-B	<1
WS- 002762	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 201	WF-08312022-002762	12/30/2022	FT-FY23-11182022-002762-A	<1	FT-FY23-11182022-002762-B	<1
WS- 002763	5/10/2022	5/10/2023	2	Combo Fountain	In classroom 201	WF-05102022-002763	12/30/2022	FT-FY23-11182022-002763-A	<1	FT-FY23-11182022-002763-B	<1
WS- 002764	5/10/2022	5/10/2023	2	Combo Fountain	In classroom 202	WF-05102022-002764	12/30/2022	FT-FY23-11182022-002764-A	<1	FT-FY23-11182022-002764-B	<1
WS- 002765	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 202	WF-08312022-002765	12/30/2022	FT-FY23-11182022-002765-A	<1	FT-FY23-11182022-002765-B	<1
WS- 002767	5/10/2022	5/10/2023	2	Cooler	In gym High Right	WF-05102022-002767	12/30/2022	FT-FY23-11182022-002767-A	<1	FT-FY23-11182022-002767-B	<1
WS- 002768	5/10/2022	5/10/2023	2	Cooler	In hallway adjacent to room 206 Low Left	WF-05102022-002768	12/30/2022	FT-FY23-11182022-002768-A	<1	FT-FY23-11182022-002768-B	<1
WS- 002769	5/10/2022	5/10/2023	2	Cooler	In hallway adjacent to room 206 High Right	WF-05102022-002769	12/30/2022	FT-FY23-11182022-002769-A	<1	FT-FY23-11182022-002769-B	<1
WS- 002770	5/10/2022	5/10/2023	2	Combo Faucet	In classroom 208	WF-05102022-002770	12/30/2022	FT-FY23-11182022-002770-A	<1	FT-FY23-11182022-002770-B	<1
WS- 002771	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 210	WF-08312022-002771	12/30/2022	FT-FY23-11182022-002771-A	<1	FT-FY23-11182022-002771-B	<1
WS- 002772	5/10/2022	5/10/2023	2	Combo Fountain	In classroom 210	WF-05102022-002772	12/30/2022	FT-FY23-11182022-002772-A	<1	FT-FY23-11182022-002772-B	<1
WS- 002773	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 211	WF-08312022-002773	12/30/2022	FT-FY23-11182022-002773-A	<1	FT-FY23-11182022-002773-B	<1
WS- 002774	5/10/2022	5/10/2023	2	Combo Fountain	In classroom 211	WF-05102022-002774	12/30/2022	FT-FY23-11182022-002774-A	<1	FT-FY23-11182022-002774-B	<1
WS- 002775	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 316	WF-08312022-002775	12/30/2022	FT-FY23-11182022-002775-A	<1	FT-FY23-11182022-002775-B	<1
WS- 002776	5/10/2022	5/10/2023	3	Combo Fountain	In classroom 316	WF-05102022-002776	12/30/2022	FT-FY23-11182022-002776-A	<1	FT-FY23-11182022-002776-B	<1
WS- 002777	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 313	WF-08312022-002777	12/30/2022	FT-FY23-11182022-002777-A	<1	FT-FY23-11182022-002777-B	<1
WS- 002778	5/10/2022	5/10/2023	3	Combo Fountain	In classroom 313	WF-05102022-002778	12/30/2022	FT-FY23-11182022-002778-A	<1	FT-FY23-11182022-002778-B	<1
WS- 002779	5/10/2022	5/10/2023	3	Cooler	In hallway across from room 312 High Right	WF-05102022-002779	12/30/2022	FT-FY23-11182022-002779-A	<1	FT-FY23-11182022-002779-B	<1
WS- 002780	5/10/2022	5/10/2023	3	Cooler	In hallway across from room 312 Low Left	WF-05102022-002780	12/30/2022	FT-FY23-11182022-002780-A	<1	FT-FY23-11182022-002780-B	<1
WS- 002781	5/10/2022	5/10/2023	3	Combo Fountain	In classroom 309	WF-05102022-002781	12/30/2022	FT-FY23-11182022-002781-A	<1	FT-FY23-11182022-002781-B	<1
WS- 002782	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 309	WF-08312022-002782	12/30/2022	FT-FY23-11182022-002782-A	<1	FT-FY23-11182022-002782-B	<1
WS- 002783	5/10/2022	5/10/2023	3	Combo Fountain	In classroom 308	WF-05102022-002783	12/30/2022	FT-FY23-11182022-002783-A	<1	FT-FY23-11182022-002783-B	<1
WS- 002784	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 308	WF-08312022-002784	12/30/2022	FT-FY23-11182022-002784-A	<1	FT-FY23-11182022-002784-B	<1
WS- 002785	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 304	WF-08312022-002785	12/30/2022	FT-FY23-11182022-002785-A	<1	FT-FY23-11182022-002785-B	<1
WS- 002786	5/10/2022	5/10/2023	3	Combo Fountain	In classroom 304	WF-05102022-002786	12/30/2022	FT-FY23-11182022-002786-A	<1	FT-FY23-11182022-002786-B	<1
WS- 002789	8/31/2022	8/31/2023	4	Combo Faucet	In classroom 401	WF-08312022-002789	12/30/2022	FT-FY23-11182022-002789-A	<1	FT-FY23-11182022-002789-B	<1
WS- 002790	5/10/2022	5/10/2023	4	Combo Fountain	In classroom 401	WF-05102022-002790	12/30/2022	FT-FY23-11182022-002790-A	<1	FT-FY23-11182022-002790-B	<1

WS- 002791	8/31/2022	8/31/2023	4	Combo Faucet	In classroom 405		WF-08312022-002791	12/30/2022	FT-FY23-11182022-002791-A	<1	FT-FY23-11182022-002791-B	<1
WS- 002792	5/10/2022	5/10/2023	4	Combo Fountain	In classroom 405		WF-05102022-002792	12/30/2022	FT-FY23-11182022-002792-A	<1	FT-FY23-11182022-002792-B	<1
WS- 002793	8/31/2022	8/31/2023	4	Combo Faucet	In classroom 407		WF-08312022-002793	12/30/2022	FT-FY23-11182022-002793-A	<1	FT-FY23-11182022-002793-B	<1
WS- 002794	5/10/2022	5/10/2023	4	Combo Fountain	In classroom 407		WF-05102022-002794	12/30/2022	FT-FY23-11182022-002794-A	<1	FT-FY23-11182022-002794-B	<1
WS- 002795	5/10/2022	5/10/2023	4	Cooler	In hallway adjacent to room 408	High Right	WF-05102022-002795	12/30/2022	FT-FY23-11182022-002795-A	<1	FT-FY23-11182022-002795-B	<1
WS- 002796	5/10/2022	5/10/2023	4	Cooler	In hallway adjacent to room 408	Low Left	WF-05102022-002796	12/30/2022	FT-FY23-11182022-002796-A	<1	FT-FY23-11182022-002796-B	<1
WS- 002797	8/31/2022	8/31/2023	4	Combo Faucet	In classroom 410		WF-08312022-002797	12/30/2022	FT-FY23-11182022-002797-A	<1	FT-FY23-11182022-002797-B	<1
WS- 002798	5/10/2022	5/10/2023	4	Combo Fountain	In classroom 410		WF-05102022-002798	12/30/2022	FT-FY23-11182022-002798-A	<1	FT-FY23-11182022-002798-B	<1
WS- 004808	8/31/2022	8/31/2023	4	Combo Faucet	In classroom 412		WF-08312022-004808	12/30/2022	FT-FY23-11182022-004808-A	<1	FT-FY23-11182022-004808-B	<1
WS- 004809	5/10/2022	5/10/2023	4	Combo Fountain	In classroom 412		WF-05102022-004809	12/30/2022	FT-FY23-11182022-004809-A	<1	FT-FY23-11182022-004809-B	<1
WS- 004810	8/31/2022	8/31/2023	4	Combo Faucet	In classroom 415		WF-08312022-004810	12/30/2022	FT-FY23-11182022-004810-A	<1	FT-FY23-11182022-004810-B	<1
WS- 004811	5/10/2022	5/10/2023	4	Combo Fountain	In classroom 415		WF-05102022-004811	12/30/2022	FT-FY23-11182022-004811-A	<1	FT-FY23-11182022-004811-B	<1
WS- 004832	5/10/2022	5/10/2023	Ground Floor	Break Room	In trailer in staff lounge		WF-05102022-004832	12/30/2022	FT-FY23-11182022-004832-A	<1	FT-FY23-11182022-004832-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002753	1/19/2022	1/19/2023	1	Food Prep Sink	In kitchen	Left	WF-01192022-002753	12/30/2022	FT-FY23-11182022-002753-A	<1	FT-FY23-11182022-002753-B	<1
WS- 002754	1/19/2022	1/19/2023	1	Food Prep Sink	In kitchen	Right	WF-01192022-002754	12/30/2022	FT-FY23-11182022-002754-A	<1	FT-FY23-11182022-002754-B	<1