



Oyster Adams Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002594	8/22/2023	8/22/2024	2	Classroom Faucet	In music room 205	WF-08222023-002594	11/2/2023	FT-FY24-09282023-002594-A	<1	FT-FY24-09282023-002594-B	<1
WS- 002752	5/1/2023	5/1/2024	1	Health Suite	In health suite	WF-05012023-002752	11/2/2023	FT-FY24-09282023-002752-A	<1	FT-FY24-09282023-002752-B	<1
WS- 002755	5/1/2023	5/1/2024	1	Combo Fountain	In art room 104	WF-05012023-002755	11/2/2023	FT-FY24-09282023-002755-A	<1	FT-FY24-09282023-002755-B	<1
WS- 002756	8/22/2023	8/22/2024	1	Combo Faucet	In art room 104 Left	WF-08222023-002756	11/2/2023	FT-FY24-09282023-002756-A	<1	FT-FY24-09282023-002756-B	<1
WS- 002757	8/22/2023	8/22/2024	1	Classroom Faucet	In art room 104 Right	WF-08222023-002757	11/2/2023	FT-FY24-09282023-002757-A	<1	FT-FY24-09282023-002757-B	<1
WS- 002758	5/1/2023	5/1/2024	1	Cooler	In hallway across from room 108 Low Left	WF-05012023-002758	11/2/2023	FT-FY24-09282023-002758-A	<1	FT-FY24-09282023-002758-B	<1
WS- 002759	5/1/2023	5/1/2024	1	Cooler	In hallway across from room 108 High Right	WF-05012023-002759	11/2/2023	FT-FY24-09282023-002759-A	<1	FT-FY24-09282023-002759-B	<1
WS- 002760	8/22/2023	8/22/2024	1	Combo Faucet	In classroom 107	WF-08222023-002760	11/2/2023	FT-FY24-09282023-002760-A	<1	FT-FY24-09282023-002760-B	<1
WS- 002761	5/1/2023	5/1/2024	1	Combo Fountain	In classroom 107	WF-05012023-002761	11/2/2023	FT-FY24-09282023-002761-A	<1	FT-FY24-09282023-002761-B	<1
WS- 002762	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 201	WF-08222023-002762	11/2/2023	FT-FY24-09282023-002762-A	4.2	FT-FY24-09282023-002762-B	<1
WS- 002763	5/1/2023	5/1/2024	2	Combo Fountain	In classroom 201	WF-05012023-002763	11/2/2023	FT-FY24-09282023-002763-A	<1	FT-FY24-09282023-002763-B	<1
WS- 002764	5/1/2023	5/1/2024	2	Combo Fountain	In classroom 202	WF-05012023-002764	11/2/2023	FT-FY24-09282023-002764-A	<1	FT-FY24-09282023-002764-B	<1
WS- 002765	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 202	WF-08222023-002765	11/2/2023	FT-FY24-09282023-002765-A	<1	FT-FY24-09282023-002765-B	<1
WS- 002768	5/1/2023	5/1/2024	2	Cooler	In hallway adjacent to room 206 Low Left	WF-05012023-002768	11/2/2023	FT-FY24-09282023-002768-A	<1	FT-FY24-09282023-002768-B	<1
WS- 002769	5/1/2023	5/1/2024	2	Cooler	In hallway adjacent to room 206 High Right	WF-05012023-002769	11/2/2023	FT-FY24-09282023-002769-A	<1	FT-FY24-09282023-002769-B	<1
WS- 002770	5/1/2023	5/1/2024	2	Combo Faucet	In classroom 208	WF-05012023-002770	11/2/2023	FT-FY24-09282023-002770-A	<1	FT-FY24-09282023-002770-B	<1
WS- 002771	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 210	WF-08222023-002771	11/2/2023	FT-FY24-09282023-002771-A	<1	FT-FY24-09282023-002771-B	<1
WS- 002772	5/1/2023	5/1/2024	2	Combo Fountain	In classroom 210	WF-05012023-002772	11/2/2023	FT-FY24-09282023-002772-A	<1	FT-FY24-09282023-002772-B	<1
WS- 002773	8/22/2023	8/22/2024	2	Combo Faucet	In classroom 211	WF-08222023-002773	11/2/2023	FT-FY24-09282023-002773-A	1.3	FT-FY24-09282023-002773-B	<1
WS- 002774	5/1/2023	5/1/2024	2	Combo Fountain	In classroom 211	WF-05012023-002774	11/2/2023	FT-FY24-09282023-002774-A	<1	FT-FY24-09282023-002774-B	<1
WS- 002775	8/22/2023	8/22/2024	3	Combo Faucet	In classroom 316	WF-08222023-002775	11/2/2023	FT-FY24-09282023-002775-A	<1	FT-FY24-09282023-002775-B	<1
WS- 002776	5/1/2023	5/1/2024	3	Combo Fountain	In classroom 316	WF-05012023-002776	11/2/2023	FT-FY24-09282023-002776-A	<1	FT-FY24-09282023-002776-B	<1
WS- 002777	8/22/2023	8/22/2024	3	Combo Faucet	In classroom 313	WF-08222023-002777	11/2/2023	FT-FY24-09282023-002777-A	<1	FT-FY24-09282023-002777-B	<1
WS- 002778	5/1/2023	5/1/2024	3	Combo Fountain	In classroom 313	WF-05012023-002778	11/2/2023	FT-FY24-09282023-002778-A	<1	FT-FY24-09282023-002778-B	<1
WS- 002779	5/1/2023	5/1/2024	3	Cooler	In hallway across from room 312 High Right	WF-05012023-002779	11/2/2023	FT-FY24-09282023-002779-A	<1	FT-FY24-09282023-002779-B	<1
WS- 002780	5/1/2023	5/1/2024	3	Cooler	In hallway across from room 312 Low Left	WF-05012023-002780	11/2/2023	FT-FY24-09282023-002780-A	<1	FT-FY24-09282023-002780-B	<1
WS- 002781	5/1/2023	5/1/2024	3	Combo Fountain	In classroom 309	WF-05012023-002781	11/2/2023	FT-FY24-09282023-002781-A	<1	FT-FY24-09282023-002781-B	<1
WS- 002782	8/22/2023	8/22/2024	3	Combo Faucet	In classroom 309	WF-08222023-002782	11/2/2023	FT-FY24-09282023-002782-A	<1	FT-FY24-09282023-002782-B	<1
WS- 002783	5/1/2023	5/1/2024	3	Combo Fountain	In classroom 308	WF-05012023-002783	11/2/2023	FT-FY24-09282023-002783-A	<1	FT-FY24-09282023-002783-B	<1
WS- 002784	8/22/2023	8/22/2024	3	Combo Faucet	In classroom 308	WF-08222023-002784	11/2/2023	FT-FY24-09282023-002784-A	<1	FT-FY24-09282023-002784-B	1.3
WS- 002785	8/22/2023	8/22/2024	3	Combo Faucet	In classroom 304	WF-08222023-002785	11/2/2023	FT-FY24-09282023-002785-A	<1	FT-FY24-09282023-002785-B	<1
WS- 002786	5/1/2023	5/1/2024	3	Combo Fountain	In classroom 304	WF-05012023-002786	11/2/2023	FT-FY24-09282023-002786-A	<1	FT-FY24-09282023-002786-B	<1
WS- 002789	8/22/2023	8/22/2024	4	Combo Faucet	In classroom 401	WF-08222023-002789	11/2/2023	FT-FY24-09282023-002789-A	<1	FT-FY24-09282023-002789-B	<1
WS- 002790	5/1/2023	5/1/2024	4	Combo Fountain	In classroom 401	WF-05012023-002790	11/2/2023	FT-FY24-09282023-002790-A	<1	FT-FY24-09282023-002790-B	<1
WS- 002791	8/22/2023	8/22/2024	4	Combo Faucet	In classroom 405	WF-08222023-002791	11/2/2023	FT-FY24-09282023-002791-A	<1	FT-FY24-09282023-002791-B	<1

WS- 002792	5/1/2023	5/1/2024	4	Combo Fountain	In classroom 405		WF-05012023-002792	11/2/2023	FT-FY24-09282023-002792-A	<1	FT-FY24-09282023-002792-B	<1
WS- 002793	8/22/2023	8/22/2024	4	Combo Faucet	In classroom 407		WF-08222023-002793	11/2/2023	FT-FY24-09282023-002793-A	<1	FT-FY24-09282023-002793-B	<1
WS- 002794	5/1/2023	5/1/2024	4	Combo Fountain	In classroom 407		WF-05012023-002794	11/2/2023	FT-FY24-09282023-002794-A	<1	FT-FY24-09282023-002794-B	<1
WS- 002795	5/1/2023	5/1/2024	4	Cooler	In hallway adjacent to room 408	High Right	WF-05012023-002795	11/2/2023	FT-FY24-09282023-002795-A	<1	FT-FY24-09282023-002795-B	<1
WS- 002796	5/1/2023	5/1/2024	4	Cooler	In hallway adjacent to room 408	Low Left	WF-05012023-002796	11/2/2023	FT-FY24-09282023-002796-A	<1	FT-FY24-09282023-002796-B	<1
WS- 002797	8/22/2023	8/22/2024	4	Combo Faucet	In classroom 410		WF-08222023-002797	11/2/2023	FT-FY24-09282023-002797-A	<1	FT-FY24-09282023-002797-B	<1
WS- 002798	5/1/2023	5/1/2024	4	Combo Fountain	In classroom 410		WF-05012023-002798	11/2/2023	FT-FY24-09282023-002798-A	<1	FT-FY24-09282023-002798-B	<1
WS- 004808	8/22/2023	8/22/2024	4	Combo Faucet	In classroom 412		WF-08222023-004808	11/2/2023	FT-FY24-09282023-004808-A	<1	FT-FY24-09282023-004808-B	<1
WS- 004809	5/1/2023	5/1/2024	4	Combo Fountain	In classroom 412		WF-05012023-004809	11/2/2023	FT-FY24-09282023-004809-A	<1	FT-FY24-09282023-004809-B	<1
WS- 004810	8/22/2023	8/22/2024	4	Combo Faucet	In classroom 415		WF-08222023-004810	11/2/2023	FT-FY24-09282023-004810-A	<1	FT-FY24-09282023-004810-B	<1
WS- 004811	5/1/2023	5/1/2024	4	Combo Fountain	In classroom 415		WF-05012023-004811	11/2/2023	FT-FY24-09282023-004811-A	<1	FT-FY24-09282023-004811-B	<1
WS- 004831	5/1/2023	5/1/2024	2	Combo Fountain	In classroom 208		WF-05012023-004831	11/2/2023	FT-FY24-09282023-004831-A	<1	FT-FY24-09282023-004831-B	<1
WS- 004832	5/1/2023	5/1/2024	Ground Floor	Break Room	In trailer in staff lounge		WF-05012023-004832	11/2/2023	FT-FY24-09282023-004832-A	<1	FT-FY24-09282023-004832-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002753	12/28/2022	12/28/2023	1	Food Prep Sink	In kitchen	Left	WF-12282022-002753	11/2/2023	FT-FY24-09282023-002753-A	<1	FT-FY24-09282023-002753-B	<1
WS- 002754	12/27/2022	12/27/2023	1	Food Prep Sink	In kitchen	Right	WF-12272022-002754	11/2/2023	FT-FY24-09282023-002754-A	<1	FT-FY24-09282023-002754-B	<1