



OYSTER ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	OYSTER ELEMENTARY SCHOOL	WS- 002756	12/11/2016	1	Combo Faucet	In art room 104 Left	FT-122016-002756-A	< 1	FT-122016-002756-B	< 1
2	OYSTER ELEMENTARY SCHOOL	WS- 002765	12/11/2016	2	Combo Faucet	In classroom 202	FT-122016-002765-A	< 1	FT-122016-002765-B	< 1
3	OYSTER ELEMENTARY SCHOOL	WS- 002771	12/11/2016	2	Combo Faucet	In classroom 210	FT-122016-002771-A	< 1	FT-122016-002771-B	< 1
4	OYSTER ELEMENTARY SCHOOL	WS- 002773	12/11/2016	2	Combo Faucet	In classroom 211	FT-122016-002773-A	< 1	FT-122016-002773-B	< 1
5	OYSTER ELEMENTARY SCHOOL	WS- 002760	12/11/2016	1	Combo Faucet	In classroom 107	FT-122016-002760-A	< 1	FT-122016-002760-B	< 1
6	OYSTER ELEMENTARY SCHOOL	WS- 002784	12/11/2016	3	Combo Faucet	In classroom 308	FT-122016-002784-A	< 1	FT-122016-002784-B	< 1
7	OYSTER ELEMENTARY SCHOOL	WS- 002757	12/11/2016	1	Classroom Faucet	In art room 104 Right	FT-122016-002757-A	< 1	FT-122016-002757-B	< 1
8	OYSTER ELEMENTARY SCHOOL	WS- 002762	12/11/2016	2	Combo Faucet	In classroom 201	FT-122016-002762-A	< 1	FT-122016-002762-B	< 1
9	OYSTER ELEMENTARY SCHOOL	WS- 002785	12/11/2016	3	Combo Faucet	In classroom 304	FT-122016-002785-A	1.3	FT-122016-002785-B	< 1
10	OYSTER ELEMENTARY SCHOOL	WS- 002787	12/11/2016	3	Combo Faucet	In classroom 301	FT-122016-002787-A	< 1	FT-122016-002787-B	< 1
11	OYSTER ELEMENTARY SCHOOL	WS- 002797	12/11/2016	4	Combo Faucet	In classroom 410	FT-122016-002797-A	< 1	FT-122016-002797-B	< 1
12	OYSTER ELEMENTARY SCHOOL	WS- 002782	12/11/2016	3	Combo Faucet	In classroom 309	FT-122016-002782-A	< 1	FT-122016-002782-B	< 1
13	OYSTER ELEMENTARY SCHOOL	WS- 004808	12/11/2016	4	Combo Faucet	In classroom 412	FT-122016-004808-A	< 1	FT-122016-004808-B	< 1
14	OYSTER ELEMENTARY SCHOOL	WS- 002789	12/11/2016	4	Combo Faucet	In classroom 401	FT-122016-002789-A	< 1	FT-122016-002789-B	< 1
15	OYSTER ELEMENTARY SCHOOL	WS- 004810	12/11/2016	4	Combo Faucet	In classroom 415	FT-122016-004810-A	< 1	FT-122016-004810-B	< 1
16	OYSTER ELEMENTARY SCHOOL	WS- 002793	12/11/2016	4	Combo Faucet	In classroom 407	FT-122016-002793-A	< 1	FT-122016-002793-B	< 1
17	OYSTER ELEMENTARY SCHOOL	WS- 002594	12/11/2016	2	Classroom Faucet	In music room 205	FT-122016-002594-A	< 1	FT-122016-002594-B	< 1
18	OYSTER ELEMENTARY SCHOOL	WS- 002777	12/11/2016	3	Combo Faucet	In classroom 313	FT-122016-002777-A	< 1	FT-122016-002777-B	< 1
19	OYSTER ELEMENTARY SCHOOL	WS- 002791	12/11/2016	4	Combo Faucet	In classroom 405	FT-122016-002791-A	< 1	FT-122016-002791-B	< 1
20	OYSTER ELEMENTARY SCHOOL	WS- 002775	12/11/2016	3	Combo Faucet	In classroom 316	FT-122016-002775-A	< 1	FT-122016-002775-B	< 1
21	OYSTER ELEMENTARY SCHOOL	WS- 002770	12/11/2016	2	Break Room	In staff lounge 208	FT-112016-002770-A	< 1	FT-112016-002770-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

9	OYSTER ELEMENTARY SCHOOL	WS- 002785	1/25/2017	3	Combo Faucet	In classroom 304	FT-122016-002785-A	< 1	FT-122016-002785-B	< 1
---	--------------------------	------------	-----------	---	--------------	------------------	--------------------	-----	--------------------	-----

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb