



OYSTER ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	OYSTER ELEMENTARY SCHOOL	WS- 002752	8/19/2016	1	Health Suite	In health suite	FT-82016-002752-A	< 1	FT-82016-002752-B	< 1
2	OYSTER ELEMENTARY SCHOOL	WS- 002754	8/19/2016	1	Food Prep Sink	In kitchen Right	FT-72016-002754-A	< 1	FT-72016-002754-B	< 1
3	OYSTER ELEMENTARY SCHOOL	WS- 002755	8/19/2016	1	Fountain	In art room 104	FT-72016-002755-A	< 1	FT-72016-002755-B	< 1
4	OYSTER ELEMENTARY SCHOOL	WS- 002758	8/19/2016	1	Cooler	In hallway across from room 108 Low Left	FT-72016-002758-A	< 1	FT-72016-002758-B	< 1
5	OYSTER ELEMENTARY SCHOOL	WS- 002759	8/19/2016	1	Cooler	In hallway across from room 108 High Right	FT-72016-002759-A	< 1	FT-72016-002759-B	< 1
6	OYSTER ELEMENTARY SCHOOL	WS- 002761	8/19/2016	1	Fountain	In classroom 107	FT-72016-002761-A	< 1	FT-72016-002761-B	< 1
7	OYSTER ELEMENTARY SCHOOL	WS- 002763	8/19/2016	2	Fountain	In classroom 201	FT-72016-002763-A	< 1	FT-72016-002763-B	< 1
8	OYSTER ELEMENTARY SCHOOL	WS- 002764	8/19/2016	2	Fountain	In classroom 202	FT-82016-002764-A	< 1	FT-82016-002764-B	< 1
9	OYSTER ELEMENTARY SCHOOL	WS- 002766	8/19/2016	2	Cooler	In gym Low Left	FT-72016-002766-A	< 1	FT-72016-002766-B	< 1
10	OYSTER ELEMENTARY SCHOOL	WS- 002767	8/19/2016	2	Cooler	In gym High Right	FT-72016-002767-A	< 1	FT-72016-002767-B	< 1
11	OYSTER ELEMENTARY SCHOOL	WS- 002768	8/19/2016	2	Cooler	In hallway adjacent to room 206 Low Left	FT-72016-002768-A	< 1	FT-72016-002768-B	< 1
12	OYSTER ELEMENTARY SCHOOL	WS- 002769	8/19/2016	2	Cooler	In hallway adjacent to room 206 High Right	FT-72016-002769-A	< 1	FT-72016-002769-B	< 1
13	OYSTER ELEMENTARY SCHOOL	WS- 002772	8/19/2016	2	Fountain	In classroom 210	FT-72016-002772-A	< 1	FT-72016-002772-B	< 1
14	OYSTER ELEMENTARY SCHOOL	WS- 002774	8/19/2016	2	Fountain	In classroom 211	FT-82016-002774-A	< 1	FT-82016-002774-B	< 1
15	OYSTER ELEMENTARY SCHOOL	WS- 002776	8/19/2016	3	Fountain	In classroom 316	FT-72016-002776-A	< 1	FT-72016-002776-B	< 1
16	OYSTER ELEMENTARY SCHOOL	WS- 002777	8/19/2016	3	Fountain	In classroom 313	FT-82016-002777-A	< 1	FT-82016-002777-B	< 1
17	OYSTER ELEMENTARY SCHOOL	WS- 002778	8/19/2016	3	Fountain	In classroom 313	FT-72016-002778-A	< 1	FT-72016-002778-B	< 1
18	OYSTER ELEMENTARY SCHOOL	WS- 002779	8/19/2016	3	Cooler	In hallway across from room 312 High Right	FT-72016-002779-A	< 1	FT-72016-002779-B	< 1
19	OYSTER ELEMENTARY SCHOOL	WS- 002780	8/19/2016	3	Cooler	In hallway across from room 312 Low Left	FT-72016-002780-A	< 1	FT-72016-002780-B	< 1
20	OYSTER ELEMENTARY SCHOOL	WS- 002781	8/19/2016	3	Fountain	In classroom 309	FT-72016-002781-A	< 1	FT-72016-002781-B	< 1
21	OYSTER ELEMENTARY SCHOOL	WS- 002783	8/19/2016	3	Fountain	In classroom 308	FT-72016-002783-A	< 1	FT-72016-002783-B	< 1
22	OYSTER ELEMENTARY SCHOOL	WS- 002786	8/19/2016	3	Fountain	In classroom 304	FT-82016-002786-A	< 1	FT-82016-002786-B	< 1
23	OYSTER ELEMENTARY SCHOOL	WS- 002788	8/19/2016	3	Fountain	In classroom 301	FT-72016-002788-A	< 1	FT-72016-002788-B	< 1
24	OYSTER ELEMENTARY SCHOOL	WS- 002790	8/19/2016	4	Fountain	In classroom 401	FT-72016-002790-A	< 1	FT-72016-002790-B	< 1
25	OYSTER ELEMENTARY SCHOOL	WS- 002792	8/19/2016	4	Fountain	In classroom 405	FT-72016-002792-A	< 1	FT-72016-002792-B	< 1
26	OYSTER ELEMENTARY SCHOOL	WS- 002794	8/19/2016	4	Fountain	In classroom 407	FT-72016-002794-A	< 1	FT-72016-002794-B	< 1
27	OYSTER ELEMENTARY SCHOOL	WS- 002795	8/19/2016	4	Cooler	In hallway adjacent to room 408 High Right	FT-72016-002795-A	< 1	FT-72016-002795-B	< 1
28	OYSTER ELEMENTARY SCHOOL	WS- 002796	8/19/2016	4	Cooler	In hallway adjacent to room 408 Low Left	FT-72016-002796-A	< 1	FT-72016-002796-B	< 1
29	OYSTER ELEMENTARY SCHOOL	WS- 002798	8/19/2016	4	Fountain	In classroom 410	FT-72016-002798-A	< 1	FT-72016-002798-B	< 1
30	OYSTER ELEMENTARY SCHOOL	WS- 004809	8/19/2016	4	Fountain	In classroom 412	FT-72016-004809-A	< 1	FT-72016-004809-B	< 1
31	OYSTER ELEMENTARY SCHOOL	WS- 004811	8/19/2016	4	Fountain	In classroom 415	FT-72016-004811-A	< 1	FT-72016-004811-B	1.1
			10/10/2016				Re-test A	< 1	Re-test B	< 1