



# Oyster ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002594	10/1/2018	10/1/2019	2	Classroom Faucet	In music room 205	WF-10012018-002594	12/9/2018	FT-FY19-112018-002594-A	<1	FT-FY19-112018-002594-B	<1
WS- 002752	5/10/2018	5/10/2019	1	Health Suite	In health suite	WF-05102018-002752	12/9/2018	FT-FY19-112018-002752-A	<1	FT-FY19-112018-002752-B	<1
WS- 002755	5/10/2018	5/10/2019	1	Combo Fountain	In art room 104	WF-05102018-002755	12/9/2018	FT-FY19-112018-002755-A	<1	FT-FY19-112018-002755-B	<1
WS- 002756	10/1/2018	10/1/2019	1	Combo Faucet	In art room 104 Left	WF-10012018-002756	12/9/2018	FT-FY19-112018-002756-A	<1	FT-FY19-112018-002756-B	<1
WS- 002757	10/1/2018	10/1/2019	1	Classroom Faucet	In art room 104 Right	WF-10012018-002757	12/9/2018	FT-FY19-112018-002757-A	<1	FT-FY19-112018-002757-B	<1
WS- 002758	5/10/2018	5/10/2019	1	Cooler	In hallway across from room 108 Low Left	WF-05102018-002758	12/9/2018	FT-FY19-112018-002758-A	<1	FT-FY19-112018-002758-B	<1
WS- 002759	5/10/2018	5/10/2019	1	Cooler	In hallway across from room 108 High Right	WF-05102018-002759	12/9/2018	FT-FY19-112018-002759-A	<1	FT-FY19-112018-002759-B	<1
WS- 002760	10/1/2018	10/1/2019	1	Combo Faucet	In classroom 107	WF-10012018-002760	12/9/2018	FT-FY19-112018-002760-A	<1	FT-FY19-112018-002760-B	<1
WS- 002761	5/10/2018	5/10/2019	1	Combo Fountain	In classroom 107	WF-05102018-002761	12/9/2018	FT-FY19-112018-002761-A	<1	FT-FY19-112018-002761-B	<1
WS- 002762	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 201	WF-10012018-002762	12/9/2018	FT-FY19-112018-002762-A	<1	FT-FY19-112018-002762-B	<1
WS- 002763	5/10/2018	5/10/2019	2	Combo Fountain	In classroom 201	WF-05102018-002763	12/9/2018	FT-FY19-112018-002763-A	<1	FT-FY19-112018-002763-B	<1
WS- 002764	5/10/2018	5/10/2019	2	Combo Fountain	In classroom 202	WF-05102018-002764	12/9/2018	FT-FY19-112018-002764-A	<1	FT-FY19-112018-002764-B	<1
WS- 002765	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 202	WF-10012018-002765	12/9/2018	FT-FY19-112018-002765-A	<1	FT-FY19-112018-002765-B	<1
WS- 002766	5/10/2018	5/10/2019	2	Cooler	In gym Low Left	WF-05102018-002766	12/9/2018	FT-FY19-112018-002766-A	<1	FT-FY19-112018-002766-B	<1
WS- 002767	5/10/2018	5/10/2019	2	Cooler	In gym High Right	WF-05102018-002767	12/9/2018	FT-FY19-112018-002767-A	<1	FT-FY19-112018-002767-B	<1
WS- 002768	5/10/2018	5/10/2019	2	Cooler	In hallway adjacent to room 206 Low Left	WF-05102018-002768	12/9/2018	FT-FY19-112018-002768-A	<1	FT-FY19-112018-002768-B	<1
WS- 002769	5/10/2018	5/10/2019	2	Cooler	In hallway adjacent to room 206 High Right	WF-05102018-002769	12/9/2018	FT-FY19-112018-002769-A	<1	FT-FY19-112018-002769-B	<1
WS- 002770	5/10/2018	5/10/2019	2	Break Room	In staff lounge 208	WF-05102018-002770	12/9/2018	FT-FY19-112018-002770-A	<1	FT-FY19-112018-002770-B	<1
WS- 002771	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 210	WF-10012018-002771	12/9/2018	FT-FY19-112018-002771-A	<1	FT-FY19-112018-002771-B	<1
WS- 002772	5/10/2018	5/10/2019	2	Combo Fountain	In classroom 210	WF-05102018-002772	12/9/2018	FT-FY19-112018-002772-A	<1	FT-FY19-112018-002772-B	<1
WS- 002773	10/1/2018	10/1/2019	2	Combo Faucet	In classroom 211	WF-10012018-002773	12/9/2018	FT-FY19-112018-002773-A	<1	FT-FY19-112018-002773-B	<1
WS- 002774	5/10/2018	5/10/2019	2	Combo Fountain	In classroom 211	WF-05102018-002774	12/9/2018	FT-FY19-112018-002774-A	<1	FT-FY19-112018-002774-B	<1
WS- 002775	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 316	WF-10012018-002775	12/9/2018	FT-FY19-112018-002775-A	<1	FT-FY19-112018-002775-B	<1
WS- 002776	5/10/2018	5/10/2019	3	Combo Fountain	In classroom 316	WF-05102018-002776	12/9/2018	FT-FY19-112018-002776-A	<1	FT-FY19-112018-002776-B	<1
WS- 002777	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 313	WF-10012018-002777	12/9/2018	FT-FY19-112018-002777-A	<1	FT-FY19-112018-002777-B	<1
WS- 002778	5/10/2018	5/10/2019	3	Combo Fountain	In classroom 313	WF-05102018-002778	12/9/2018	FT-FY19-112018-002778-A	<1	FT-FY19-112018-002778-B	<1
WS- 002779	5/10/2018	5/10/2019	3	Cooler	In hallway across from room 312 High Right	WF-05102018-002779	12/9/2018	FT-FY19-112018-002779-A	<1	FT-FY19-112018-002779-B	<1
WS- 002780	5/10/2018	5/10/2019	3	Cooler	In hallway across from room 312 Low Left	WF-05102018-002780	12/9/2018	FT-FY19-112018-002780-A	<1	FT-FY19-112018-002780-B	<1
WS- 002781	5/10/2018	5/10/2019	3	Combo Fountain	In classroom 309	WF-05102018-002781	12/9/2018	FT-FY19-112018-002781-A	<1	FT-FY19-112018-002781-B	<1
WS- 002782	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 309	WF-10012018-002782	12/9/2018	FT-FY19-112018-002782-A	<1	FT-FY19-112018-002782-B	<1
WS- 002783	5/10/2018	5/10/2019	3	Combo Fountain	In classroom 308	WF-05102018-002783	12/9/2018	FT-FY19-112018-002783-A	<1	FT-FY19-112018-002783-B	<1
WS- 002784	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 308	WF-10012018-002784	12/9/2018	FT-FY19-112018-002784-A	<1	FT-FY19-112018-002784-B	<1
WS- 002785	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 304	WF-10012018-002785	12/9/2018	FT-FY19-112018-002785-A	<1	FT-FY19-112018-002785-B	<1

WS- 002786	5/10/2018	5/10/2019	3	Combo Fountain	In classroom 304			WF-05102018-002786	12/9/2018	FT-FY19-112018-002786-A	<1	FT-FY19-112018-002786-B	<1
WS- 002787	10/1/2018	10/1/2019	3	Combo Faucet	In classroom 301			WF-10012018-002787	12/9/2018	FT-FY19-112018-002787-A	<1	FT-FY19-112018-002787-B	<1
WS- 002788	5/10/2018	5/10/2019	3	Combo Fountain	In classroom 301			WF-05102018-002788	12/9/2018	FT-FY19-112018-002788-A	<1	FT-FY19-112018-002788-B	<1
WS- 002789	10/1/2018	10/1/2019	4	Combo Faucet	In classroom 401			WF-10012018-002789	12/9/2018	FT-FY19-112018-002789-A	<1	FT-FY19-112018-002789-B	<1
WS- 002790	5/10/2018	5/10/2019	4	Combo Fountain	In classroom 401			WF-05102018-002790	12/9/2018	FT-FY19-112018-002790-A	<1	FT-FY19-112018-002790-B	<1
WS- 002791	10/1/2018	10/1/2019	4	Combo Faucet	In classroom 405			WF-10012018-002791	12/9/2018	FT-FY19-112018-002791-A	<1	FT-FY19-112018-002791-B	<1
WS- 002792	5/10/2018	5/10/2019	4	Combo Fountain	In classroom 405			WF-05102018-002792	12/9/2018	FT-FY19-112018-002792-A	<1	FT-FY19-112018-002792-B	<1
WS- 002793	10/1/2018	10/1/2019	4	Combo Faucet	In classroom 407			WF-10012018-002793	12/9/2018	FT-FY19-112018-002793-A	<1	FT-FY19-112018-002793-B	<1
WS- 002794	5/10/2018	5/10/2019	4	Combo Fountain	In classroom 407			WF-05102018-002794	12/9/2018	FT-FY19-112018-002794-A	<1	FT-FY19-112018-002794-B	<1
WS- 002795	5/10/2018	5/10/2019	4	Cooler	In hallway adjacent to room 408	High	Right	WF-05102018-002795	12/9/2018	FT-FY19-112018-002795-A	<1	FT-FY19-112018-002795-B	<1
WS- 002796	5/10/2018	5/10/2019	4	Cooler	In hallway adjacent to room 408	Low	Left	WF-05102018-002796	12/9/2018	FT-FY19-112018-002796-A	<1	FT-FY19-112018-002796-B	<1
WS- 002797	10/1/2018	10/1/2019	4	Combo Faucet	In classroom 410			WF-10012018-002797	12/9/2018	FT-FY19-112018-002797-A	<1	FT-FY19-112018-002797-B	<1
WS- 002798	5/10/2018	5/10/2019	4	Combo Fountain	In classroom 410			WF-05102018-002798	12/9/2018	FT-FY19-112018-002798-A	<1	FT-FY19-112018-002798-B	<1
WS- 004808	10/1/2018	10/1/2019	4	Combo Faucet	In classroom 412			WF-10012018-004808	12/9/2018	FT-FY19-112018-004808-A	<1	FT-FY19-112018-004808-B	<1
WS- 004809	5/10/2018	5/10/2019	4	Combo Fountain	In classroom 412			WF-05102018-004809	12/9/2018	FT-FY19-112018-004809-A	<1	FT-FY19-112018-004809-B	<1
WS- 004810	10/1/2018	10/1/2019	4	Combo Faucet	In classroom 415			WF-10012018-004810	12/9/2018	FT-FY19-112018-004810-A	<1	FT-FY19-112018-004810-B	<1
WS- 004811	5/10/2018	5/10/2019	4	Combo Fountain	In classroom 415			WF-05102018-004811	12/9/2018	FT-FY19-112018-004811-A	<1	FT-FY19-112018-004811-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location		Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002754	1	Food Prep Sink	In kitchen	Right	12/9/2018	FT-FY19-112018-002754-A	<1	FT-FY19-112018-002754-B	<1