Palisades CC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004276	6/4/2021	6/4/2022	Ground Floor	Bottle Filler	In hallway next to boys and girls restroom	WF-06042021-004276	2/4/2022	FT-FY22-01182022-004276-A	<1	FT-FY22-01182022-004276-B	<1
WS- 004277	6/4/2021	6/4/2022	Ground Floor	Cooler	In hallway next to boys and girls restroom High Left	WF-06042021-004277	2/4/2022	FT-FY22-01182022-004277-A	<1	FT-FY22-01182022-004277-B	<1
WS- 004278	6/4/2021	6/4/2022	Ground Floor	Cooler	In hallway next to boys and girls restroom Low Right	WF-06042021-004278	2/4/2022	FT-FY22-01182022-004278-A	<1	FT-FY22-01182022-004278-B	<1
WS- 004279	2/23/2021	2/23/2022	Ground Floor	Food Prep Sink	In kitchen	WF-02232021-004279	2/4/2022	FT-FY22-01182022-004279-A	<1	FT-FY22-01182022-004279-B	<1
WS- 004280	6/4/2021	6/4/2022	Ground Floor	Break Room	In break room	WF-06042021-004280	2/4/2022	FT-FY22-01182022-004280-A	<1	FT-FY22-01182022-004280-B	<1