Palisades CC Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004279	12/2/2025	12/2/2026	Ground Floor	Food Prep Sink	In kitchen	WF-12022025-004279	3/12/2026	FT-FY26-01282026-004279-A	<2	FT-FY26-01282026-004279-B	<2
WS- 004280	4/3/2025	4/3/2026	Ground Floor	Classroom Faucet	In break room / classroom / kitchen	WF-04032025-004280	3/12/2026	FT-FY26-01282026-004280-A	<2	FT-FY26-01282026-004280-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.