



PALISADES COM LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	PALISADES COMMUNITY CENTER	WS- 003824	9/21/2016	1	Cooler	In hallway adjacent to main office	FT-82016-003824-A	< 1	FT-82016-003824-B	< 1