



PARKVIEW ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	PARKVIEW ELEMENTARY SCHOOL	WS- 003661	8/12/2016	Ground Floor	Food Prep Sink	In kitchen	FT-82016-003661-A	< 1	FT-82016-003661-B	< 1
2	PARKVIEW ELEMENTARY SCHOOL	WS- 003662	8/12/2016	Ground Floor	Cooler	In classroom 007	FT-82016-003662-A	< 1	FT-82016-003662-B	< 1
3	PARKVIEW ELEMENTARY SCHOOL	WS- 003663	8/12/2016	Ground Floor	Cooler	In classroom 006	FT-72016-003663-A	< 1	FT-72016-003663-B	< 1
4	PARKVIEW ELEMENTARY SCHOOL	WS- 003664	8/12/2016	Ground Floor	Cooler	In classroom 008	FT-72016-003664-A	< 1	FT-72016-003664-B	< 1
5	PARKVIEW ELEMENTARY SCHOOL	WS- 003665	8/12/2016	Ground Floor	Cooler	In hallway 037	FT-72016-003665-A	< 1	FT-72016-003665-B	< 1
6	PARKVIEW ELEMENTARY SCHOOL	WS- 003666	8/12/2016	Ground Floor	Cooler	In classroom 021	FT-72016-003666-A	< 1	FT-72016-003666-B	< 1
7	PARKVIEW ELEMENTARY SCHOOL	WS- 003667	8/12/2016	Ground Floor	Cooler	In classroom 022	FT-72016-003667-A	< 1	FT-72016-003667-B	< 1
8	PARKVIEW ELEMENTARY SCHOOL	WS- 003668	8/12/2016	Ground Floor	Cooler	In classroom 024	FT-72016-003668-A	< 1	FT-72016-003668-B	< 1
9	PARKVIEW ELEMENTARY SCHOOL	WS- 003669	8/12/2016	Ground Floor	Cooler	In hallway 049 adjacent to gym stairwell	FT-82016-003669-A	< 1	FT-82016-003669-B	< 1
10	PARKVIEW ELEMENTARY SCHOOL	WS- 003670	8/12/2016	1	Cooler	In hallway 156 adjacent to restroom	FT-82016-003670-A	< 1	FT-82016-003670-B	< 1
11	PARKVIEW ELEMENTARY SCHOOL	WS- 003671	8/12/2016	1	Cooler	In classroom 126	FT-82016-003671-A	< 1	FT-82016-003671-B	< 1
12	PARKVIEW ELEMENTARY SCHOOL	WS- 003672	8/12/2016	1	Cooler	In classroom 127	FT-82016-003672-A	< 1	FT-82016-003672-B	< 1
13	PARKVIEW ELEMENTARY SCHOOL	WS- 003673	8/12/2016	1	Cooler	In classroom 123	FT-72016-003673-A	< 1	FT-72016-003673-B	< 1
14	PARKVIEW ELEMENTARY SCHOOL	WS- 003674	8/12/2016	1	Cooler	In classroom 122	FT-72016-003674-A	< 1	FT-72016-003674-B	< 1
15	PARKVIEW ELEMENTARY SCHOOL	WS- 003675	8/12/2016	1	Cooler	In hallway 144	FT-82016-003675-A	< 1	FT-82016-003675-B	< 1
16	PARKVIEW ELEMENTARY SCHOOL	WS- 003676	8/12/2016	1	Health Suite	In health suite	FT-82016-003676-A	< 1	FT-82016-003676-B	< 1
17	PARKVIEW ELEMENTARY SCHOOL	WS- 003679	8/12/2016	1	Cooler	In hallway 151 adjacent to restroom	FT-82016-003679-A	< 1	FT-82016-003679-B	< 1
18	PARKVIEW ELEMENTARY SCHOOL	WS- 003680	8/12/2016	2	Cooler	In hallway 234 adjacent to restroom	FT-82016-003680-A	< 1	FT-82016-003680-B	< 1
19	PARKVIEW ELEMENTARY SCHOOL	WS- 003681	8/12/2016	2	Cooler	In hallway 229 adjacent to library	FT-82016-003681-A	1.3	FT-82016-003681-B	< 1
20	PARKVIEW ELEMENTARY SCHOOL	WS- 003682	8/12/2016	2	Cooler	In hallway 240 adjacent to restroom	FT-82016-003682-A	< 1	FT-82016-003682-B	< 1