



Patterson Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003093	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 132	WF-05262020-003093	2/5/2021	FT-FY21-012021-003093-A	<1	FT-FY21-012021-003093-B	<1	
WS-003095	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 131	WF-05262020-003095	2/5/2021	FT-FY21-012021-003095-A	<1	FT-FY21-012021-003095-B	<1	
WS-003097	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 127	WF-05262020-003097	2/5/2021	FT-FY21-012021-003097-A	<1	FT-FY21-012021-003097-B	<1	
WS-003099	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 125	WF-05262020-003099	2/5/2021	FT-FY21-012021-003099-A	<1	FT-FY21-012021-003099-B	<1	
WS-003102	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 115	WF-05262020-003102	2/5/2021	FT-FY21-012021-003102-A	<1	FT-FY21-012021-003102-B	<1	
WS-003103	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 123	WF-09282020-003103	2/5/2021	FT-FY21-012021-003103-A	<1	FT-FY21-012021-003103-B	<1	
WS-003104	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 123	WF-05262020-003104	2/5/2021	FT-FY21-012021-003104-A	<1	FT-FY21-012021-003104-B	<1	
WS-003106	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 119	WF-05262020-003106	2/5/2021	FT-FY21-012021-003106-A	<1	FT-FY21-012021-003106-B	<1	
WS-003108	5/26/2020	5/26/2021	1	Combo Fountain	In classroom 120	WF-05262020-003108	2/5/2021	FT-FY21-012021-003108-A	<1	FT-FY21-012021-003108-B	<1	
WS-003109	5/26/2020	5/26/2021	1	Cooler	In hallway adjacent to restrooms	High Left	WF-05262020-003109	2/5/2021	FT-FY21-012021-003109-A	<1	FT-FY21-012021-003109-B	<1
WS-003110	5/26/2020	5/26/2021	1	Cooler	In hallway adjacent to restrooms	Low Right	WF-05262020-003110	2/5/2021	FT-FY21-012021-003110-A	<1	FT-FY21-012021-003110-B	<1
WS-003112	5/26/2020	5/26/2021	1	Cooler	In cafeteria 106	High Left	WF-05262020-003112	2/5/2021	FT-FY21-012021-003112-A	<1	FT-FY21-012021-003112-B	<1
WS-003113	5/26/2020	5/26/2021	1	Cooler	In cafeteria 106	Low Right	WF-05262020-003113	2/5/2021	FT-FY21-012021-003113-A	<1	FT-FY21-012021-003113-B	<1
WS-003117	5/26/2020	5/26/2021	2	Cooler	In hallway adjacent to restrooms	High Left	WF-05262020-003117	2/5/2021	FT-FY21-012021-003117-A	<1	FT-FY21-012021-003117-B	<1
WS-003118	5/26/2020	5/26/2021	2	Cooler	In hallway adjacent to restrooms	Low Right	WF-05262020-003118	2/5/2021	FT-FY21-012021-003118-A	<1	FT-FY21-012021-003118-B	<1
WS-003119	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 223	WF-09282020-003119	2/5/2021	FT-FY21-012021-003119-A	<1	FT-FY21-012021-003119-B	<1	
WS-003120	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 223	WF-05262020-003120	2/5/2021	FT-FY21-012021-003120-A	<1	FT-FY21-012021-003120-B	<1	
WS-003122	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 222	WF-05262020-003122	2/5/2021	FT-FY21-012021-003122-A	<1	FT-FY21-012021-003122-B	<1	
WS-003124	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 224	WF-05262020-003124	2/5/2021	FT-FY21-012021-003124-A	<1	FT-FY21-012021-003124-B	<1	
WS-003126	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 221	WF-05262020-003126	2/5/2021	FT-FY21-012021-003126-A	<1	FT-FY21-012021-003126-B	<1	
WS-003127	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 220	WF-09282020-003127	2/5/2021	FT-FY21-012021-003127-A	<1	FT-FY21-012021-003127-B	<1	
WS-003128	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 220	WF-05262020-003128	2/5/2021	FT-FY21-012021-003128-A	<1	FT-FY21-012021-003128-B	<1	
WS-003129	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 225	WF-09282020-003129	2/5/2021	FT-FY21-012021-003129-A	<1	FT-FY21-012021-003129-B	<1	
WS-003130	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 225	WF-05262020-003130	2/5/2021	FT-FY21-012021-003130-A	<1	FT-FY21-012021-003130-B	<1	
WS-003131	5/26/2020	5/26/2021	2	Break Room	In staff work room 219	WF-05262020-003131	2/5/2021	FT-FY21-012021-003131-A	<1	FT-FY21-012021-003131-B	<1	
WS-003132	5/26/2020	5/26/2021	2	Break Room	In staff work room 227	WF-05262020-003132	2/5/2021	FT-FY21-012021-003132-A	<1	FT-FY21-012021-003132-B	<1	
WS-003133	5/26/2020	5/26/2021	2	Combo Fountain	In staff work room 227	WF-05262020-003133	2/5/2021	FT-FY21-012021-003133-A	<1	FT-FY21-012021-003133-B	<1	
WS-003135	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 218	WF-05262020-003135	2/5/2021	FT-FY21-012021-003135-A	<1	FT-FY21-012021-003135-B	<1	
WS-003137	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 226	WF-05262020-003137	2/5/2021	FT-FY21-012021-003137-A	<1	FT-FY21-012021-003137-B	<1	
WS-003138	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 213	WF-09282020-003138	2/5/2021	FT-FY21-012021-003138-A	<1	FT-FY21-012021-003138-B	<1	
WS-003139	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 213	WF-05262020-003139	2/5/2021	FT-FY21-012021-003139-A	<1	FT-FY21-012021-003139-B	<1	
WS-003140	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 216	WF-09282020-003140	2/5/2021	FT-FY21-012021-003140-A	<1	FT-FY21-012021-003140-B	<1	

WS- 003141	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 216		WF-05262020-003141	2/5/2021	FT-FY21-012021-003141-A	<1	FT-FY21-012021-003141-B	<1
WS- 003142	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 215		WF-09282020-003142	2/5/2021	FT-FY21-012021-003142-A	<1	FT-FY21-012021-003142-B	<1
WS- 003143	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 215		WF-05262020-003143	2/5/2021	FT-FY21-012021-003143-A	<1	FT-FY21-012021-003143-B	<1
WS- 003144	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 214		WF-09282020-003144	2/5/2021	FT-FY21-012021-003144-A	<1	FT-FY21-012021-003144-B	<1
WS- 003145	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 214		WF-05262020-003145	2/5/2021	FT-FY21-012021-003145-A	<1	FT-FY21-012021-003145-B	<1
WS- 003147	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 232		WF-09282020-003147	2/5/2021	FT-FY21-012021-003147-A	<1	FT-FY21-012021-003147-B	<1
WS- 003148	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 232		WF-05262020-003148	2/5/2021	FT-FY21-012021-003148-A	<1	FT-FY21-012021-003148-B	<1
WS- 003149	9/28/2020	9/28/2021	2	Combo Faucet	In classroom 230		WF-09282020-003149	2/5/2021	FT-FY21-012021-003149-A	<1	FT-FY21-012021-003149-B	<1
WS- 003150	5/26/2020	5/26/2021	2	Combo Fountain	In classroom 230		WF-05262020-003150	2/5/2021	FT-FY21-012021-003150-A	<1	FT-FY21-012021-003150-B	<1
WS- 003152	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 323		WF-05262020-003152	2/5/2021	FT-FY21-012021-003152-A	<1	FT-FY21-012021-003152-B	<1
WS- 003154	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 324		WF-05262020-003154	2/5/2021	FT-FY21-012021-003154-A	<1	FT-FY21-012021-003154-B	<1
WS- 003156	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 321		WF-05262020-003156	2/5/2021	FT-FY21-012021-003156-A	<1	FT-FY21-012021-003156-B	<1
WS- 003159	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 317		WF-05262020-003159	2/5/2021	FT-FY21-012021-003159-A	<1	FT-FY21-012021-003159-B	<1
WS- 003161	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 307		WF-05262020-003161	2/5/2021	FT-FY21-012021-003161-A	<1	FT-FY21-012021-003161-B	<1
WS- 003163	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 316		WF-05262020-003163	2/5/2021	FT-FY21-012021-003163-A	<1	FT-FY21-012021-003163-B	<1
WS- 003165	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 312		WF-05262020-003165	2/5/2021	FT-FY21-012021-003165-A	<1	FT-FY21-012021-003165-B	<1
WS- 003167	5/26/2020	5/26/2021	3	Combo Fountain	In classroom 311		WF-05262020-003167	2/5/2021	FT-FY21-012021-003167-A	<1	FT-FY21-012021-003167-B	<1
WS- 003168	5/26/2020	5/26/2021	3	Cooler	In hallway adjacent to room 302	High Left	WF-05262020-003168	2/5/2021	FT-FY21-012021-003168-A	<1	FT-FY21-012021-003168-B	<1
WS- 003169	5/26/2020	5/26/2021	3	Cooler	In hallway adjacent to room 302	Low Right	WF-05262020-003169	2/5/2021	FT-FY21-012021-003169-A	<1	FT-FY21-012021-003169-B	<1
WS- 003170	5/26/2020	5/26/2021	1	Break Room	In custodians' break room 103		WF-05262020-003170	2/5/2021	FT-FY21-012021-003170-A	<1	FT-FY21-012021-003170-B	<1
WS- 003171	5/26/2020	5/26/2021	2	Health Suite	In health suite 201		WF-05262020-003171	2/5/2021	FT-FY21-012021-003171-A	<1	FT-FY21-012021-003171-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003115	2/20/2020	2/20/2021	1	Food Prep Sink	In kitchen	Mid	WF-02202020-003115	2/5/2021	FT-FY21-012021-003115-A	<1	FT-FY21-012021-003115-B	<1
WS- 003116	2/20/2020	2/20/2021	1	Food Prep Sink	In kitchen	Right	WF-02202020-003116	2/5/2021	FT-FY21-012021-003116-A	<1	FT-FY21-012021-003116-B	<1