



# Patterson ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003093	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 132	WF-06032019-003093	11/8/2019	FT-FY20-102019-003093-A	<1	FT-FY20-102019-003093-B	<1
WS- 003095	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 131	WF-06032019-003095	11/8/2019	FT-FY20-102019-003095-A	<1	FT-FY20-102019-003095-B	<1
WS- 003097	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 127	WF-06032019-003097	11/8/2019	FT-FY20-102019-003097-A	<1	FT-FY20-102019-003097-B	<1
WS- 003099	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 125	WF-06032019-003099	11/8/2019	FT-FY20-102019-003099-A	<1	FT-FY20-102019-003099-B	<1
WS- 003102	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 115	WF-06032019-003102	11/8/2019	FT-FY20-102019-003102-A	<1	FT-FY20-102019-003102-B	<1
WS- 003103	10/7/2019	10/7/2020	1	Combo Faucet	In classroom 123	WF-10072019-003103	11/8/2019	FT-FY20-102019-003103-A	<1	FT-FY20-102019-003103-B	<1
WS- 003104	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 123	WF-06032019-003104	11/8/2019	FT-FY20-102019-003104-A	<1	FT-FY20-102019-003104-B	<1
WS- 003106	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 119	WF-06032019-003106	11/8/2019	FT-FY20-102019-003106-A	<1	FT-FY20-102019-003106-B	<1
WS- 003108	6/3/2019	6/3/2020	1	Combo Fountain	In classroom 120	WF-06032019-003108	11/8/2019	FT-FY20-102019-003108-A	<1	FT-FY20-102019-003108-B	<1
WS- 003109	6/3/2019	6/3/2020	1	Cooler	In hallway adjacent to restrooms High Left	WF-06032019-003109	11/8/2019	FT-FY20-102019-003109-A	<1	FT-FY20-102019-003109-B	<1
WS- 003110	6/3/2019	6/3/2020	1	Cooler	In hallway adjacent to restrooms Low Right	WF-06032019-003110	11/8/2019	FT-FY20-102019-003110-A	<1	FT-FY20-102019-003110-B	<1
WS- 003112	6/3/2019	6/3/2020	1	Cooler	In cafeteria 106 High Left	WF-06032019-003112	11/8/2019	FT-FY20-102019-003112-A	<1	FT-FY20-102019-003112-B	<1
WS- 003113	6/3/2019	6/3/2020	1	Cooler	In cafeteria 106 Low Right	WF-06032019-003113	11/8/2019	FT-FY20-102019-003113-A	<1	FT-FY20-102019-003113-B	<1
WS- 003117	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to restrooms High Left	WF-06032019-003117	11/8/2019	FT-FY20-102019-003117-A	<1	FT-FY20-102019-003117-B	<1
WS- 003118	6/3/2019	6/3/2020	2	Cooler	In hallway adjacent to restrooms Low Right	WF-06032019-003118	11/8/2019	FT-FY20-102019-003118-A	<1	FT-FY20-102019-003118-B	<1
WS- 003119	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 223	WF-10072019-003119	11/8/2019	FT-FY20-102019-003119-A	<1	FT-FY20-102019-003119-B	<1
WS- 003120	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 223	WF-06032019-003120	11/8/2019	FT-FY20-102019-003120-A	<1	FT-FY20-102019-003120-B	<1
WS- 003122	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 222	WF-06032019-003122	11/8/2019	FT-FY20-102019-003122-A	<1	FT-FY20-102019-003122-B	<1
WS- 003124	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 224	WF-06032019-003124	11/8/2019	FT-FY20-102019-003124-A	<1	FT-FY20-102019-003124-B	<1
WS- 003126	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 221	WF-06032019-003126	11/8/2019	FT-FY20-102019-003126-A	<1	FT-FY20-102019-003126-B	<1
WS- 003127	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 220	WF-10072019-003127	11/8/2019	FT-FY20-102019-003127-A	<1	FT-FY20-102019-003127-B	<1
WS- 003128	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 220	WF-06032019-003128	11/8/2019	FT-FY20-102019-003128-A	<1	FT-FY20-102019-003128-B	<1
WS- 003129	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 225	WF-10072019-003129	11/8/2019	FT-FY20-102019-003129-A	<1	FT-FY20-102019-003129-B	<1
WS- 003130	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 225	WF-06032019-003130	11/8/2019	FT-FY20-102019-003130-A	<1	FT-FY20-102019-003130-B	<1
WS- 003131	6/3/2019	6/3/2020	2	Break Room	In staff work room 219	WF-06032019-003131	11/8/2019	FT-FY20-102019-003131-A	<1	FT-FY20-102019-003131-B	<1
WS- 003132	6/3/2019	6/3/2020	2	Break Room	In staff work room 227	WF-06032019-003132	11/8/2019	FT-FY20-102019-003132-A	<1	FT-FY20-102019-003132-B	<1
WS- 003133	6/3/2019	6/3/2020	2	Combo Fountain	In staff work room 227	WF-06032019-003133	11/8/2019	FT-FY20-102019-003133-A	<1	FT-FY20-102019-003133-B	<1
WS- 003135	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 218	WF-06032019-003135	11/8/2019	FT-FY20-102019-003135-A	<1	FT-FY20-102019-003135-B	<1
WS- 003137	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 226	WF-06032019-003137	11/8/2019	FT-FY20-102019-003137-A	<1	FT-FY20-102019-003137-B	<1
WS- 003138	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 213	WF-10072019-003138	11/8/2019	FT-FY20-102019-003138-A	<1	FT-FY20-102019-003138-B	<1
WS- 003139	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 213	WF-06032019-003139	11/8/2019	FT-FY20-102019-003139-A	<1	FT-FY20-102019-003139-B	<1
WS- 003140	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 216	WF-10072019-003140	11/8/2019	FT-FY20-102019-003140-A	<1	FT-FY20-102019-003140-B	<1

WS-003141	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 216		WF-06032019-003141	11/8/2019	FT-FY20-102019-003141-A	<1	FT-FY20-102019-003141-B	<1
WS-003142	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 215		WF-10072019-003142	11/8/2019	FT-FY20-102019-003142-A	<1	FT-FY20-102019-003142-B	<1
WS-003143	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 215		WF-06032019-003143	11/8/2019	FT-FY20-102019-003143-A	<1	FT-FY20-102019-003143-B	<1
WS-003144	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 214		WF-10072019-003144	11/8/2019	FT-FY20-102019-003144-A	<1	FT-FY20-102019-003144-B	<1
WS-003145	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 214		WF-06032019-003145	11/8/2019	FT-FY20-102019-003145-A	<1	FT-FY20-102019-003145-B	<1
WS-003147	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 232		WF-10072019-003147	11/8/2019	FT-FY20-102019-003147-A	<1	FT-FY20-102019-003147-B	<1
WS-003148	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 232		WF-06032019-003148	11/8/2019	FT-FY20-102019-003148-A	1.6	FT-FY20-102019-003148-B	<1
WS-003149	10/7/2019	10/7/2020	2	Combo Faucet	In classroom 230		WF-10072019-003149	11/8/2019	FT-FY20-102019-003149-A	<1	FT-FY20-102019-003149-B	<1
WS-003150	6/3/2019	6/3/2020	2	Combo Fountain	In classroom 230		WF-06032019-003150	11/8/2019	FT-FY20-102019-003150-A	<1	FT-FY20-102019-003150-B	<1
WS-003152	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 323		WF-06032019-003152	11/8/2019	FT-FY20-102019-003152-A	<1	FT-FY20-102019-003152-B	<1
WS-003154	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 324		WF-06032019-003154	11/8/2019	FT-FY20-102019-003154-A	<1	FT-FY20-102019-003154-B	<1
WS-003156	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 321		WF-06032019-003156	11/8/2019	FT-FY20-102019-003156-A	<1	FT-FY20-102019-003156-B	<1
WS-003159	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 317		WF-06032019-003159	11/8/2019	FT-FY20-102019-003159-A	<1	FT-FY20-102019-003159-B	<1
WS-003161	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 307		WF-06032019-003161	11/8/2019	FT-FY20-102019-003161-A	<1	FT-FY20-102019-003161-B	<1
WS-003163	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 316		WF-06032019-003163	11/8/2019	FT-FY20-102019-003163-A	<1	FT-FY20-102019-003163-B	<1
WS-003165	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 312		WF-06032019-003165	11/8/2019	FT-FY20-102019-003165-A	<1	FT-FY20-102019-003165-B	<1
WS-003167	6/3/2019	6/3/2020	3	Combo Fountain	In classroom 311		WF-06032019-003167	11/8/2019	FT-FY20-102019-003167-A	<1	FT-FY20-102019-003167-B	<1
WS-003168	6/3/2019	6/3/2020	3	Cooler	In hallway adjacent to room 302	High Left	WF-06032019-003168	11/8/2019	FT-FY20-102019-003168-A	<1	FT-FY20-102019-003168-B	<1
WS-003169	6/3/2019	6/3/2020	3	Cooler	In hallway adjacent to room 302	Low Right	WF-06032019-003169	11/8/2019	FT-FY20-102019-003169-A	<1	FT-FY20-102019-003169-B	<1
WS-003170	6/3/2019	6/3/2020	1	Break Room	In custodians' break room 103		WF-06032019-003170	11/8/2019	FT-FY20-102019-003170-A	<1	FT-FY20-102019-003170-B	<1
WS-003171	6/3/2019	6/3/2020	2	Health Suite	In health suite 201		WF-06032019-003171	11/8/2019	FT-FY20-102019-003171-A	<1	FT-FY20-102019-003171-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003115	7/10/2019	7/10/2020	1	Food Prep Sink	In kitchen	Mid	WF-07102019-003115	11/8/2019	FT-FY20-102019-003115-A	<1	FT-FY20-102019-003115-B	<1
WS-003116	7/10/2019	7/10/2020	1	Food Prep Sink	In kitchen	Right	WF-07102019-003116	11/8/2019	FT-FY20-102019-003116-A	<1	FT-FY20-102019-003116-B	<1