



Patterson Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003093	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 132	WF-04112023-003093	12/4/2023	FT-FY24-10102023-003093-A	<1	FT-FY24-10102023-003093-B	<1	
WS- 003095	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 131	WF-04112023-003095	12/4/2023	FT-FY24-10102023-003095-A	<1	FT-FY24-10102023-003095-B	<1	
WS- 003097	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 127	WF-04112023-003097	12/4/2023	FT-FY24-10102023-003097-A	<1	FT-FY24-10102023-003097-B	<1	
WS- 003099	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 125	WF-04112023-003099	12/4/2023	FT-FY24-10102023-003099-A	<1	FT-FY24-10102023-003099-B	<1	
WS- 003102	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 115	WF-04112023-003102	12/4/2023	FT-FY24-10102023-003102-A	<1	FT-FY24-10102023-003102-B	<1	
WS- 003103	9/8/2023	9/8/2024	1	Combo Faucet	In classroom 123	WF-09082023-003103	12/4/2023	FT-FY24-10102023-003103-A	<1	FT-FY24-10102023-003103-B	<1	
WS- 003104	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 123	WF-04112023-003104	12/4/2023	FT-FY24-10102023-003104-A	<1	FT-FY24-10102023-003104-B	<1	
WS- 003106	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 119	WF-04112023-003106	12/4/2023	FT-FY24-10102023-003106-A	<1	FT-FY24-10102023-003106-B	<1	
WS- 003108	4/11/2023	4/11/2024	1	Combo Fountain	In classroom 120	WF-04112023-003108	12/4/2023	FT-FY24-10102023-003108-A	<1	FT-FY24-10102023-003108-B	<1	
WS- 003109	4/11/2023	4/11/2024	1	Cooler	In hallway adjacent to restrooms	High Left	WF-04112023-003109	12/4/2023	FT-FY24-10102023-003109-A	<1	FT-FY24-10102023-003109-B	<1
WS- 003112	4/11/2023	4/11/2024	1	Cooler	In cafeteria 106	High Left	WF-04112023-003112	12/4/2023	FT-FY24-10102023-003112-A	<1	FT-FY24-10102023-003112-B	<1
WS- 003113	4/11/2023	4/11/2024	1	Cooler	In cafeteria 106	Low Right	WF-04112023-003113	12/4/2023	FT-FY24-10102023-003113-A	<1	FT-FY24-10102023-003113-B	<1
WS- 003117	4/11/2023	4/11/2024	2	Cooler	In hallway adjacent to restrooms	High Left	WF-04112023-003117	12/4/2023	FT-FY24-10102023-003117-A	<1	FT-FY24-10102023-003117-B	<1
WS- 003118	4/11/2023	4/11/2024	2	Cooler	In hallway adjacent to restrooms	Low Right	WF-04112023-003118	12/4/2023	FT-FY24-10102023-003118-A	<1	FT-FY24-10102023-003118-B	<1
WS- 003119	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 223	WF-09082023-003119	12/4/2023	FT-FY24-10102023-003119-A	<1	FT-FY24-10102023-003119-B	<1	
WS- 003120	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 223	WF-04112023-003120	12/4/2023	FT-FY24-10102023-003120-A	<1	FT-FY24-10102023-003120-B	<1	
WS- 003122	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 222	WF-04112023-003122	12/4/2023	FT-FY24-10102023-003122-A	<1	FT-FY24-10102023-003122-B	<1	
WS- 003124	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 224	WF-04112023-003124	12/4/2023	FT-FY24-10102023-003124-A	<1	FT-FY24-10102023-003124-B	<1	
WS- 003126	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 221	WF-04112023-003126	12/4/2023	FT-FY24-10102023-003126-A	<1	FT-FY24-10102023-003126-B	<1	
WS- 003127	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 220	WF-09082023-003127	12/4/2023	FT-FY24-10102023-003127-A	<1	FT-FY24-10102023-003127-B	<1	
WS- 003128	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 220	WF-04112023-003128	12/4/2023	FT-FY24-10102023-003128-A	<1	FT-FY24-10102023-003128-B	<1	
WS- 003129	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 225	WF-09082023-003129	12/4/2023	FT-FY24-10102023-003129-A	<1	FT-FY24-10102023-003129-B	<1	
WS- 003130	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 225	WF-04112023-003130	12/4/2023	FT-FY24-10102023-003130-A	<1	FT-FY24-10102023-003130-B	<1	
WS- 003131	4/11/2023	4/11/2024	2	Break Room	In staff work room 219	WF-04112023-003131	12/4/2023	FT-FY24-10102023-003131-A	<1	FT-FY24-10102023-003131-B	<1	
WS- 003135	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 218	WF-04112023-003135	12/4/2023	FT-FY24-10102023-003135-A	<1	FT-FY24-10102023-003135-B	<1	
WS- 003137	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 226	WF-04112023-003137	12/4/2023	FT-FY24-10102023-003137-A	<1	FT-FY24-10102023-003137-B	<1	
WS- 003138	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 213	WF-09082023-003138	12/4/2023	FT-FY24-10102023-003138-A	<1	FT-FY24-10102023-003138-B	<1	
WS- 003139	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 213	WF-04112023-003139	12/4/2023	FT-FY24-10102023-003139-A	<1	FT-FY24-10102023-003139-B	<1	
WS- 003140	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 216	WF-09082023-003140	12/4/2023	FT-FY24-10102023-003140-A	<1	FT-FY24-10102023-003140-B	<1	
WS- 003141	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 216	WF-04112023-003141	12/4/2023	FT-FY24-10102023-003141-A	<1	FT-FY24-10102023-003141-B	<1	
WS- 003142	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 215	WF-09082023-003142	12/4/2023	FT-FY24-10102023-003142-A	<1	FT-FY24-10102023-003142-B	<1	
WS- 003143	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 215	WF-04112023-003143	12/4/2023	FT-FY24-10102023-003143-A	<1	FT-FY24-10102023-003143-B	<1	
WS- 003144	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 214	WF-09082023-003144	12/4/2023	FT-FY24-10102023-003144-A	<1	FT-FY24-10102023-003144-B	<1	
WS- 003145	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 214	WF-04112023-003145	12/4/2023	FT-FY24-10102023-003145-A	<1	FT-FY24-10102023-003145-B	<1	
WS- 003147	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 232	WF-09082023-003147	12/4/2023	FT-FY24-10102023-003147-A	<1	FT-FY24-10102023-003147-B	<1	

WS-003148	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 232		WF-04112023-003148	12/4/2023	FT-FY24-10102023-003148-A	<1	FT-FY24-10102023-003148-B	<1
WS-003149	9/8/2023	9/8/2024	2	Combo Faucet	In classroom 230		WF-09082023-003149	12/4/2023	FT-FY24-10102023-003149-A	<1	FT-FY24-10102023-003149-B	<1
WS-003150	4/11/2023	4/11/2024	2	Combo Fountain	In classroom 230		WF-04112023-003150	12/4/2023	FT-FY24-10102023-003150-A	<1	FT-FY24-10102023-003150-B	<1
WS-003152	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 323		WF-04112023-003152	12/4/2023	FT-FY24-10102023-003152-A	<1	FT-FY24-10102023-003152-B	<1
WS-003154	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 324		WF-04112023-003154	12/4/2023	FT-FY24-10102023-003154-A	<1	FT-FY24-10102023-003154-B	<1
WS-003156	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 321		WF-04112023-003156	12/4/2023	FT-FY24-10102023-003156-A	<1	FT-FY24-10102023-003156-B	<1
WS-003163	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 316		WF-04112023-003163	12/4/2023	FT-FY24-10102023-003163-A	<1	FT-FY24-10102023-003163-B	<1
WS-003165	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 312		WF-04112023-003165	12/4/2023	FT-FY24-10102023-003165-A	<1	FT-FY24-10102023-003165-B	<1
WS-003167	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 311		WF-04112023-003167	12/4/2023	FT-FY24-10102023-003167-A	<1	FT-FY24-10102023-003167-B	<1
WS-003168	4/11/2023	4/11/2024	3	Cooler	In hallway adjacent to room 302	High Left	WF-04112023-003168	12/4/2023	FT-FY24-10102023-003168-A	<1	FT-FY24-10102023-003168-B	<1
WS-003169	4/11/2023	4/11/2024	3	Cooler	In hallway adjacent to room 302	Low Right	WF-04112023-003169	12/4/2023	FT-FY24-10102023-003169-A	<1	FT-FY24-10102023-003169-B	<1
WS-003170	4/11/2023	4/11/2024	1	Break Room	In custodians' break room 103		WF-04112023-003170	12/4/2023	FT-FY24-10102023-003170-A	<1	FT-FY24-10102023-003170-B	<1
WS-003171	4/11/2023	4/11/2024	2	Health Suite	In health suite 202I		WF-04112023-003171	12/4/2023	FT-FY24-10102023-003171-A	<1	FT-FY24-10102023-003171-B	<1
WS-007219	4/11/2023	4/11/2024	2	Bottle Filler	In hallway adjacent to restrooms		WF-04112023-007219	12/4/2023	FT-FY24-10102023-007219-A	<1	FT-FY24-10102023-007219-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003115	1/10/2023	1/10/2024	1	Food Prep Sink	In kitchen	Mid	WF-01102023-003115	12/4/2023	FT-FY24-10102023-003115-A	<1	FT-FY24-10102023-003115-B	<1
WS-003116	1/10/2023	1/10/2024	1	Food Prep Sink	In kitchen	Right	WF-01102023-003116	12/4/2023	FT-FY24-10102023-003116-A	<1	FT-FY24-10102023-003116-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003161	4/11/2023	4/11/2024	3	Combo Fountain	In classroom 307		WF-04112023-003161	12/4/2023	FT-FY24-10102023-003161-A	<1	FT-FY24-10102023-003161-B	12.9

First Re-Test (After Plumbing Check)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003161	12/5/2023	12/5/2024	3	Combo Fountain	In classroom 307		WF-12052023-003161	12/11/2023	FT-FY24-12052023-003161-A	1.3	FT-FY24-12052023-003161-B	<1