



PATTERSON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	
1	PATTERSON ELEMENTARY SCHOOL	WS- 003093	8/24/2016	1	Fountain	In classroom 132	FT-82016-003093-A	< 1	FT-82016-003093-B	< 1	
2	PATTERSON ELEMENTARY SCHOOL	WS- 003095	8/24/2016	1	Fountain	In classroom 131	FT-82016-003095-A	< 1	FT-82016-003095-B	< 1	
3	PATTERSON ELEMENTARY SCHOOL	WS- 003097	8/24/2016	1	Fountain	In classroom 127	FT-82016-003097-A	< 1	FT-82016-003097-B	< 1	
4	PATTERSON ELEMENTARY SCHOOL	WS- 003099	8/24/2016	1	Fountain	In classroom 125	FT-82016-003099-A	< 1	FT-82016-003099-B	< 1	
5	PATTERSON ELEMENTARY SCHOOL	WS- 003102	8/24/2016	1	Fountain	In classroom 115	FT-82016-003102-A	< 1	FT-82016-003102-B	< 1	
6	PATTERSON ELEMENTARY SCHOOL	WS- 003104	8/24/2016	1	Fountain	In classroom 123	FT-82016-003104-A	< 1	FT-82016-003104-B	< 1	
7	PATTERSON ELEMENTARY SCHOOL	WS- 003106	8/24/2016	1	Fountain	In classroom 119	FT-82016-003106-A	< 1	FT-82016-003106-B	< 1	
8	PATTERSON ELEMENTARY SCHOOL	WS- 003108	8/24/2016	1	Fountain	In classroom 120	FT-82016-003108-A	< 1	FT-82016-003108-B	< 1	
9	PATTERSON ELEMENTARY SCHOOL	WS- 003109	8/24/2016	1	Cooler	In hallway adjacent to restrooms	High Left	FT-82016-003109-A	< 1	FT-82016-003109-B	< 1
10	PATTERSON ELEMENTARY SCHOOL	WS- 003110	8/24/2016	1	Cooler	In hallway adjacent to restrooms	Low Right	FT-82016-003110-A	< 1	FT-82016-003110-B	< 1
11	PATTERSON ELEMENTARY SCHOOL	WS- 003112	8/24/2016	1	Cooler	In cafeteria 106	High Left	FT-82016-003112-A	< 1	FT-82016-003112-B	< 1
12	PATTERSON ELEMENTARY SCHOOL	WS- 003113	8/24/2016	1	Cooler	In cafeteria 106	Low Right	FT-82016-003113-A	< 1	FT-82016-003113-B	< 1
13	PATTERSON ELEMENTARY SCHOOL	WS- 003116	8/24/2016	1	Food Prep Sink	In kitchen	Right	FT-82016-003116-A	< 1	FT-82016-003116-B	< 1
14	PATTERSON ELEMENTARY SCHOOL	WS- 003117	8/24/2016	2	Cooler	In hallway adjacent to restrooms	High Left	FT-82016-003117-A	1.2	FT-82016-003117-B	< 1
15	PATTERSON ELEMENTARY SCHOOL	WS- 003118	8/24/2016	2	Cooler	In hallway adjacent to restrooms	Low Right	FT-82016-003118-A	< 1	FT-82016-003118-B	< 1
16	PATTERSON ELEMENTARY SCHOOL	WS- 003120	8/24/2016	2	Fountain	In classroom 223	FT-82016-003120-A	< 1	FT-82016-003120-B	< 1	
17	PATTERSON ELEMENTARY SCHOOL	WS- 003122	8/24/2016	2	Fountain	In classroom 222	FT-82016-003122-A	< 1	FT-82016-003122-B	< 1	
18	PATTERSON ELEMENTARY SCHOOL	WS- 003124	8/24/2016	2	Fountain	In classroom 224	FT-82016-003124-A	< 1	FT-82016-003124-B	< 1	
19	PATTERSON ELEMENTARY SCHOOL	WS- 003126	8/24/2016	2	Fountain	In classroom 221	FT-82016-003126-A	< 1	FT-82016-003126-B	< 1	
20	PATTERSON ELEMENTARY SCHOOL	WS- 003128	8/24/2016	2	Fountain	In classroom 220	FT-82016-003128-A	< 1	FT-82016-003128-B	< 1	
21	PATTERSON ELEMENTARY SCHOOL	WS- 003130	8/24/2016	2	Fountain	In classroom 225	FT-82016-003130-A	< 1	FT-82016-003130-B	< 1	
22	PATTERSON ELEMENTARY SCHOOL	WS- 003133	8/24/2016	2	Fountain	In staff work room 227	FT-82016-003133-A	< 1	FT-82016-003133-B	< 1	
23	PATTERSON ELEMENTARY SCHOOL	WS- 003135	8/24/2016	2	Fountain	In classroom 218	FT-82016-003135-A	< 1	FT-82016-003135-B	< 1	
24	PATTERSON ELEMENTARY SCHOOL	WS- 003137	8/24/2016	2	Fountain	In classroom 226	FT-82016-003137-A	< 1	FT-82016-003137-B	< 1	
25	PATTERSON ELEMENTARY SCHOOL	WS- 003139	8/24/2016	2	Fountain	In classroom 213	FT-82016-003139-A	< 1	FT-82016-003139-B	< 1	
26	PATTERSON ELEMENTARY SCHOOL	WS- 003141	8/24/2016	2	Fountain	In classroom 216	FT-82016-003141-A	< 1	FT-82016-003141-B	< 1	
27	PATTERSON ELEMENTARY SCHOOL	WS- 003143	8/24/2016	2	Fountain	In classroom 215	FT-82016-003143-A	< 1	FT-82016-003143-B	< 1	
28	PATTERSON ELEMENTARY SCHOOL	WS- 003145	8/24/2016	2	Fountain	In classroom 214	FT-82016-003145-A	< 1	FT-82016-003145-B	< 1	
29	PATTERSON ELEMENTARY SCHOOL	WS- 003148	8/24/2016	2	Fountain	In classroom 232	FT-82016-003148-A	< 1	FT-82016-003148-B	< 1	
30	PATTERSON ELEMENTARY SCHOOL	WS- 003150	8/24/2016	2	Fountain	In classroom 230	FT-82016-003150-A	< 1	FT-82016-003150-B	< 1	
31	PATTERSON ELEMENTARY SCHOOL	WS- 003152	8/24/2016	3	Fountain	In classroom 323	FT-82016-003152-A	< 1	FT-82016-003152-B	< 1	
32	PATTERSON ELEMENTARY SCHOOL	WS- 003154	8/24/2016	3	Fountain	In classroom 324	FT-82016-003154-A	< 1	FT-82016-003154-B	< 1	
33	PATTERSON ELEMENTARY SCHOOL	WS- 003156	8/24/2016	3	Fountain	In classroom 321	FT-82016-003156-A	< 1	FT-82016-003156-B	< 1	
34	PATTERSON ELEMENTARY SCHOOL	WS- 003159	8/24/2016	3	Fountain	In classroom 317	FT-82016-003159-A	< 1	FT-82016-003159-B	< 1	
35	PATTERSON ELEMENTARY SCHOOL	WS- 003161	8/24/2016	3	Fountain	In classroom 307	FT-82016-003161-A	< 1	FT-82016-003161-B	< 1	
36	PATTERSON ELEMENTARY SCHOOL	WS- 003163	8/24/2016	3	Fountain	In classroom 316	FT-82016-003163-A	< 1	FT-82016-003163-B	< 1	
37	PATTERSON ELEMENTARY SCHOOL	WS- 003165	8/24/2016	3	Fountain	In classroom 312	FT-82016-003165-A	< 1	FT-82016-003165-B	< 1	
38	PATTERSON ELEMENTARY SCHOOL	WS- 003167	8/24/2016	3	Fountain	In classroom 311	FT-82016-003167-A	< 1	FT-82016-003167-B	< 1	
39	PATTERSON ELEMENTARY SCHOOL	WS- 003168	8/24/2016	3	Cooler	In hallway adjacent to room 302	High Left	FT-82016-003168-A	< 1	FT-82016-003168-B	< 1
40	PATTERSON ELEMENTARY SCHOOL	WS- 003169	8/24/2016	3	Cooler	In hallway adjacent to room 302	Low Right	FT-82016-003169-A	< 1	FT-82016-003169-B	< 1
41	PATTERSON ELEMENTARY SCHOOL	WS- 003171	8/24/2016	2	Health Suite	In health suite 202I	FT-82016-003171-A	< 1	FT-82016-003171-B	< 1	