



PATTERSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Restart Date
1	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003171	Health Suite	2	In room 202I	WT-042916-3188- A	< 1	WT-042916-3188- B	< 1		
2	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003170	Classroom	1	In custodians room 103	WT-042916-3187- A	< 1	WT-042916-3187- B	< 1		
3	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003169	Cooler	3	In hallway adjacent to janitor 302 Right Low	WT-042916-3186- A	< 1	WT-042916-3186- B	< 1		
4	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003168	Cooler	3	In hallway adjesent to janitor 302 Left High	WT-042916-3185- A	< 1	WT-042916-3185- B	< 1		
5	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003167	Fountain	3	In classroom 311	WT-042916-3184- A	< 1	WT-042916-3184- B	< 1		
6	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003166	Classroom	3	In classroom 311	WT-042916-3183- A	< 1	WT-042916-3183- B	< 1		
7	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003165	Fountain	3	In classroom 312	WT-042916-3182- A	< 1	WT-042916-3182- B	< 1		
8	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003164	Classroom	3	In classroom 312	WT-042916-3181- A	< 1	WT-042916-3181- B	< 1		
9	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003163	Fountain	3	In classroom 316	WT-042916-3180- A	< 1	WT-042916-3180- B	< 1		
10	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003162	Classroom	3	In classroom 316	WT-042916-3179- A	< 1	WT-042916-3179- B	< 1		
11	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003161	Fountain	3	In classroom 307	WT-042916-3178- A	< 1	WT-042916-3178- B	< 1		
12	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003160	Classroom	3	In classroom 307	WT-042916-3177- A	< 1	WT-042916-3177- B	< 1		
13	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003159	Fountain	3	In classroom 317	WT-042916-3176- A	< 1	WT-042916-3176- B	< 1		
14	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003158	Classroom	3	In classroom 317	WT-042916-3175- A	4.4	WT-042916-3175- B	< 1		
15	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003157	Classroom	3	In room 325	WT-042916-3174- A	< 1	WT-042916-3174- B	< 1		
16	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003156	Fountain	3	In classroom 321	WT-042916-3173- A	< 1	WT-042916-3173- B	< 1		
17	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003155	Classroom	3	In classroom 321	WT-042916-3172- A	< 1	WT-042916-3172- B	< 1		
18	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003154	Fountain	3	In classroom 324	WT-042916-3171- A	< 1	WT-042916-3171- B	< 1		
19	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003153	Classroom	3	In classroom 324	WT-042916-3170- A	< 1	WT-042916-3170- B	< 1		
20	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003152	Fountain	3	In classroom 323	WT-042916-3169- A	< 1	WT-042916-3169- B	< 1		
21	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003151	Classroom	3	In classroom 323	WT-042916-3168- A	< 1	WT-042916-3168- B	< 1		
22	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003150	Fountain	2	In classroom 230	WT-042916-3167- A	< 1	WT-042916-3167- B	< 1		
23	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003149	Classroom	2	In classroom 230	WT-042916-3166- A	< 1	WT-042916-3166- B	< 1		



PATTERSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Restart Date
24	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003148	Fountain	2	In classroom 232	WT-042916-3165- A	< 1	WT-042916-3165- B	< 1		
25	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003147	Classroom	2	In classroom 232	WT-042916-3164- A	3.1	WT-042916-3164- B	< 1		
26	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003146	Classroom	2	In room 217	WT-042916-3163- A	< 1	WT-042916-3163- B	< 1		
27	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003145	Fountain	2	In classroom 214	WT-042916-3162- A	< 1	WT-042916-3162- B	< 1		
28	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003144	Classroom	2	In classroom 214	WT-042916-3161- A	< 1	WT-042916-3161- B	< 1		
29	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003143	Fountain	2	In classroom 215	WT-042916-3160- A	< 1	WT-042916-3160- B	< 1		
30	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003142	Classroom	2	In classroom 215	WT-042916-3159- A	< 1	WT-042916-3159- B	< 1		
31	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003141	Fountain	2	In classroom 216	WT-042916-3158- A	11.6	WT-042916-3158- B	< 1		
32	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003140	Classroom	2	In classroom 216	WT-042916-3157- A	< 1	WT-042916-3157- B	< 1		
33	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003139	Fountain	2	In classroom 213	WT-042916-3156- A	< 1	WT-042916-3156- B	< 1		
34	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003138	Classroom	2	In classroom 213	WT-042916-3155- A	< 1	WT-042916-3155- B	< 1		
35	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003137	Fountain	2	In room 226	WT-042916-3154- A	< 1	WT-042916-3154- B	< 1		
36	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003136	Classroom	2	In room 226	WT-042916-3153- A	< 1	WT-042916-3153- B	< 1		
37	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003135	Fountain	2	In classroom 218	WT-042916-3152- A	< 1	WT-042916-3152- B	< 1		
38	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003134	Classroom	2	In classroom 218	WT-042916-3151- A	< 1	WT-042916-3151- B	< 1		
39	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003133	Fountain	2	In teachers work room 227	WT-042916-3150- A	< 1	WT-042916-3150- B	< 1		
40	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003132	Classroom	2	In teachers work room 227	WT-042916-3149- A	4	WT-042916-3149- B	1.3		
41	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003131	Classroom	2	In staff room 219	WT-042916-3148- A	< 1	WT-042916-3148- B	< 1		
42	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003130	Fountain	2	In classroom 225	WT-042916-3147- A	< 1	WT-042916-3147- B	< 1		
43	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003129	Classroom	2	In classroom 225	WT-042916-3146- A	< 1	WT-042916-3146- B	< 1		
44	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003128	Fountain	2	In classroom 220	WT-042916-3145- A	< 1	WT-042916-3145- B	< 1		
45	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003127	Classroom	2	In classroom 220	WT-042916-3144- A	< 1	WT-042916-3144- B	< 1		
46	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003126	Fountain	2	In classroom 221	WT-042916-3143- A	< 1	WT-042916-3143- B	< 1		



PATTERSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Restart Date
47	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003125	Classroom	2	In classroom 221	WT-042916-3142- A	< 1	WT-042916-3142- B	< 1		
48	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003124	Fountain	2	In classroom 224	WT-042916-3141- A	4.1	WT-042916-3141- B	< 1		
49	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003123	Classroom	2	In classroom 224	WT-042916-3140- A	< 1	WT-042916-3140- B	< 1		
50	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003122	Fountain	2	In classroom 222	WT-042916-3139- A	< 1	WT-042916-3139- B	< 1		
51	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003121	Classroom	2	In classroom 222	WT-042916-3138- A	< 1	WT-042916-3138- B	< 1		
52	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003120	Fountain	2	In classroom 223	WT-042916-3137- A	< 1	WT-042916-3137- B	< 1		
53	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003119	Classroom	2	In classroom 223	WT-042916-3136- A	< 1	WT-042916-3136- B	< 1		
54	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003118	Cooler	2	In hallway adjacent to restrooms Right Low	WT-042916-3135- A	< 1	WT-042916-3135- B	< 1		
55	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003117	Cooler	2	In hallway adjusent to restrooms Left High	WT-042916-3134- A	< 1	WT-042916-3134- B	< 1		
56	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003116	Kitchen	1	In kitchen last from left Right	WT-042916-3133- A	< 1	WT-042916-3133- B	< 1		
57	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003115	Kitchen	1	In kitchen second from left Mid	WT-042916-3132- A	< 1	WT-042916-3132- B	< 1		
58	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003114	Kitchen	1	In kitchen first from left Left	WT-042916-3131- A	< 1	WT-042916-3131- B	< 1		
59	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003113	Cooler	1	In cafeteria 106 Right Low	WT-042916-3130- A	< 1	WT-042916-3130- B	< 1		
60	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003112	Cooler	1	In cafeteria 106 Left High	WT-042916-3129- A	< 1	WT-042916-3129- B	< 1		
61	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003111	Classroom	1	In classroom 108	WT-042916-3128- A	< 1	WT-042916-3128- B	< 1		
62	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003110	Cooler	1	In hallway adjacent to restrooms Right Low	WT-042916-3127- A	< 1	WT-042916-3127- B	< 1		
63	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003109	Cooler	1	In hallway adjusent to restrooms Left High	WT-042916-3126- A	< 1	WT-042916-3126- B	< 1		
64	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003108	Fountain	1	In classroom 120	WT-042916-3125- A	< 1	WT-042916-3125- B	< 1		
65	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003107	Classroom	1	In classroom 120	WT-042916-3124- A	< 1	WT-042916-3124- B	< 1		
66	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003106	Fountain	1	In classroom 119	WT-042916-3123- A	< 1	WT-042916-3123- B	< 1		
67	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003105	Classroom	1	In classroom 119	WT-042916-3122- A	< 1	WT-042916-3122- B	< 1		
68	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003104	Fountain	1	In classroom 123	WT-042916-3121- A	< 1	WT-042916-3121- B	< 1		
69	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003103	Classroom	1	In classroom 123	WT-042916-3120- A	< 1	WT-042916-3120- B	< 1		



PATTERSON LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Restart Date
70	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003102	Fountain	1	In classroom 115	WT-042916-3119- A	< 1	WT-042916-3119- B	< 1		
71	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003101	Classroom	1	In classroom 115	WT-042916-3118- A	< 1	WT-042916-3118- B	< 1		
72	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003100	Classroom	1	In classroom 124	WT-042916-3117- A	< 1	WT-042916-3117- B	< 1		
73	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003099	Fountain	1	In classroom 125	WT-042916-3116- A	< 1	WT-042916-3116- B	< 1		
74	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003098	Classroom	1	In classroom 125	WT-042916-3115- A	< 1	WT-042916-3115- B	< 1		
75	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003097	Fountain	1	In classroom 127	WT-042916-3114- A	< 1	WT-042916-3114- B	< 1		
76	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003096	Classroom	1	In classroom 127	WT-042916-3113- A	< 1	WT-042916-3113- B	< 1		
77	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003095	Fountain	1	In classroom 131	WT-042916-3112- A	< 1	WT-042916-3112- B	< 1		
78	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003094	Classroom	1	In classroom 131	WT-042916-3111- A	< 1	WT-042916-3111- B	< 1		
79	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003093	Fountain	1	In classroom 132	WT-042916-3110- A	< 1	WT-042916-3110- B	< 1		
80	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003092	Classroom	1	In classroom 132	WT-042916-3109- A	< 1	WT-042916-3109- B	< 1		
81	PATTERSON ELEMENTARY SCHOOL	5/4/2016	WS- 003091	Utility	1	In water valve room 135A	WT-042916-3108- A	289	WT-042916-3108- B	67.3	Non-drinking Water Source Flush	

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.

