



PATTERSON ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	PATTERSON ELEMENTARY SCHOOL	WS- 003131	12/20/2016	2	Break Room	In staff work room 219	FT-102016-003131-A	< 1	FT-102016-003131-B	< 1
2	PATTERSON ELEMENTARY SCHOOL	WS- 003170	12/20/2016	1	Break Room	In custodians' break room 103	FT-102016-003170-A	< 1	FT-102016-003170-B	< 1
3	PATTERSON ELEMENTARY SCHOOL	WS- 003132	12/20/2016	2	Break Room	In staff work room 227	FT-102016-003132-A	< 1	FT-102016-003132-B	< 1
4	PATTERSON ELEMENTARY SCHOOL	WS- 003142	12/20/2016	2	Combo Faucet	In classroom 215	FT-122016-003142-A	< 1	FT-122016-003142-B	< 1
5	PATTERSON ELEMENTARY SCHOOL	WS- 003144	12/20/2016	2	Combo Faucet	In classroom 214	FT-122016-003144-A	< 1	FT-122016-003144-B	< 1
6	PATTERSON ELEMENTARY SCHOOL	WS- 003140	12/20/2016	2	Combo Faucet	In classroom 216	FT-122016-003140-A	< 1	FT-122016-003140-B	< 1
7	PATTERSON ELEMENTARY SCHOOL	WS- 003149	12/20/2016	2	Combo Faucet	In classroom 230	FT-122016-003149-A	1.2	FT-122016-003149-B	< 1
8	PATTERSON ELEMENTARY SCHOOL	WS- 003103	12/20/2016	1	Combo Faucet	In classroom 123	FT-122016-003103-A	< 1	FT-122016-003103-B	< 1
9	PATTERSON ELEMENTARY SCHOOL	WS- 003129	12/20/2016	2	Combo Faucet	In classroom 225	FT-122016-003129-A	< 1	FT-122016-003129-B	< 1
10	PATTERSON ELEMENTARY SCHOOL	WS- 003138	12/20/2016	2	Combo Faucet	In classroom 213	FT-122016-003138-A	< 1	FT-122016-003138-B	< 1
11	PATTERSON ELEMENTARY SCHOOL	WS- 003147	12/20/2016	2	Combo Faucet	In classroom 232	FT-122016-003147-A	< 1	FT-122016-003147-B	< 1
12	PATTERSON ELEMENTARY SCHOOL	WS- 003119	12/20/2016	2	Combo Faucet	In classroom 223	FT-122016-003119-A	< 1	FT-122016-003119-B	< 1
13	PATTERSON ELEMENTARY SCHOOL	WS- 003127	12/20/2016	2	Combo Faucet	In classroom 220	FT-122016-003127-A	< 1	FT-122016-003127-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

7	PATTERSON ELEMENTARY SCHOOL	WS- 003149	1/25/2017	2	Combo Faucet	In classroom 230	FT-122016-003149-A	< 1	FT-122016-003149-B	< 1
---	-----------------------------	------------	-----------	---	--------------	------------------	--------------------	-----	--------------------	-----

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb