



# Patterson ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003099	6/23/2017	6/23/2018	1	Combo Fountain	In classroom 125	WF-62017-003099	11/20/2017	FT-FY18-62017-003099-A	<1	FT-FY18-62017-003099-B	<1	
WS-003104	6/23/2017	6/23/2018	1	Combo Fountain	In classroom 123	WF-62017-003104	11/20/2017	FT-FY18-62017-003104-A	<1	FT-FY18-62017-003104-B	<1	
WS-003108	6/23/2017	6/23/2018	1	Combo Fountain	In classroom 120	WF-62017-003108	11/20/2017	FT-FY18-62017-003108-A	<1	FT-FY18-62017-003108-B	<1	
WS-003110	6/23/2017	6/23/2018	1	Cooler	In hallway adjacent to restrooms	Right Low	WF-62017-003110	11/20/2017	FT-FY18-62017-003110-A	<1	FT-FY18-62017-003110-B	<1
WS-003112	6/23/2017	6/23/2018	1	Cooler	In cafeteria 106	Left High	WF-62017-003112	11/20/2017	FT-FY18-62017-003112-A	<1	FT-FY18-62017-003112-B	<1
WS-003113	6/23/2017	6/23/2018	1	Cooler	In cafeteria 106	Right Low	WF-62017-003113	11/20/2017	FT-FY18-62017-003113-A	<1	FT-FY18-62017-003113-B	<1
WS-003120	6/23/2017	6/23/2018	2	Combo Fountain	In classroom 223	WF-62017-003120	11/20/2017	FT-FY18-62017-003120-A	<1	FT-FY18-62017-003120-B	<1	
WS-003130	6/23/2017	6/23/2018	2	Combo Fountain	In classroom 225	WF-62017-003130	11/20/2017	FT-FY18-62017-003130-A	<1	FT-FY18-62017-003130-B	<1	
WS-003140	11/6/2017	11/6/2018	2	Combo Faucet	In classroom 216	WF-112017-003140	11/20/2017	FT-FY18-112017-003140-A	<1	FT-FY18-112017-003140-B	<1	
WS-003142	11/6/2017	11/6/2018	2	Combo Faucet	In classroom 215	WF-112017-003142	11/20/2017	FT-FY18-112017-003142-A	<1	FT-FY18-112017-003142-B	<1	
WS-003147	11/6/2017	11/6/2018	2	Combo Faucet	In classroom 232	WF-112017-003147	11/20/2017	FT-FY18-112017-003147-A	<1	FT-FY18-112017-003147-B	<1	
WS-003149	11/6/2017	11/6/2018	2	Combo Faucet	In classroom 230	WF-112017-003149	11/20/2017	FT-FY18-112017-003149-A	<1	FT-FY18-112017-003149-B	<1	
WS-003156	7/10/2017	7/10/2018	3	Combo Fountain	In classroom 321	WF-72017-003156	11/20/2017	FT-FY18-72017-003156-A	<1	FT-FY18-72017-003156-B	<1	
WS-003161	6/23/2017	6/23/2018	3	Combo Fountain	In classroom 307	WF-62017-003161	11/20/2017	FT-FY18-62017-003161-A	<1	FT-FY18-62017-003161-B	<1	
WS-003163	6/23/2017	6/23/2018	3	Combo Fountain	In classroom 316	WF-62017-003163	11/20/2017	FT-FY18-62017-003163-A	<1	FT-FY18-62017-003163-B	<1	
WS-003167	6/23/2017	6/23/2018	3	Combo Fountain	In classroom 311	WF-62017-003167	11/20/2017	FT-FY18-62017-003167-A	<1	FT-FY18-62017-003167-B	<1	
WS-003168	6/23/2017	6/23/2018	3	Cooler	In hallway adjacent to room 302	Left High	WF-62017-003168	11/20/2017	FT-FY18-62017-003168-A	<1	FT-FY18-62017-003168-B	<1
WS-003169	6/23/2017	6/23/2018	3	Cooler	In hallway adjacent to room 302	Right Low	WF-62017-003169	11/20/2017	FT-FY18-62017-003169-A	<1	FT-FY18-62017-003169-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003116	1	Food Prep Sink	In kitchen	Right	11/20/2017	FT-FY18-102017-003116-A	<1	FT-FY18-102017-003116-B	<1